

Cextral Alex

August 20, 1980

Mr. James G. Keppler, Director Directorate of Inspection and Enforcement - Region III U.S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, IL 60137

> Subject: Dresden Station Units 2 and 3

> > Additional Response to IE Bulletin

NRC Docket Nos. 50-237

Reference (a): J. G. Keppler letter to C. Reed

dated July 3, 1980.

Dear Mr. Keppler:

This letter is to provide an additional response for Dresden Units 2 and 3 to Item 5 of IE Bulletin 80-17, which was transmitted by Reference (a).

Although compliance with Item 5 of the bulletin has been previously discussed with the on-site and main office personnel of NRC Region III, our formal documentation of compliance has been inadvertently omitted. In accordance with Item 5 of the Bulletin, procedures have been developed and are being followed to monitor the scram discharge volume for residual water on a daily basis.

Please address any questions concerning this matter to this office.

Very truly yours,

Robert F. Janecek

Nuclear Licensing Administrator

Boiling Water Reactors

Director, Division of Reactor Operations Inspection

SUBSCRIBED and SWORN to before me this 2014, day

Notary Public

'AUG 2 2 1980'