



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

October 14, 1980

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Dresden Station Units 2 and 3
Quad Cities Station Units 1 and 2
Proposed Amendment to Appendix A,
Technical Specifications, to
Operating Licenses DPR-19, 25, 29, and 30
NRC Docket Nos. 50-237/249 and 50-254/265

Reference (a): D. G. Eisenhower letter to All Operating
Boiling Water Reactors (BWR's) dated
July 7, 1980

Dear Sir:

In accordance with the request in Reference (a), and pursuant to 10 CFR 50.59, Commonwealth Edison proposes to amend Appendix A, Technical Specifications, to Operating Licenses DPR-19, DPR-25, DPR-29, and DPR-30 for Dresden Units 2, 3 and Quad Cities Units 1, 2, respectively. The proposed amendments would add surveillance requirements for the scram discharge volume (SDV) vent and drain valves and LCO/surveillance requirements for RPS and control rod block SDV limit switches.

The proposed changes provide additional operational and surveillance requirements and thereby strengthen the provisions for assuring continued operability of the control rod drive system during reactor operation. As such, the proposed changes do not present an unreviewed safety concern nor do they present any additional hazard to the health and safety of the public.

The proposed changes were prepared in accordance with the guidance provided in Reference (a) and have received On-Site and Off-Site review and approval. The changes are included in Attachments 1, 2, 3, and 4 for Dresden 2, Dresden 3, Quad Cities 1, and Quad Cities 2, respectively.

Pursuant to 10 CFR 170, Commonwealth Edison has reviewed the proposed changes and determined them to be two (2) Class III and two (2) Class I Amendments. As such, a fee remittance in the amount of \$8,800.00 has been provided.


8010240203

P

Please address any questions you may have concerning this matter to this office.

Three (3) signed originals and fifty-nine (59) copies of this transmittal are provided for your use.

Very truly yours,



Robert F. Janecek
Nuclear Licensing Administrator
Boiling Water Reactors

SUBSCRIBED and SWORN to
before me this 14TH,
day of October, 1980



Notary Public

cc: RIII Inspector, Dresden
RIII Inspector, Quad Cities