

### LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7	0	1	I	L	D	R	S	3	0	0	-	0	0	0	0	0	0	-	0	0	4	1	1	1	1	4	5
LICENSEE CODE								LICENSE NUMBER												LICENSE TYPE				CAT 58			

7	0	1	L	0	5	0	0	0	2	4	9	1	2	2	0	8	0	0	1	0	2	8	1	9
REPORT SOURCE			DOCKET NUMBER									EVENT DATE				REPORT DATE								

**EVENT DESCRIPTION AND PROBABLE CONSEQUENCES**

0 2 | During unit shutdown while performing quarterly timing surveillance of Main Steam Isolation Valves, valve 3-203-2D had a closure time of 2.8 seconds. Tech Spec. Table 0 3 | 3.7.1 requires closure time limits of between 3 and 5 seconds. Minimal effect upon 0 4 | public health and safety because remaining MSIV closure times were within Tech. Spec. 0 5 | limits and all valves were operable. There have been similar occurrences, the last 0 6 | being R.O. #80-030/03L-0.

7	0	9	C	D	E	B	V	A	L	V	E	X	F	D			
SYSTEM CODE			CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE					COMP. SUBCODE		VALVE SUBCODE			
LER/RO REPORT NUMBER			EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.						
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
A		Z		Z		Z		0 0 0 0		N		N		N		C 6 6 5	

**CAUSE DESCRIPTION AND CORRECTIVE ACTIONS**

1 0 | MSIV 3-203-2D timing mechanism become misadjusted because of leaking hydraulic dashpot. 1 1 | O-ring on dashpot was deteriorated. Repairs to MSIV 3-203-2D included O-ring re- 1 2 | placement, hydraulic oil addition and timing adjustment, valve closure time was then 1 3 | checked and found to be 3.7 secs. The quarterly valve timing surveillance will con- 1 4 | tinue to be performed to ensure proper closure times are maintained.

7	1	5	G	0	0	0	0	N/A	B	Operator Observation				
FACILITY STATUS			% POWER				OTHER STATUS		METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
ACTIVITY - CONTENT			RELEASED - OF RELEASE					AMOUNT OF ACTIVITY			LOCATION OF RELEASE			
PERSONNEL EXPOSURES			NUMBER		TYPE		DESCRIPTION							
PERSONNEL INJURIES			NUMBER		DESCRIPTION									
LOSS OF OR DAMAGE TO FACILITY			TYPE									DESCRIPTION		
PUBLCITY ISSUED			DESCRIPTION									NRC USE ONLY		



Commonwealth Edison

# DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
	0	12	3	80 - 100

**PART 1** TITLE OF DEVIATION: MSIV 3-203-2D Closure Time Not Within Limits

SYSTEM AFFECTED: 1600

PLANT CONDITIONS: Primary Containment

MODE: Shutdown PWR(MWT): 0 LOAD(MWE): 0

TESTING: YES  NO

OCCURRED DATE: 12-20-80 TIME: 0405

DESCRIPTION OF EVENT: During quarterly MSIV timing test, valve 3-203-2D closed at 2.8 seconds.

DESCRIPTION OF CAUSE: Unknown

OTHER APPLICABLE INFORMATION: Valve was closed and logged as such. Tech. Spec. limit is a closure time between 3 and 5 seconds.

EQUIPMENT FAILURE	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	DR NO.	N/A	WR NO.	N/A	RESPONSIBLE SUPERVISOR	J. Gilligan	DATE	12-20-80
-------------------	--	--------	-----	--------	-----	------------------------	-------------	------	----------

**PART 2** OPERATING ENGINEERS COMMENTS: The valve will be readjusted to meet Tech. Spec. timing requirements prior to reactor startup.

TYPE OF DEVIATION REPORTABLE OCCURRENCE	EVENT OF POTENTIAL PUBLIC INTEREST	TECH SPEC VIOLATION	NON-REPORTABLE OCCURRENCE	ANNUAL REPORTING	SAFETY-RELATED WR ISSUED
<input type="checkbox"/> 14 DAY <input type="checkbox"/> 10CFR21	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
<input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.b					

REPORTABLE OCCURRENCE NUMBER	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION
<input checked="" type="checkbox"/> 80-46/03L-0		R. M. Ragan 12/22/80 0600 TITLE DATE TIME
		TITLE DATE TIME

24-HOUR NRC NOTIFICATION	PROMPT OFF-SITE NOTIFICATION
<input checked="" type="checkbox"/> In Person TPH Tom Tongue 12-22-80 0900 REGION III DATE TIME	F. Palmer 12/22/80 10:33 TITLE DATE TIME
<input type="checkbox"/> TGM REGION III & COL DATE TIME	TITLE DATE TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC

REVIEW AND COMPLETED: Michael Wright 12/22/80  
OPERATING ENGINEER DATE

ACCEPTANCE BY STATION REVIEW AS REQUIRED

DATE: 1/2/81

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION

*J. Brunner* 1-5-81  
*Michael Wright* 1-5-81  
*Douglas K. Scott* 1/6/81  
STATION SUPERINTENDENT DATE