

(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	I	L	D	R	S	3	2	0	0	-	0	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4	5
7	8	9	14	15	25	26	30	57	58																			
LICENSEE CODE		LICENSE NUMBER						LICENSE TYPE					CAT		58													

0	1	L	6	0	5	0	0	0	2	4	9	7	0	1	1	3	8	1	8	0	1	2	8	8	1	9
7	8	60	61	65	66	67	68	69	74	75	80															
CON'T		REPORT SOURCE		DOCKET NUMBER						EVENT DATE				REPORT DATE												

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation with reactor level instrument surveillance in progress, level

0 3 | switch LIS 3-263-58A tripped at less than the Tech. Spec. limit (Table 3.2.1) of 84

0 4 | inches. The safety significance of this event was minimal since the remaining

0 5 | three instruments were operable. There was no effect on public health or safety.

0 6 | Previous occurrences: R.O. 76-57/03L, Docket 50-237; 77-51/03L, 80-23/03L and

0 7 | 80-24/03L Docket 50-249.

0	9	S	D	E	E	I	N	S	T	R	U	S	Z						
7	8	9	10	11	12	13	18	19	20										
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE					COMP. SUBCODE		VALVE SUBCODE						

17	8	1	—	0	0	2	0	3	L	—	0
21	22	23	24	26	27	28	29	30	31	32	
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause is attributed to setpoint drift. The instrument was immediately adjusted

1 1 | and tested, with satisfactory results. Subsequent tests were performed, and each

1 2 | time the results were satisfactory. DIS 500-2 will continue to be done monthly.

1 3 |

1 4 |

1	5	E	0	9	1	N/A	B	Instrument Surveillance		
7	8	9	10	12	13	44	45	46		
FACILITY STATUS		% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	

1	6	Z	Z	N/A	N/A				
7	8	9	10	11	44				
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			

1	7	0	0	0	Z	N/A			
7	8	9	11	12	13				
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			

1	8	0	0	0	N/A		
7	8	9	11	12			
PERSONNEL INJURIES		NUMBER		DESCRIPTION			

1	9	Z	N/A				
7	8	9	10				
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION			

2	0	N	N/A				
7	8	9	10				
ISSUED DESCRIPTION		PUBLCITY		NRC USE ONLY			

8102100458

P. Holland

PHONE: 815-942-2920 Ext. 483

U.S. NUCLEAR REGULATORY COMMISSION