NRC FORM 366 (7-77) U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I L D R S 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T
0 1 | REPORT SOURCE L (6) | DOCKET NUMBER 0 5 0 0 0 2 3 7 (7) | EVENT DATE 0 1 0 5 8 1 (8) | REPORT DATE 0 1 2 9 8 1 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During Unit 2 refueling outage LPCI Test Spray Valve failed to shut electrically.
0 3 One set of thermal contacts would not reset. The safety significance was minimal
0 4 since the valve could be manually shut and the reactor was in cold shutdown. There
0 5 was no effect on public health or safety. This is the first occurrance of this type
0 6 for this valve
0 7
0 8

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
S F (11)	E (12)	A (13)	V A L V O P (14)	A (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 1	—	0 0 2	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
A (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	Y (24)	N (25)	L 2 0 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of failure was stuck auxiliary contacts. The auxiliary contacts were
1 1 replaced and valve operated properly. Motor Contactor breaker compartments will
1 2 continue to be checked during outages per established procedures.
1 3
1 4

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	H (28)	0 0 0 (29)	N/A	A (31)	Operator Observation

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	N/A

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	N/A	

8102100472

NAME OF PREPARER K. Zirwas PHONE: 815-942-2920 Ext. 422

GPO 917-926