Enclosure 1

EGG-EA-5065 November 1979

5

SUMMARY OF THE DRESDEN UNIT 2 PIPING CALCULATIONS PERFORMED FOR THE SYSTEMATIC EVALUATION PROGRAM

M. E. Nitzel

U.S. Department of Energy Idaho Operations Office • Idaho National Engineering Laboratory



This is an informal report intended for use as a preliminary or working document

U. S. Nuclear Regulatory Commission Under DOE Contract No. DE-AC07-67ID01570 FIN No. A6250





INTERIM REPORT

Accession No. ___

Report No. ____EGG-EA-5065

Contract Program or Project Title:

Code Assessment and Applications Program

Subject of this Document:

Summary of The Dresden Unit 2 Piping Calculations Performed for The Systematic Evaluation Program

Type of Document:

Informal Technical Report

Author(s):

M. E. Nitzel

Date of Document:

November 1979

Responsible NRC Individual and NRC Office or Division:

K. N. Jabbour, NRC-DOR

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

EG&G Idaho, Inc. Idaho Falls, Idaho 83401

Prepared for the U.S. Nuclear Regulatory Commission and the U.S. Department of Energy Idaho Operations Office Under contract No. EY-76-C-07-1570 NRC FIN No.

A6250

INTERIM REPORT

ABSTRACT

The Dresden Unit 2 recirculation loop and low pressure coolant injection piping systems were analyzed in support of the Nuclear Regulatory Commission's Systematic Evaluation Program. Audit calculations to verify the original analyses and new calculations incorporating current regulations and standards were performed. In addition, a piping system composed of small diameter piping was analyzed to verify design charts used to locate seismic supports. Pertinent details concerning each analysis are contained within the report.

i

SUMMARY

This report describes the analyses performed on the Dresden Nuclear Power Station, Unit 2, piping in support of the Nuclear Regulatory Commission's Systematic Evaluation Program (SEP). Calculations were performed on the recirculation and Low Pressure Coolant Injection (LPCI) pipelines to verify the original analyses. New calculations were also performed on these systems to investigate the effects of certain modeling techniques and to obtain analyses which incorporate current ASME Code and Regulatory Guide criteria. A representative piping system was also analyzed to provide. verification to design charts which are used to locate seismic supports on small diameter piping. Results of these analyses were compared to ASME Code requirements for Class 2 piping systems at the appropriate service conditions. All pertinent assumptions and methodology employed are discussed in the report.

The analyzed piping systems were chosen to be representative of the various piping size ranges and analysis methods used in the design of the plant. The results from these analyses are intended to be used as information to aid in the assessment of piping structural adequacy under Safe Shutdown Earthquake (SSE) loading when considering current seismic requirements.

11

CONTENTS

	Page
ABSTRACT	. 1
SUMMARY	. 11
I. INTRODUCTION	. 1
II. PIPING SYSTEM DESCRIPTION	. 4
1. STRUCTURAL DESCRIPTION	. 4
2.1.1Recirculation Loop2.1.2LPCI Suction2.1.3Small Piping Seismic Example	. 4 . 4 . 9
2. MATERIAL AND GEOMETRIC DATA	. 9
III. DESIGN AND SERVICE CONDITIONS	. 17
1.DESIGN CONDITIONS	. 17 . 17 . 19 . 19 . 19
IV. PIPING SYSTEM STRUCTURAL ANALYSES	• 20
 RECIRCULATION LOOP ANALYSES LPCI SUCTION PIPING ANALYSES SMALL PIPING SEISMIC EXAMPLE ANALYSES 	· 20 · 27 · 33
V. ASME BOILER AND PRESSURE VESSEL CODE, SECTION III, CLASS 2 STRESS ANALYSES	• 35
 MINIMUM THICKNESS CHECK	· 36 · 37
5.2.1Recirculation Loop <t< td=""><td>• 38 • 51 • 56</td></t<>	• 38 • 51 • 56
VI. CONCLUSIONS	. 61
 RECIRCULATION LOOP. LPCI SUCTION. SMALL PIPING SEISMIC EXAMPLE. 	. 61 . 62 . 62
VII. REFERENCES	. 64

i. T

3

避

iii

APPENDIX

		Page
APPENDIX /	A - NUPIPE-II Computer Program Description	A-i
APPENDIX 8	B - Benchmark Problem to Assess Spatial Combination Method for Response Spectrum Analysis	B-i
APPENDIX	C - Microfiche Copies of NUPIPE-II Computer Runs	C-i
APPENDIX (D - Original Analysis LPCI Suction Piping Nozzle Loads	D-i
	TABLES	
Ι.	Material and Geometric Data for Recirculation Loop	15
II.	Material and Geometric Data for LPCI Suction Piping .	- 15
III.	Material and Geometric Data for Small Piping Seismic Example	16
IV.	Piping System Valve Weights and Centers of Gravity - Recirculation Loop Piping	22
۷.	Piping System Valve Weights and Centers of Gravity - LPCI Suction Piping	27
VI.	Minimum Thickness Parameters - Recirculation Loop Piping	36
VII.	Minimum Thickness Parameters - LPCI Suction Piping	36
VIII.	Dresden Recirculation Loop Piping - PI Model - Summary of Natural Frequencies and Periods of Vibration	41
IX.	Dresden Recirculation Loop Piping - P2 and P3 Models - Summary of Natural Frequencies and Periods of Vibration	42
Χ.	Summary of ASME Code, Class 2, Equation 9, Stress Values - Pl Model Considering Restraint Stiffness Variations, OBE Load Case (P + DW + OBE)	43
XI.	Summary of ASME Code, Class 2, Equation 9, Stress Values - P2 and P3 Models, Two Methods, OBE Load Case (P + DW + OBE)	44

Arrile.

1v

TABLES (Cont'd)

		Page
XII.	Summary of ASME Code, Class 2, Equation 9, Stress Values - Current Criteria Analysis, SSE Loading (P + DW + SSE)	45
XIII.	Stress Comparison at Identical Points - OBE loading, 0.1g ZPGA	46
XIV.	Support Load Summary - Recirculation Loop Pl Model - Seismic Loads Only	47
XV.	Support Load Summary - Recirculation Loop P2 and P3 Models - Seismic Loads Only	48
XVI.	Anchor Load Summary - Recirculation Loop P1 Model - Seismic Loads Only	49
XVII.	Anchor Load Summary - Recirculation Loop P2 and P3 Models - Seismic Loads Only	50
XVIII.	Dresden Unit 2 LPCI Suction Piping Model - Natural Frequencies and Periods of Vibration	52
XIX.	Summary of ASME Code, Class 2, Equation 9, Stress Values - LPCI Model, Two Methods, SSE Load Case	53
XX.	Support Load Summary - LPCI Model - Seismic Loads Only	54
XXI.	Anchor Load Summary - LPCI Model - Seismic Loads Only	55
XXII.	Summary of Natural Frequencies and Periods of Vibration for Small Piping Example Problem	57
XXIII.	Summary of ASME Code, Class 2, Equation 9, Stress Values - Small Piping Example Problem, SSE Load Case (P + DW + SSE)	58
XXIV.	Support Load Summary - Small Piping Example Problem - Seismic Loads Only	59
XXV.	Anchor Load Summary - Small Piping Seismic Example Model - Seismic Loads Only	60

۷

¥...

FIGURES

		Page
1.	General Layout of Dresden Unit 2 Recirculation Loop Piping	. 5
2.	Computer Model Plot - Dresden Recirculation Loop Piping - Pl Model	6
3.	Computer Model Plot - Dresden Recirculation Loop Piping - P2 Model	7
4.	Computer Model Plot - Dresden Recirculation Loop Piping - P3 Model	8
5.	Dresden Unit 2 LPCI Suction Piping Model	10
6.	Small Piping Example Problem Finite Element Model Including Vertical Supports	13
7.	Small Piping Example Problem Finite Element Model Omitting Vertical Supports	14
8.	Response Spectrum, Mass Point 7, 0.5% Damping, Dresden Recirculation Loop Piping	26
9.	Response Spectrum, Mass Point 7, East-West, 3% Damping	28
10.	Response Spectrum, Mass Point 7, North-South, 3% Damping .	29
11.	Response Spectrum, Mass Point 8, North-South, 3% Damping .	31
12.	Response Spectrum, Mass Point 8, East-West, 3% Damping	32
13.	Response Spectrum, Mass Point 8, East-West, 2% Damping	-34

vf

I. INTRODUCTION

The U.S. Nuclear Regulatory Commission (NRC) is conducting the Systematic Evaluation Program (SEP). This program includes a plant-by-plant reassessment of the safety of 11 older operating reactors. Unit 2 of the Dresden Nuclear Power Station is an 800 MWe Boiling Water Reactor (BWR) located at Morris, Illinois. This reactor began commercial operation in August of 1970 and has been included for review within the SEP.

Briefly, SEP goals will be accomplished by reviewing typical components and systems with the objective of assessing their integrity and capability of achieving and maintaining a safe shutdown condition in the reactor during and after a postulated seismic event. The assessment of this subgroup of equipment will then be used to infer similar capabilities in other safety related systems. Judgment would indicate that a positive finding with respect to a carefully chosen subgroup of systems would imply assurance of the adequacy of similarly designed systems.

1

653. `a`

> This report describes the analyses performed on the Dresden Unit 2 recirculation loop and Low Pressure Coolant Injection (LPCI) piping systems. A representative piping system was also analyzed to provide verification to design charts which were used to locate seismic supports on small diameter piping.

The recirculation loop piping was originally analyzed for seismic loading conditions using the finite element methods and procedures

described in the Reference 1 report. The LPCI pump suction piping was originally qualified for seismic loading by performing a "seismic coefficient" type analysis. This means that acceleration values are used to determine a set of "equivalent" loads which are then applied statically to the piping mathematical model. Piping design charts were originally developed to be used for the seismic qualification of piping of eight-inch nominal size and below. The small diameter piping seismic example is used to verify the acceptability of these charts.

The three types of analyses described above have been identified as being typical of the methods used to seismically qualify Dresden Unit 2 piping systems. The purposes of these analyses are to simulate and thus verify the methodology used in the original analyses and to analyze the subject piping using current ASME Code and Regulatory Guide guidelines. Enough information will be produced such that the accuracy and adequacy of the modeling techniques used in the original analysis may be assessed. The results of these analyses may then be used to develop a level of confidence in the seismic qualification of the piping under currently accepted criteria.

The ASME Boiler and Pressure Vessel $Code^{[2]}$ (elsewhere referred to as the ASME Code) was used as the criterion for evaluating piping structural adequacy. The governing conditions, engineering assumptions, and analytical techniques used in completing the analyses are described herein. The report is organized such that each major section contains a subsection pertinent to each piping system analyzed.

This work was performed for and funded by the United States Nuclear Regulatory Commission.

;;

ġ.

÷.

<u>.</u>

II. PIPING SYSTEM DESCRIPTION

1. STRUCTURAL DESCRIPTION

1.1 Recirculation Loop

The recirculation loop consists of 28-inch piping which discharges fluid from each pump into a 22-inch manifold. Riser piping of 12-inch nominal size carries the fluid from the manifold to nozzles distributed around the circumference of the reactor vessel. Pump suction piping of 28-inch nominal size and a 20-inch shutdown line are also included. The general layout of the piping is shown in Figure 1.

Three separate finite element models corresponding to the Reference 1 designations of P1, P2, and P3 were developed for the recirculation loop piping. Plots of these models are shown in Figures 2 through 4. Nodes, masspoints, and restraint locations are indicated. The P1 model includes the 28-inch pump discharge lines, 22-inch manifold and the 12-inch riser piping. The P2 model includes the loop two 28-inch pump suction line and the 20-inch shutdown line. The P3 model is comprised of the loop one 28-inch pump suction line.

1.2 LPCI Suction Piping

3:

The LPCI suction line consists of 24-inch piping which carries fluid from a 24-inch ring header. The piping changes diameter at a tee



General Layout of Dresden Unit 2 Recirculation Loop Piping (NOTE: Not to Scale)







Figure 3 Computer Model Plot - Dresden Recirculation Loop Piping - P2 Model



Computer Model Plot - Dresden Recirculation Loop Piping - P3 Model

and a reducer such that two 14-inch lines are used to carry fluid to the two LPCI pumps. A portion of the 24-inch ring header piping was also included in this model for purposes of continuity. The LPCI mathematical model is shown in Figure 5. Nodes, element types, masspoints, and restraint locations are indicated.

1.3 Small Piping Seismic Example

The small piping seismic example consists of eight-inch piping extending from a tank anchor through a long radius elbow and a pipe bend to arrive at the terminating anchor. Figure 6 contains the finite element model including vertical supports while Figure 7 contains the finite element model which results when the vertical supports are assumed not effective during seismic loading.

Listings of geometric and structural data used in the analyses of all piping models are included in the computer output contained in Appendix C.

2. MATERIAL AND GEOMETRIC DATA

Tables I, II, and III list the significant material and geometric data used in the recirculation loop, LPCI pump suction, and small piping seismic example analyses, respectively.











Small Piping Example Problem Finite Element Model Including Vertical Supports







·				:
O.D. (inches)	28.3	21.3	20.0	12.8
Thickness (inches)	1.20	1.09	1.03	.687
Weight (lbs/inch)	51.3	33.5	28.7	12.7
Material	All Piping -	SA 358, TP	304 Stainl	ess Steel
E _{cold} (10 ⁶ psi)	28.3	28.3	28.3	28.3
S (575°F) (psi)	15900	15900	15900	15900
S _y (psi)	30000	30000	30000	30000
$\alpha \overline{T}$ (in./ft)	0.0568	0.0568	0.0568	0.0568
· · ·				

TABLE I

MATERIAL AND GEOMETRIC DATA FOR RECIRCULATION LOOP

TABLE II

MATERIAL AND GEOMETRIC DATA FOR LPCI SUCTION PIPING

O.D. (inches)	24.0	14.0	
Thickness (inches)	0.375	0.375	
Weight (lbs/inch)	23.2	9.52	
Material	A106 GRB	A106 GRB	
E _{cold} (10 ⁶ psi)	27.9	27.9	
S (165°F) (psi)	15000	15000	
S _y (psi)	35000	35000	
$\alpha \overline{T}$ (in./ft)	0.0023	0.0023	

TABLE III

MATERIAL AND GEOMETRIC DATA FOR SMALL PIPING SEISMIC EXAMPLE

والمراجع المراجع المراجع المنافع المراجع المراجع المراجع والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع	
O.D. (inches)	8.63
Thickness (inches)	0.375
Weight (lbs/inch)	5.27
Material	A106, GR.B.
E _{cold} (10 ⁶ psi)	29.0
S'(100°F) (psi)	15000 😁
S _y (psi)	35000
$\alpha \overline{T}$ (in./ft)	0.0023
•	

As used in the previous tables, $\alpha \overline{T}$ is the overall thermal growth parameter of the pipe. α is the average thermal coefficient of expansion and \overline{T} is the average temperature of the pipe. Insulation weight is not included in the above tables.

III. DESIGN AND SERVICE CONDITIONS

The following sections list the various design and operating conditions utilized in the analyses. It is emphasized that all systems were analyzed as ASME Code Class 2.

1. DESIGN CONDITIONS

3.1.1 Recirculation Loop

Design Pressure - 1250 PSI Design Temperature - 575°F

3.1.2 LPCI Suction

7.

m Ø

Design Pressure - 70 PSI Design Temperature - 165°F

3.1.3 <u>Small Piping Seismic Example</u>

Design Pressure - O PSI Design Temperature - 70°F

2. SERVICE LEVEL A

Service Level A was referred to as the normal operating condition in previous versions of the ASME code. Operating temperature and pressures are listed below.

3.2.1 Recirculation Loop

Operating Pressure - 1250 PSI Operating Temperature - 575°F

3.2.2 LPCI Suction

1

Operating Pressure - 70 PSI Operating Temperature - 100°F

3.2.3 Small Piping Seismic Example

Operating Pressure - O PSI Operating Temperature - 70°F

It should be noted that the temperatures and pressures listed for design conditions and Service Level A are those quantities used in the analyses described herein. In most cases, only one value was available and was therefore used for both the design and operating values. Since no pressure or temperature information was obtained for the small piping example problem, the values listed above were assumed. While the values shown above may not be exactly correct, they do represent the best available information and are sufficiently accurate to achieve the main objective of the SEP - assessing plant safety relative to current criteria.

3. SERVICE LEVEL B

Service Level B was referred to as the upset operating condition in previous versions of the ASME Code. The only Service Level B loading condition considered was the Operating Basis Earthquake (OBE). The OBE loading case was considered in the simulation of the original analyses of the recirculation and LPCI systems.

4. SERVICE LEVEL C

Service Level C was referred to as the emergency condition in former versions of the ASME Code. No Service Level C load cases were considered for the analyses described herein.

5. SERVICE LEVEL D

Sec.

38

Service Level D was referred to as the faulted condition in former versions of the ASME Code. Safe Shutdown Earthquake (SSE) was considered as the Service Level D loading for the analyses described in this report.

IV. PIPING SYSTEM STRUCTURAL ANALYSES

The piping systems were analyzed for the various structural load cases using the computer program NUPIPE-II, a proprietary program developed by Nuclear Services Corporation. NUPIPE-II capabilities are briefly described in Appendix A. Idaho National Engineering Laboratory (INEL) program modules LCPIP6L and C0059001 were used for the analyses.

1. RECIRCULATION LOOP ANALYSES

Three separate finite element models corresponding to the Reference 1 designations of Pl, P2, and P3 were developed for the recirculation loop. These models are as shown in Figures 2 through 4. Certain pipe and valve weight data used in these calculations were obtained from the Reference 1 report. Additional information and piping drawings were provided by NRC-DOR.

Important assumptions used for the recirculation loop analyses are listed below:

 Valves were simulated by placing concentrated weights at appropriate node points. This approach was used to verify the original finite element model. The valve weights and node locations are shown in Table IV.

 No account was taken for interaction of the shutdown line on the P3 model. This shutdown line is indicated on drawings

provided by DØR; however, little detail is provided. No attempt was made to simulate any shutdown line interaction in the audit calculation P3 model; thus, similarity to the original analysis P3 model was maintained.

- 3. Some values of spring hanger hot loads, spring stiffnesses of spring hangers and sway braces, and snubber stiffnesses were assumed. This was due to the poor quality of reproduction on the drawings used. As much information as possible was taken from the drawings; however, when unreadable, assumptions of necessary values were based on the known information coupled with analytical experience and engineering judgment. All stiffness and applied load values used are listed with the NUPIPE-II input data contained in Appendix C.
- 4. No pipe supports are shown mounted to the 20-inch shutdown line in the P2 model. Insufficient detail exists on the drawings provided to determine if supports are present; thus, none were assumed.
- 5. The drawings used for the audit calculations indicated three snubbers which, apparently, were not included in the original (Reference 1) analysis of the Pl model. These snubbers were included in the Pl model for the "current criteria" calculations but were omitted in other runs required to verify the original analyses.

5

- 6. It was uncertain whether the two piping crosses on the 22-inch manifold piping were forged or fabricated components. Thus, forged tee stress intensification factors were used as an estimate of the stress intensification at these two points.
 - 7. Further assumptions made for the audit calculations were:
 - a. All components were forged and butt welded (flush).
 - b. All components meet ANSI B16.9 and B16.28 standards.
 - c. The requirements of the ASME Code, Section III, Subarticle NC-3640 are satisfied.

TABLE IV

PIPING SYSTEM VALVE WEIGHTS ' AND CENTERS OF GRAVITY RECIRCULATION LOOP PIPING

Model	Node	Weight (1b)	C.G. Distance From Pipe Axis (in.)
P1	10	17220	0
P1	85	6280	0
P1	100	6280	0
P1	148	17220	0
P2	45	17000	0
P2	70	5720	0
P3	50	17220	0

10

The recirculation system was analyzed for the following loads:

1. Deadweight

いては語る

- North-south plus vertical OBE (Square Root Sum of the Squares (SRSS) combination technique "stiff" restraints).
- North-south plus vertical OBE (absolute sum combination technique "stiff" restraints).
- East-west plus vertical OBE (SRSS combination technique "stiff" restraints).
- East-west plus vertical OBE (absolute sum combination technique "stiff" restraints).

6. Repeat of load Case 2 using "reasonable" restraint stiffnesses.

7. Repeat of load Case 3 using "reasonable" restraint stiffnesses.

8. Repeat of load Case 4 using "reasonable" restraint stiffnesses.

9. Repeat of load Case 5 using "reasonable" restraint stiffnesses.

10. SSE using SRSS combination of modal response from "current criteria" three directional earthquake and "reasonable" support stiffnesses.

The response spectrum shown in Figure 8 was used to verify the original analysis OBE response. The data contained in Figure 8 have been normalized to a 0.1 g Zero Period Ground Acceleration (ZPGA). Mass point seven data were used because the elevations of the 12-inch riser anchors were at approximately the same elevation as this masspoint. Since the north-south and east-west OBE response spectra are nearly identical, the plot contained in Figure 8 was used to represent both of the response directions. Vertical spectra were taken to be 2/3 times the horizontal spectrum.

The many variations of OBE loading listed above were considered in order to satisfy several objectives. The original analysis (References 1) was performed using two directional earthquakes and high (rigid) stiffness 37 values for beam type seismic supports. The SRSS method was used to combine modal results in the original analysis. The maximum stresses reported in Reference 1 are without regard to the direction of the earthquake used for 1.11 loading. The original analysis was simulated by the north-south plus vertical and east-west plus vertical load cases using the SRSS method of combining modal results and "rigid' restraint stiffnesses for beam-type seismic supports. The absolute sum method of combining dynamic analysis results was also commonly used during the time period in which the original analysis was performed. Computer runs using this method were made in order to assess the resulting differences in calculated stress levels. The version of NUPIPE-II used throughout these analyses performs absolute summations only on a resultant level. Therefore, the technique employed on the absolute sum computer runs was to perform single directional response spectra analyses and then combine the resultants by absolute summation.

This was done for both X+Y (north-south + vertical) and Z+Y (east-west + vertical) combinations. This technique will indicate an upper bound to be expected on the results of an analysis using the SRSS combination method. A further discussion of various combination methods and test problems run at the INEL is presented in Appendix B. Restraint stiffnesses of 1.0 \times 10¹² lb/in. were used to simulate the "rigid" stiffnesses of beam-type seismic supports. Values of 1.0 \times 10⁶ lb/in. were chosen as being a better representation of the actual beam stiffnesses and were used in the loading cases as listed above to determine if any significant differences in system response would occur due to the resulting increase in flexibility. It should be noted that the P2 and P3 models did not contain any beam-type seismic supports. Thus, the computer runs containing restraint stiffness variations apply only to the Pl model. The purposes of the analyses described above are to simulate the original analysis and to produce enough information such that the accuracy and adequacy of the modeling techniques used in the original analysis may be assessed.

ē.

Ċ.

蕔.

麟

Analyses using the P1, P2, and P3 recirculation loop models were also performed using the response spectra shown in Figures 9 and 10. These spectra were taken from Reference 2 for mass point seven at three-percent damping for the SSE load case. Modal responses were combined using the SRSS method. These runs were made using current ASME Code (Reference 3) criteria and are in compliance with Regulatory Guide 1.92. The results of "current criteria" analysis will be used to assess the margin of safety under current standards and regulations.

Microfiche copies of all computer runs are contained in Appendix C. Paper copies of the computer output were not included because of the large volume.



2. LPCI SUCTION PIPING ANALYSES

The finite element model representing the LPCI suction piping is shown in Figure 5. The required physical data were provided by NRC-DOR. In addition, it was assumed that all components were forged and butt welded, that all components met ANSI B 16.9 and B16.28 standards, and that the requirements of the ASME Code, Section III, Subarticle NC-3640 are satisfied. The valve weights and centers-of-gravity for this system are shown in Table V.

TABLE V

Valve	Weight (1b)	C.G. Distance From Pipe Axis (in.)
٧7	1120	24
٧8	1299	24
V.9	1120	24
V10	1299	24
V11	3284	24
		· ·

2

......

PIPING SYSTEM VALVE WEIGHTS AND CENTERS OF GRAVITY -LPCI SUCTION PIPING

The LPCI system was analyzed for the following loads:

1. Deadweight

なたちちろう

- 2. Seismic coefficient
- 3. "Current criteria" SSE




The seismic coefficient analysis was performed to simulate the original analysis of the LPCI suction piping. The procedure followed was to use acceleration values to determine a set of "equivalent" loads which were then applied statically to the piping mathematical model. A horizontal acceleration of 0.7 g applied perpendicular to the pipe axis and a vertical acceleration of 0.067 g were used for the seismic coefficient load case. The response spectra data contained in Figures 11 and 12 were used in the horizontal directions to perform the SSE analysis using current modeling practice, standards, and regulations. These spectra were obtained from Reference 2. The spectral accelerations of Figure 12 were also used as the vertical direction data after a scaling factor of 2/3 was applied. The modal responses of the response spectra run were combined using the SRSS method. Support stiffnesses of 1.0 \times 10⁷ lb/in. were considered reasonable estimates and, thus, were used at all support locations. This stiffness is slightly higher than the values used on the Recirculation Loop Piping. Exact support Geometries were not known; however, from the available information it appeared likely that these supports were somewhat shorter and, thus, possibly stiffer than the other beam type supports. It is reiterated that these are assumed values and are considered to be reasonable for the pipe size under consideration. Stiffnesses of 2.0 X 10⁵ 1b/in. were used to simulate the stiffness of the adjacent piping at nodes 215 and 300. Continuance of the piping at these points was indicated by dashed lines on the system isometric drawings, however, no further detail was obtainable.

Microfiche copies of all LPCI computer runs are contained in Appendix C.



.

чċ.

÷.





3. SMALL PIPING SEISMIC EXAMPLE ANALYSES

Two configurations of the small piping seismic example problem were analyzed. Figure 6 contains the finite element model including vertical supports while Figure 7 contains the finite element model which results when the vertical supports are assumed not effective during seismic loading. Required physical data were provided by NRC-DOR. It was assumed that all components were forged and butt welded, that all components met ANSI B16.9 and B16.28 standards, and that the requirements of the ASME Code, Section III, Subarticle NC-3640 are satisfied. The only valve included in this system weighed 1000 pounds and was assumed to have its center of gravity 15 inches from the axis of the pipe. Both models were analyzed using currently acceptable modeling practice and reasonable $(2.0 \times 10^5 \text{ lb/in.})$ values of support stiffness. Additional computer runs were made using support stiffness values of 10 times the bending stiffness of a typical pipe section spanning two adjacent supports. This stiffness value was 6.8 X 10⁶ lb/in. The response spectrum shown 😤 in Figure 13 was used in all small piping example problem computer runs. This spectrum was also taken from Reference 2. A scaling factor of 2/3 was applied to the Figure 13 spectrum to obtain vertical spectral data. Modal responses were combined using the SRSS method. The small piping example problem was analyzed to provide information which would help determine the degree of conservatism in the original design charts.

開設などです。

- - - Histonian

ind the second second

Acceleration, a, (g's)



Figure 13 Response Spectrum, Mass Point 8, East-West, 2% Damping



V. ASME BOILER AND PRESSURE VESSEL CODE, SECTION III, STRESS ANALYSES

Stress analyses of the recirculation loop, LPCI, and small piping seismic example were performed per the requirements of Subarticle NC-3600 of the ASME Code. The 1977 edition of the ASME Code including the Winter, 1978, addenda was used throughout the analyses described herein. The results obtained from the structural analyses described in Section IV of this report were used to evaluate stress levels.

1. MINIMUM THICKNESS CHECK

The Code[®] requires verification that the piping minimum wall thickness is satisfactory. The thickness was checked against Equation (3) of NC-3641.1: 大学である大学で

「私意見」の言語で

$$t_{m} = \frac{P D_{o}}{2 (S + PY)} + A$$

where:

t_m = Minimum required wall thickness, in. P = Internal design pressure, PSI

 $D_0 = Outside diameter, in.$

S = Allowable stress, PSI

$$y = .4 \text{ or } \frac{d}{d + D_0} \text{ if } D_0/t_m < 6 \text{ (per Code)}$$

A = Corrosion allowance (.08 in.).

Results of this calculation are contained in Tables VI and VII for the recirculation loop and LPCI suction piping, respectively. This calculation was not performed for the small piping seismic example because a design pressure of zero was used.

TABLE VI

MINIMUM THICKNESS PARAMETERS - RECIRCULATION LOOP PIPING

Pressure (psi)	0.D. (in.)	S (psi)	t _m (in.)	t _{Actual} (in.)
1250	28.3	15900	1.16	1.20
1250	21.3	15900	0.892	1.09
1250	20.0	15900	0.842	1.03
1250	12.8	15900	0.568	0.687
			· •	

TABLE VII

<u>.</u>

计院

MINIMUM THICKNESS PARAMETERS - LPCI SUCTION PIPING

Pressure (psi)	0.D. (in.)	S (psi)	t _m (in.)	t _{Actual} (in.)
70	24.0	15000	0.136	0.375
70	14.0	15000	0.113	0.375

Since the actual thicknesses are all greater than the t_m calculated, the system meets the requirements of NC-3641.1. It has been assumed that

all intersections are standard fittings and therefore meet the requirements of NC-3643.2 for branch connections not requiring reinforcement.

2. NC-3650 PIPING STRESS ANALYSES RESULTS

The stress results of the computer runs described above were calculated using Equation 9 in Subparagraph NC-3652.2. This is the Class 2 equation which must be satisfied for occasional loads. The equation is:

$$S_{OL} = \frac{P_{MAX} D_{o}}{4t_{n}} + 0.75i \qquad \frac{M_{A} + M_{B}}{Z} < 1.2 S_{H}$$

where:

P_{MAY} = Peak pressure, psi

 D_{o} = Outside diameter of pipe, in.

t_n = Nominal wall thickness, in.

i = Stress intensification factor

Z = Section modulus of pipe, in.³

- M_A = Resultant moment loading due to weight and other sustained loads, in.-lb
- M_B = Resultant moment loading due to occassional loads such as relief valve thrusts, flow transients and earthquake, in.-lb

 S_{μ} = Basic material allowable stress at design temperatue, psi

It is very important to note that the 1.2 S_H limit is for design and service level A and B loading conditions. The Equation 9 stress limits for service levels C and D are 1.8 S_H and 2.4 S_H , respectively. The OBE load cases included in these calculations are considered as

service level B (upset) loads; therefore, Equation 9 stress limits of 1.2 S_H are used. Equation 9 stress limits of 2.4 S_H were used for the SSE load cases because they were defined as service level D (faulted) loads.

5.2.1 Recirculation Loop Piping

ፚ

12.

ST.

Individual modal frequencies and periods of vibration for the Pl, P2, and P3 models are contained in Tables VIII and IX. Guidelines contained in Reference 4 indicate that structures with natural frequencies of 33 hertz or higher may be considered rigid. For this reason, a cutoff frequency limit of 33 hertz was specified for all seismic analyses.

ASME Code Class 2 stress summaries for all models are included in the computer output contained in Appendix C. Equation 9 stress values for the anchor points and the three highest stressed points on the piping are listed for the P1, P2, and P3 models in Tables X through XII. It should be remembered that Equation 9 combines the effects of pressure, sustained loads (such as deadweight) and occasional loads (such as OBE or SSE). A stress comparison at identical points in the P1, P2, and P3 models for the original analysis seismic stresses and the audit calculation OBE seismic stresses is contained in Table XIII. Seismic support loads for the recirculation loop models are summarized in Tables XIV and XV. The Reference 1 support loads for the beam-type seismic supports on the P1 model are also included in Table XIV. The global forces on the piping system anchors are summarized and compared to the original analysis loads in Tables XVI and XVII.

As shown in Tables VIII and IX the calculations performed using NUPIPE-II resulted in slightly different natural frequencies. This was expected in the Pl model which included the three snubbers as noted in Table VIII. It should emphasized that the recirculation models as described in this report were developed with a more uniform mass distribution than that shown in the original (Reference 1) analysis. This difference in mass distribution will influence natural frequency calculations and is probably the main contributor to the differences noted above. Analyses previously performed at the INEL have shown that differences in support stiffness can also influence natural frequency results. The exact stiffnesses used in the original analysis were not known and, thus, could not be exactly duplicated. Table VIII shows that the changes in support stiffness did produce frequency changes as expected. The frequency changes were relatively minor in this case.

5

÷٩

The summaries contained in Tables X through XII indicate that the ASME Code, Equation 9 stresses were well below the allowable limits for all analyses described in this report. The seismic stresses compared in Table XIII also indicate low stress magnitudes. The support and anchor load summaries presented in Tables XIV through XVII indicate that, in general, support loads are lower while anchor loads are similar or of higher absolute value. The differences in the stresses compared in Table XIII and the support and anchor loads compared in Tables XIV through XVII are at least partially dependent upon the mass distribution of the finite element models. Since the mass of the Pl model shown in Figure 2 is more evenly distributed than is the original analysis, it follows that the inertia effects will be reduced due to the smaller mass concentration at node 30.

Similarly, it follows that the support loads would be altered. Because mass points were more accurately defined throughout the recirculation loop models, the changes in anchor loads were not surprising. The changes in stresses and loads will also be partially caused by the previously discussed variations in natural frequency. The natural frequencies are used to determine the accelerations needed to calculate the inertial forces in a response spectrum analysis. Thus variations in frequency may cause significant changes in the results.

The results of the recirculation loop analyses described in the preceeding sections show that the variations in support stiffness and modal response combination method had a greater effect on support and anchor loads than on stress levels. However, the reader is cautioned to remember that these results are specific for the subject piping and may not represent general trends.

40

TABLE VIII

Mode	Configu f(Hz)	uration 1 T(sec.)	Configu f(Hz)	ration 2 T(sec.)	Configu f(Hz)	ration 3 T(sec.)	Original Analysis T(sec.)
1	7.09	.141	7.12	.140	9.09	.110	.148
2	8.27	.121	8.33	.120	10.3	.097	.124
3	9.37	.107	9.86	.101	13.1	.077	.095
4	13.4	.075	13.4	.075	13.4	.075	.065
5	14.8	.068	17.4	.057	15.6	.064	.063
6	17.1	.058	19.4	.052	17.6	.057	.051
7	19.4	.052	19.7	.051	19.6	.051	
8	20.1	.050	20.7	.048	20.4	.049	
9	20.9	.048	21.8	.046	21.6	.047	
10	21.7	.046	25.4	.039	21.8	.046	
11	23.4	.043	25.8	.039	25.4	.039	
12 -	25.5	.039	26.8	.037	25.5	.039	
13	26.8	.037	31.2	.032	26.7	.037	
14	31.2	.032	34.2	.029	31.2	.032	
15	31.7	.032			32.8	.030	
16	34.7	.029	· .		34.3	.029	

DRESDEN RECIRCULATION LOOP PIPING - P1 MODEL - SUMMARY OF NATURAL FREQUENCIES AND PERIODS OF VIBRATION

NOTES:

3.

4

 Configuration 1 - "Reasonable" seismic support stiffnesses (K = 1.0 x 10⁶ lb/in)
Configuration 2 - "Stiff" seismic support stiffnesses (1.0 x 10¹² lb/in)
Configuration 3 - "Reasonable" seismic support stiffnesses (1.0 x 10⁶) plus model included 3 snubbers as shown on drawings provided.

TABLE IX

DRESDEN RECIRCULATION LOOP PIPING - P2 AND P3 MODELS -SUMMARY OF NATURAL FREQUENCIES AND PERIODS OF VIBRATION

P2 Model

Mode	Frequency (Hertz)	Period (sec.)	Period (sec.) Original Analysis
1	7.66	0.130	0.117
2	8.93	0.112	0.113
3	11.4	0.088	0.083
4	17.3	0.058	0.066
5	22.1	0.045	
6	24.1	0.041	
7	27.1	0.037	
8	31 1	0.032	
9	38.3	0.026	

P3 Model

Frequency (Hertz)	Period (sec.)	Original Analysis
8.50	0.118	0.098
10.5	0.096	0.077
19.6	0.051	
27.8	0.036	
28.4	0.035	
50.4	0.020	
	Frequency (Hertz) 8.50 10.5 19.6 27.8 28.4 50.4	Frequency (Hertz)Period (sec.)8.500.11810.50.09619.60.05127.80.03628.40.03550.40.020

- ***** - **-** -

NOTE

i.

The P2 And P3 models contained seismic supports whose stiffness values were well established. Therefore, only one configuration of these models was analyzed using the known values of support stiffness.

TABLE X

SUMMARY OF ASME CODE, CLASS 2, EQUATION 9 STRESS VALUES - P1 MODEL CONSIDERING RESTRAINT STIFFNESS VARIATIONS, OBE LOAD CASE (P + DW + OBE)

			Stresses	s (KSI	:)			
	AB	SUM 2	2-D 3	SRSS	Allowable			
Node	Stiff'	REAS	Stiff	REAS	(1.2 S _H)	Comment	S	·
5	8.24	8.37	8.09	8.20	19.1	Loop 1	Pump Anchor	
58	7.50	7.50	7.27	7.28	19.1	Riser A	nchor	
57	7.07	7.09	6.89	6.91	19.1	II.	II.	
51	7.74	7.80	7.48	7.53	19.1	11	, u	
44	8.53	8.66	8.12	8.23	19.1	58	N	
72	12.8	12.9	12.5	12.5	19.1	U	41	
98	13.2	13.4	12.6	12.6	19.1	44	n	
121	6.92	6.98	6.69	6.66	19.1	11	44	
122	7.10	7.34	6.80	6.87	19.1	11	11	
128	9.52	10.1	8.56	8.78	19.1		11	
155	8.49	8.76	7.83	7.86	19.1	н	u	
149	8.45	8,59	8.08	8.08	19.1	Loop 2	Pump Anchor	
95	8.46	8.54	8.05	8.11	19.1	Manifol	d Intersection	
76	8.28	8.30	8.04	8.04	19.1	Riser E	lbow	
102	8.06	8.23	7.94	7.90	19.1	· • •	11	

NOTES

100

1. "Stiff" \rightarrow Seismic Restraint Stiffness = 1.0 x 10¹² lb/in

2. "REAS" \rightarrow Reasonable Seismic Restraint Stiffness = 1.0 x 10⁶ lb./in.

- 3. Numbers shown for Pl Model only. P2 and P3 models did not have "beam" type seismic supports.
- 4. Allowable based on $S_{H} = 15.9$ KSI for ASTM A358, TP304 stainless steel at 575°F.
- 5. Equation 9 includes the effects of pressure, sustained loads (deadweight), and occasional loads (OBE).
- 6. "AB SUM" Denotes 2-D absolute sum combination as defined on Page 24.
- 2-D SRSS → Only 2 Directions (one horizontal and vertical) combined. Both north-south horizontal plus vertical and east-west horizontal plus vertical cases were analyzed. Loads shown are maximum values regardless of directions.

TABLE XI

		S	TRESSES (KSI		
Model	Node	AB SUM	2-D SRSS	1.2 S _H	Comment
P2 -	5	10.6	10.4	19.1	Reactor Vessel Anchor
	125	9.48	9.32	19.1	Pump Anchor
	155	9.78	9.63	19.1	Shutdown Line Anchor
	35	11.9	11.5	19.1	Tee Intersection
	45	10.7	10.6	19.1	Concentrated Weight (valve)
	30	9.86	9.69	19.1	Run (Support Point)
P3	5	8.64	8.43	19.1	Reactor Vessel Anchor
<u> </u>	85	10.3	9.99	19.1	Pump Anchor
	70	9.03	8.86	19.1	Elbow
•	75	9.79	9.53	19.1	
	80	10.2	9,91	19.1	n

SUMMARY OF ASME CODE, CLASS 2, EQUATION 9 STRESS VALUES - P2 and P3 MODELS, TWO METHODS, OBE LOAD CASE (P + DW + OBE)

- NOTES
- 1. 0.5% Damping, 0.1 ZPGA J. A. Blume Spectra Used.
- 2. AB Sum + Absolute Sum method of combination.

<u>с</u>.,

3. 2-D SRSS \rightarrow Only 2 Directions (one horizontal and vertical) combined. Both north-south horizontal plus vertical and east-west horizontal plus vertical cases were analyzed. Stresses shown are maximum values regardless of directions.

- 4. Allowable based on S_{H} = 15.9 KSI for ASTM A358, TP304 stainless steel at 575°F.
- 5. Equation 9 includes the effects of pressure, sustained loads (deadweight), and occasional loads (OBE).

TABLE XII

		Eq. 9	Allow.	· · · · ·
Model	Node	Stress (KSI)	Stress (KSI)	Comment
P1	5	8.85	38.2	Loop 1 Pump Anchor
	58	7.74	38.2	Riser Anchor
	57	7.25	38.2	11 11
	51	8.00	38.2	11 H
	44	9.14	38.2	·
	72	14.5	38.2	n' n
	98	14.7	38.2	n 0
	121	7.16	38.2	11 II
	122	7.30	38.2	u u
	128	9.18	38.2	0 ·
	155	8.58	38.2	u U
	149	8,61	38.2	Loop 2 Pump Anchor
	95	8.86	38.2	Manifold Intersection
	76	8.57	38.2	Riser Elbow
	102	8.60	38.2	и и
. P2	5	10.6	38.2	Reactor Vessel Anchor
	125	10.1	38.2	Pump Anchor
	155	9.87	38.2	Shutdown Line Anchor
	35	12.0	38.2	Tee Intersection
	45	11.1	38.2	Concentrated Weight (valve)
	30	10.0	38.2	Run (Support Point)
P3	5	9.17	38.2	Reactor Vessel Anchor
	85	11.0	38.2	Pump Anchor
	70	9.53	38.2	Elbow
	75	10.4	38.2	U U
	80	10.7	38.2	н

SUMMARY OF ASME CODE, CLASS 2, EQUATION 9, STRESS VALUES - CURRENT CRITERIA ANALYSIS, SSE LOADING (P + DW + SSE)

NOTES

5

- 1. 3% damping used in all cases.
- 2. Allowable stress based on S_{H} = 15.9 KSI for ASTM A358, TP304 Stainless Steel at 575°F.
- 3. Equation 9 includes the effects of pressure, sustained loads (deadweight), and occasional loads (SSE).

	Model			
	P1	P2	P3	
Original Analysis Node	30	150	10	
Orig. Anal. Max. Stress (KSI)	3.4	3.00	2.00	
Current Model Node	145	5	75	
Stress (KSI) - AB Sum, "Stiff"	.535	N.A	N.A	
" – AB Sum, "REAS" ³	.437	2.41	2.40	
" - 2-D SRSS, Stiff	.378	N.A	N.A	
" – 2-D SRSS, "REAS"	.385	2.21	2.14	

STRESS COMPARISON AT IDENTICAL POINTS - OBE LOADING¹, .1g ZPGA

NOTES

34 · 1- 例

- 截.

1. Seismic stresses <u>only</u> are shown above.

2. "Stiff" \rightarrow Seismic Restraint Stiffness = 1.0 x 10¹² lb./in.

3. "REAS" \rightarrow " " = 1.0 x 10⁶ lb./in.

TABLE XIV

			Lo	ad (K)			Original
Node	<u>Dir.</u>	<u>Config. 1</u>	<u>Config. 2</u>	<u>Config. 3</u>	<u>Config. 4</u>	Curr.	Analysis
25	н	.041	.042	.038	.039	.046	
143	Н	.042	.051	.032	.032		
65	Х	1.39	2.18	1.21	1.88	3.40	-3.27
95	X	2.99	12.7	2.34	10.3	19.5	-8.73
95	Z	8.44	9.52	4.79	7.47	16.5	-25.6
135	Z	N.A.	N.A.	N.A.	N.A.	9.03	
105	Х	• N.A.	N.A.	N.A.	N.A.	5.75	
35	Z	N.A.	N.A.	N.A.	N.A.	13.0	

SUPPORT LOAD SUMMARY - RECIRCULATION LOOP P1 MODEL - SEISMIC LOADS ONLY

NI ∩	TEC
NU	IES

- 1. H implies horizontal. This is the maximum load on either one of two sway braces which are oriented at 90 degrees to each other in the horizontal plane.
- 2. X or Z imply restraint in the indicated global direction.

- 4. Config. 1 \rightarrow Config. 4 loads are OBE seismic loads. Current criteria seismic loads are for an SSE load case.
- 5. N.A. = Not Applicable. Restraints at these nodes are for snubbers which were not included in OBE analyses.
- 6. Original analysis loads taken from Reference 1.

TABLE XV

SUPPORT LOAD SUMMARY - RECIRCULATION LOOP P2 and P3 MODELS - SEISMIC LOADS ONLY

P2 Model

	Load (K)							
Node	Direction	AB. Sum (OBE)	2-D SRSS (OBE)	<u>Current (SSE)</u>				
30	Н	.082	.080	.087				
P3 Mode	1			·				

	•	Load	(K)	
Node	Direction	<u>AB. Sum (OBE)</u>	2-D SRSS (OBE)	Current (SSE)
35	н	. 074	.066	. 091

NOTES

1. H implies horizontal. This is the maximum load on either one of two sway braces which are oriented at 90 degrees to each other in the horizontal plane.

ANCHOR LOAD SUMMARY - RECIRCULATION LOOP P1 MODEL - SEISMIC LOADS ONLY

			Lo	ad (K)			Original
Node	<u>Dir.</u>	<u>Config. 1</u>	<u>Config. 2</u>	<u>Config. 3</u>	<u>Config. 4</u>	<u>Curr.</u>	<u>Analysis</u>
5	Х	2.83	4.00	2.29	3.41	7.61	-4.35
	Y	2.24	3.75	1.88	2.66	5.58	-3.02
	Z	3.23	3.40	2.90	3.04	4.96	-4.38
44	Х	.549	.690	.443	.555	.63`	776
	Y	2.07	2.40	1.49	1.70	3.34	232
	Z	1.20	1.28	1.11	1.18	1.55	-1.34
51	X	.555	.628	.500	.575	.763	877
	Y	1.58	1.72	1.14	1.24	2.17	.906
	Z	1.04	1.08	.950	. 985	1.23	-1.53
57	Х	. 427	.477	.389	.430	.627	697
	Y	.836	.719	.610	.550	1.26	.186
	Z	.965	.994	.885	.910	1.13	-1.46
58	Х	.220	.242	.196	.220	.281	358
	Y	1.52	1.48	1.16	1.13	1.91	-1.84
	ͺ Ζ ·	1.02	1.03	.935	. 945	1.24	-1.56
72	× X .	.655	.724	.470	.515	900	-1.45
	Y	3.65	3.84	3.21	3.22	6.83	-7.18
	Z	.802	.885	.645	.720	1.07	842
98	X	.089	.265	.065	.196	.366	.077
	Y	4.53	4.76	3,58	3.56	7.62	-6.39
.	Z	.699	.753	.505	.500	.878	825
	Х	.466	. 540	.335	.363	.566	152
	Y	1.12	1.00	.860	.765	1.63	779
· · · ·	Z	.800	1.04	.680	.715	.765	388
122	Х	1.01	1.18	.750	.750	.838	840
	Y	2.22	2.53	1.53	1.55	2.41	. 969
·	Z.	.851	1.08	.725	.760	.818	.275
128	Х	2.74	2.29	1.98	1.97	1.88	-1.95
•	Y	6.39	5.79	4.50	4.50	5.13	3.26
	Z	1.22	1.20	1.04	1.08	1.21	.217
149	Х	5.72	6.6	4.04	3.92	7.06	-6.84
	Y	8.12	9.42	5.55	5.55	7.16	-4.48
	Z	4.12	4.86	3.19	3.33	4.86	-3.47
155	X	1.68	1.90	1.12	1.13	1.61	-2.07
	Y	1.76	1.99	1.19	1.26	2.38	548
	Z	1.02	1.22	.775	.833	1.22	-1.04

NOTES

1. Original analysis loads taken from Reference 1. Moment loads were not included because the original loads were not readily available.

- 2. Directions listed are in the model global coordinate system.
- 3. Configuration 1 = Absolute summation run with "stiff" support stiffness (1 X 10¹² lb/in.) Configuration 2 = Absolute summation run with "reasonable" support stiffness (1 x 10⁶ lb/in.) Configuration 3 = 2-D SRSS run with "stiff" support stiffness (1 x 10¹² lb/in.) Configuration 4 = 2-D SRSS run with "reasonable" support stiffness (1 x 10⁶ lb/in.) Curr. = "Current Criteria" analysis using reasonable restraint stiffness. Config. 1 → Config. 4 loads are OBE seismic loads. Current criteria seismic loads are for an SSE load case. These loads are from response spectra output and, thus, carry no sign in the computer output.

TABLE XVII

				منعينية بمتسعيته وم		01.91
P2	5	X	13.3	12.4	11.5	-9.87
		Ý	13.6	10.5	11.6	-12.7
	.:	Z	6.23	5.78	8.39	-7.82
	125	Χ.	14.7	14.0	13.1	-9.60
		Y	10.4	9.74	9.01	5.63
		Z.	8.60	7.67	11.1	-11.7
	155	X	2.99	2.83	3.03	-3.37
	· ·	Ý	2.44	1.73	2.74	-3.51
		Ζ.	7.01	6.44	9.30	-11.0
Р3	5	X	4.70	4.20	9.24	-5.07
		Y	8.06	5.80	12.3	-2.83
		Z	5.89	2.82	7.40	-4.59
	85	X	8.05	7.41	16.2	-14.2
•		Y.	5.14	4.36	9.28	-5.32
		Z	12.9	6.00	16.1	-15.6

ANCHOR LOAD SUMMARY - RECIRCULATION LOOP P2 AND P3 MODELS - SEISMIC LOADS ONLY

NOTES

25

17.

1. Original analysis loads taken from Reference 1. Moment loads were not included because the original loads were not readily available.

2. Directions listed are in the model global coordinate systems.

3. Ab Sum + Absolute Sum method of combination.

- 4. 2-D SRSS \rightarrow Only 2 Directions (one horizontal and vertical) combined. Both north-south horizontal plus vertical and east-west horizontal plus vertical cases were analyzed. Loads shown are maximum values regardless of directions.
- 5. Ab Sum and 2-D SRSS are OBE load cases. Current criteria (Curr.) load case is for an SSE. These loads are all from response spectra analyses and, thus, carry no sign in the computer output.

5.2.2 LPCI Pump Suction Piping

いい

tres.

Individual modal frequencies and periods of vibration for the LPCI model are contained in Table XVIII.

ASME Code Class 2, Equation 9 stresses are summarized at the anchors and the four highest stressed points on the piping. This summary is contained in Table XIX. Support loads are summarized in Table XX. Support load information from the original analysis was not readily available and, thus, was not compared to the loads shown in Table XX. The global forces on the piping system anchors are summarized and compared to the original analysis loads in Table XXI. Original analysis loads at the suppression chamber anchor (see Figure 5) were not included because they were not readily available. Moment loading was not included in Table XXI because the original analysis moment loads were not readily available for comparison.

TABLE XVIII

Mode	Frequency (Hertz)	Period (sec.)
1	7.55	0.132
2	10.1	0.099
3	12.5	0.080
4	15.5	0,065
5	16.6	0.060
6	16.9	0.059
7	19.9	0.050
8	23.8	0.042
9	26.8	0.037
10	37.8	0.026

DRESDEN UNIT 2 LPCI SUCTION PIPING MODEL - NATURAL FREQUENCIES AND PERIODS OF VIBRATION

TABLE XIX

Node	"Static g" ¹	Stresses (KSI) Resp. Spect ²	Allowable ³	Comment
5	5.97	5.88	36.0	Supp. Chamber Anchor
185	3.55	2.79	36.0	Pump 2A Anchor
280	2.77	2.43	36.0	Pump 2B Anchor
10	13.2	12.0	36.0	Ring Header Tee
30	10.3	9.37	36.0	Suct Line/Header Tee
105	12.1	12.5	36.0	Pump 2B Branch Intersection
260	11.1	7.67	36.0	Elpow

SUMMARY OF ASME CODE, CLASS 2, EQUATION 9, STRESS VALUES - LPCI MODEL, TWO METHODS, SSE LOAD CASE

NOTES

- Horizontal Acceleration = 0.7 g perpendicular to piping. Vertical Acceleration = 0.067 g.
- 2. Spectra shown in Figures 11 and 12 used.
- 3. Allowable stress based on $S_{\rm H}$ = 15.0 KSI for Al06, Gr. B carbon steel. Allowable = 2.4 $S_{\rm H}$ for Service Level D.
- 4. Numbers given at anchor points and 4 highest stress points. Equation 9 (NC-3652.2) used to calculate all stresses.
- 5. Equation 9 combines effects of pressure, sustained loads (deadweight), and occasional loads (SSE).

TABLE XX

	SUITORT LOAD SUP	MART - LICI MODLE -	SCISHIC LOADS UNET
	Global	Load	(K)
Node	Direction	<u>Static g</u>	Response Spectra
35	R	7.10	2.30
80	Ŷ	-1.33	3.90
165	Y	.854	1.90
260	Y .	. 647	3.60

SUPPORT LOAD SUMMARY - LPCI MODEL - SEISMIC LOADS ONLY

NOTES

1. R implies radial direction. This is a support attached to the ring header.

2. All supports listed were assumed active during seismic events.

		LOAD	(к)	
Node	<u>Dir.</u>	<u>"Static g"</u>	Resp. Spect.	<u>Orig. Anal.</u>
5	X	2.94	10.6	
	Y	289	4.12	
	Z	-6.06	2.28	
185	Х	049	2.11	4.42
	Y	207	1.11	1.70
	Z '	-3.20	1.48	3.30
280	Х	.178	2.00	9.78
	Y	850	. 990	2.72
	Z	-2.14	.745	4.18

ANCHOR LOAD SUMMARY - LPCI MODEL - SEISMIC LOADS ONLY

NOTE

 Original analysis loads taken from Appendix D. Moment loads were not included because the original loads were not readily available.

「一」には「「「」」

Individual modal frequencies and periods of vibration for the different configurations of the small piping seismic example problem are shown in Table XXII.

ASME Code Class 2, Equation 9 stresses are summarized in Table XXIII. This table contains stress results at the system anchors and the three highest stressed points on the piping. Support loads and global forces and moments on the system anchors are summarized in Tables XXIV and XXV, respectively. Original analysis loads were not included in Tables XXIV and XXV because they were not available. TABLE XXII

	Configu	ration 1	Configu	ration 2	Configu	ration 3	Configu	ration 4
Mode	f(Hz)	T(sec.)	f(Hz)	T(sec.)	f(Hz)	T(sec.)	f(Hz)	T(sec.)
1	179,	558	290	3 45	1 80	557	290	3 45
2	2 81	356	657	1 52	2 82	354	657	1 52
3	3.65	274	1.72	583	3.69	271	1.72	.583
4	5 04	198	1 79	558	5 40	185	1.80	.557
5	6 35	157	2.64	379	6.39	157	2.64	.378
6	7 58	132	2.82	354	7.62	131	2.83	.353
7	8.47	.118	3.50	286	8.49	.118	3.51	.285
8	9.05	.110	3.67	.272	9.17	.109	3.70	.270
9	10.2	. 098	4.65	.215	10.3	.097	4.83	.207
10	11.2	.089	6.33	.158	11.6	.087	6.36	.157
. 11	11.6	.086	6.40	.156	11.8	.085	6.46	.155
12	12.6	.080	8.00	.125	13.0	.077	8.02	.125
13	13.2	.076	8.48	.118	13.7	.073	8.50	.118
. 14	14.7	.068	9.57	.104	15.1	.066	9.60	.104
15	14.8	.067	10.2	. 098	16.0	.063	10.3	.097
16	15.3	.065	11.6	.086	16.1	.062	11.8	.085
17	15.9	.063	13.2	.076	17.0	.059	13.3	.075
18	17.0	.059	13.2	.075	17.1	.058	13.7	.073
19	18.1	.055	14.6	.068	19.6	.051	15.0	.067
20	20,6	.049	14.8	.067	21.2	.047	15.9	.063
21	23.4	. 043	16.0	.063	23.9	.042	16.2	.062
22	26.2	.038	17.0	.059	27.8	.036	17.1	.058
23	27,4	.037	18.4	.054	29.4	.034	18.5	.054
24	28.2	.035	20.6	049	30.0	.034	21.2	.047
25	33.9	.030	22.9	.044	34.5	.029	23.0	.043
26	34.1	.029	23.4	.043			23.8	.042
27			26.3	.038			26.4	.038
28			27.4	.037	•		27.8	.036
29			28.2	.034			29.8	.034
30			29.9	.033			29.9	.033
31			34.1	.029			34.5	.029

SUMMARY OF NATURAL FREQUENCIES AND PERIODS OF VIBRATION FOR SMALL PIPING TEST PROBLEM

NOTES

1. Configuration 1 \rightarrow Restraint Stiffness (R.S.) = 2 x 10⁵ lb./in. and vert. supports active 2. Configuration 2 \rightarrow R. S. = 2 x 10⁵, vert. supports not active

3. Configuration $3 \rightarrow R$. S. = 6.8 x 10⁶ (10X bending stiffness of pipe between adjacent supports), vert. supports active

4. Configuration $4 \rightarrow R$. S. = 6.8 x 10⁶, vert. supports <u>not</u> active

TABLE XXIII

Jt. ..

		Stresse	s (KSI)			
Node	Configuration 1 Eq. 9	Configuration 2 Eq. 9	Configuration 3 Eq. 9	Configuration 4 Eq. 9	Allow- able	Comments
5	7.53	8.5	7.86	8.57	36.0	Tank Anchor
235	13.0	26.8	12.6	26.2	36.0	Anchor
35 /	11.98		11.5		36.0	Run
45 ′	14.1		13.6		36.0	Elpow
105	12.3	16.3	12.1	15.8	36.0	Valve Weld
225		16.8		16.8	36.0	Run
230		20.2		20.0	36.0	Run

SUMMARY OF ASME CODE, CLASS 2, EQUATION 9, STRESS VALUES - SMALL PIPING EXAMPLE PROBLEM, SSE LOAD CASE (P + DW + SSE)

NOTES

58

1. Configuration 1 \rightarrow Restraint Stiffness = 2 x 10⁵ lb/in. and vert. supports active Configuration 2 \rightarrow R. S. = 2 x 10⁵, vert. supports <u>not</u> active Configuration 3 \rightarrow R. S. = 6.8 x 10⁶ (10X bending stiffness of pipe between adjacent supports), vert. supports active Configuration 4 \rightarrow R. S. = 6.8 x 10⁶, vert. supports not active

2. Allowable stress based on S_{H} = 15.0 KSI for Al06, Gr. B carbon steel. Allowable = 2.4 S_{H} for Service Level D.

3. Equation 9 includes the effects of pressure, sustained loads (deadweight) and occasional loads (SSE).

Note that zero, pressure was assumed. Thus, no pressure effects are included in the results shown above.





TABLE XXIV

	Global		Loa	id (K)	
Node	Dir.	Config. 1	Config. 2	Config. 3	Config. 4
35	X	13.7	10.2	13.0	9.57
35	Ž	2.56	2.74	2.58	2.74
55	Ŷ	3.17		3.01	
55	Z	4.32	4.59	4.31	4.55
80	Y	. 989		.749	
105	Y	.718		.421	
105	Σ	3.41	3.53	3.21	3.39
145	Y	. 586		.492	
170	Y	.898		.781	
185	Y	.747		. 648	
210	Y	.830		.718	

SUPPORT LOAD SUMMARY - SMALL PIPING TEST PROBLEM - SEISMIC LOADS ONLY

NOTES

1. Configuration 1 \rightarrow Restraint Stiffness (R.S.) = 2 x 10⁵ lb/in. and vert. supports active Configuration 2 \rightarrow R. S. = 2 x 10⁵, vert. supports not active

active Configuration $2 \rightarrow R$. S. = 2×10^5 , vert. supports <u>not</u> active Configuration $3 \rightarrow R$. S. = 6.8×10^6 (10X bending stiffness of pipe between adjacent supports), vert. supports active Configuration $4 \rightarrow R$. S. = 6.8×10^6 , vert. supports <u>not</u> active

TABLE XXV

2.15
1.42
.724
71.2
8.96
210.
1.84
1.90
1.67
566.
301.
37.8

ANCHOR LOAD SUMMARY - SMALL PIPING SEISMIC EXAMPLE MODEL -SEISMIC LOADS ONLY

NOTES

1. Configuration 1 \rightarrow Restraint Stiffness = 2 x 10⁵ lb/in. and vert. supports active. Configuration 2 \rightarrow R. S. = 2 x 10⁵, vert. supports <u>not</u> active. Configuration 3 \rightarrow R. S. = 6.8 x 10⁶ (10X bending stiffness of pipe between adjacent supports), vert. supports active. Configuration 4 \rightarrow R. S. = 6.8 x 10⁶, vert. supports <u>not</u> active.

X implies load in pounds in global X direction.

XX implies moment in inch-kips about the global X direction.

<u>,</u> 2.

÷.

强

- 16

VI. CONCLUSIONS

The recirculation loop, LPCI suction and small piping seismic example piping systems have been analyzed using independently developed finite element models. Original analyses have been simulated and new analyses incorporating current ASME Code and Regulatory Guide requirements have been performed. Specific comments regarding each piping system follow.

1. RECIRCULATION LOOP

From the information described in the previous report sections it can be concluded that recirculation loop piping stresses are within acceptable limits during an OBE or SSE event. Since the support loads determined by the analyses described herein are of lower magnitude than the original analysis loads, it can be concluded that the recirculation loop piping is adequately supported for OBE and SSE events. Detailed drawings of the seismic support members were not provided. It is therefore obvious that any conclusions regarding support structural adequacy are based on the assumption that suitable stress analysis of the pertinent supports has been previously performed. In certain cases, the anchor loads discussed above are higher than those found by the original analysis. However, the piping stresses at the anchor points have all been shown to be well within allowable limits. Thus, it can be concluded that the nozzles will not be overstressed due to imposed piping seismic loads.

, Ś

當

. .

As a final suggestion, points of high stress may be considered as possible locations for postulating pipe breaks if future efforts address the effects of pipe breaks inside containment.

2. LPCI SUCTION

As shown in Table XIX, the maximum stresses for the LPCI suction piping were well within allowable limits for both methods used. From the information contained in this table it can be concluded that the piping stresses should be within allowable limits during OBE or SSE loading.

Support configuration or load information was not readily available for this system. Thus, no comparison of support loads or conclusions concerning support structural adequacy will be made.

The anchor load summary contained in Table XXI indicates that the loads determined by the analyses described in this report were of similar magnitude to those found by the original analysis. Therefore, it can be concluded that the pump suction nozzles will not be overstressed due to imposed piping seismic loads.

The reader is again reminded that these results and conclusions are dependent upon the engineering assumptions utilized.

3. SMALL PIPING SEISMIC EXAMPLE

The purpose of analyzing the small piping seismic example problem was to verify design charts which were developed for piping of eight-inch nominal size or less. Since there are no original analysis results no comparisons to the results of the analyses described herein are possible. The stress summary contained in Table XXIII indicates that the piping stresses will be within allowable limits when subjected to SSE loading. This also indicates that the support configuration resulting from use of the design charts will provide sufficient seismic support. It can be concluded that for this particular case use of the design charts would provide for the structural adequacy of the piping. No conclusions can be drawn concerning structural adequacy of supports or nozzles.

63

 $\frac{1}{2}$

: 1911

-

VII. REFERENCES

- 1. John A. Blume & Associates, Engineers, "Dresden Units 2 & 3 Nuclear Plant Earthquake Analysis: Recirculation Loop Piping", Report to General Electric Company, December 1968.
- Senior Seismic Review Team, "Seismic Review of Dresden Nuclear Power Station Unit 2 for the Systematic Evaluation Program" NUREG/CR-0891, July 1979.
- 3. American Society of Mechanical Engineers, <u>ASME Boiler and Pressure</u> <u>Vessel Code</u>, Section III, Division I, "Nuclear Power Plant Components", Subsection NC, 1977 Edition plus Winter 1979 Addenda.
- 4. U.S. Department of Energy Division of Nuclear Power Development, "Seismic Requirements for Design of Nuclear Power Plants and Test Facilities", RDT Standard F9-2, Draft Version, August 1979.
APPENDIX A

NUPIPE-II COMPUTER PROGRAM DESCRIPTION

A-i

COMPUTER PROGRAM DESCRIPTION

The NUPIPE-II computer program performs linear elastic analysis of threedimensional piping systems subject to thermal, deadweight, seismic, and other static and dynamic loads. The NUPIPE-II program is also designed to perform stress and fatigue analyses in accordance with the ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, 1974 Edition through the Summer 1975 Addenda; and the ANSI B31.1 Code, 1967 and Summer 1973 versions. NUPIPE-II may also be utilized to assure compliance with later piping code requirements provided the analyst takes into consideration any possible changes. Piping systems of more than one classification can be analyzed.

NUPIPE-II utilizes the finite element method of analysis with special features incorporated to accommodate specific requirements of piping system analysis. In accordance with the finite element method, the continuous piping is mathematically idealized as an assembly of elastic structural members connecting discrete nodal points. Nodal points are placed in such a manner as to isolate particular types of piping elements, such as straight runs of pipe, elbows, valves, etc., for which force-deformation characteristics can be categorized. Nodal points are also placed at all discontinuities, such as piping supports, concentrated weights, branch lines, and changes in cross-section. System loads such as weights, equivalent thermal forces, and earthquake inertia forces are applied at the nodal points. For the deadweight and dynamic timehistory and response spectra analyses, distributed weight properties of the piping as well as concentrated weights, such as valves, pumps, or snubbers, can be considered. A lumped mass model of the piping system is used for all dynamic analyses. Both translational and rotational degrees-of-freedom may be considered.

For further information concerning NUPIPE-II capabilities or analytical procedures, contact Applied Mechanics Branch of EG&G Idaho, Inc.

APPENDIX B

BENCHMARK PROBLEM TO ASSESS SPATIAL COMBINATION METHOD FOR RESPONSE SPECTRUM ANALYSIS

ME Nitzel

April 19, 1979

Mr. R. E. Tiller, Director Reactor Operations and Programs Division Idaho Operations Office - DOE Idaho Falls, ID 83401

SEISMIC REEVALUATION OF PIPING ASSOCIATED WITH THE NRC SHOW CAUSE ORDER OF MARCH 13, 1979 - JAD-96-79

Dear Mr. Tiller:

A benchmark problem which permits assessment of intermodel spatial combination methodology for response spectrum analysis has been formulated and analyzed at the request of Mr. V. S. Noonan, NRC-DOR. The attachment describes the problem and the results generated from hand calculations and the SAP-IV, NUPIPE, and ADLPIPE computer codes. The costs incurred in doing this benchmark problem were charged against the task of reviewing five plants currently undergoing piping seismic reevaluation.

Very truly yours,

J. A. Dearien, Manager Code Assessment and Applications Program

vjd

Attachment: As stated

cc: V. S. Noonan, NRC-DOR

K. R. Wichman, NRC-EE

R. W. Kiehn, EG&G Idaho, w/o Attach.

bcc: J. A. Dearien

R. C. Guenzler

C. A. Moore

C. F. Obenchain

Applied Mechanics Branch personnel Central File J. A. Dearien File

BENCHMARK PROBLEM TO ASSESS SPATIAL COMBINATION METHOD FOR RESPONSE SPECTRUM ANALYSIS

by R. L. Grubb R. W. Macek G. L. Thinnes

ä,

A mathematical problem has been designed to exercise the spatial combination of motion components which may be used in a seismic modal response spectrum analysis. Specifications for the finite element model include:

- 1. The capability to exercise all known schemes of spatial combination,
 - i.e. SRSS, absolute sum, and algebraic sum methods.
- A simplicity affording manual calculation of eigenvectors, modal participation factors, eigenvalues and displacements for the purposes of verifying the original computer code solutions.
- 3. A solution which will quickly and easily reflect the method of spatial combination in the total deflections calculated by the tested computer code.

With this in mind, the following problem has been constructed:



It consists of a uniform beam with all degrees of freedom (D.O.F.) fixed at Node (1) and all translational D.O.F. fixed at Node (6). Intermediate support is provided by boundary or truss elements of equal stiffness directed perpendicularly to the Z axis oriented as shown in the end view and attached to the beam at Nodes (2) - (5). The mass of the system is uniformly distributed.

In the finite element models, however, the mass is lumped at nodes with mass moments of inertia assumed equal to zero. It is, therefore, expected that small variations in frequencies will exist between the theoretical and model calculations.

Specific mass and stiffness data includes:

Typical Boundary Stiffness: 1.0(10⁵)1bs/in.

Typical Lumped Mass: $\frac{100}{386.4}$ = .259 lb mass

Beam Modulus of Elasticity: 1.0(10⁶)lbs/in²

All Beam Moments of Inertia: 1.0 in⁴

(No Shear Deflections Considered)

Axial Area: 1.0 in²

The boundary elements are skewed 45° off the X-Z and Y-Z planes to force the beam to respond in the plane perpendicular to the boundary elements' direction. With the support conditions shown, the beam modes under 33 Hz are bending modes of a propped cantilever in a plane rotated 45° about its neutral axis. This arrangement forces the modal participation factors in the X and Y directions for at least the first four modes to be of opposite sign. This is of importance since this sign difference may cause unconservative spatial combination. As an example:

 $\{U_{re}\} = S_{re}(W_r) \Gamma_{re}\{\phi_r\}$

where:

Γ_{re}

ينيني. معبد

> {U_{re}} A vector of displacements caused by excitation in the e direction for mode r.

 $S_{re}(W_r)$ The spectral displacement corresponding to circular frequency W_r for mode r in direction e = X, Y, Z. (This is equal to spectral acceleration divided by W_r^2)

(1)

The modal participation factor for mode r in direction e.

2

$\{\phi_r\}$ The eigenvector for mode r.

Since the scalar quantity $S_{re}(W_r)$ always has a positive sign and the spatial combination is performed at each mode (ϕ is the same for all three components), the modal participation factor governs the summation. For mode r:

$$U_{x} = S_{x}(W)r_{x^{\phi}}$$
(2)

$$U_{y} = S_{y}(W)\Gamma_{y\phi}$$
(3)

$$U_{z} = S_{z}(W)r_{z}\phi$$
 (4)

and the components can be combined as:

or

or

Э.

の一部の

÷

$$U = \sqrt{U_x^2 + U_y^2 + U_z^2}$$
(5)

$$U = U_{x} + U_{y} + U_{z}$$
(6)

$$U = |U_{x}| + |U_{y}| + |U_{z}|$$
(7)

For this test problem a spectrum is applied to the model to excite only the second mode. (See Table I for all calculated periods.) The applied acceleration spectrum is:



TABLE I

CALCULATED MODAL PERIODS

Method	T ₁	T ₂	Τ ₃	T4
Manual	.610	.188	.090	.053
SAP IV	.610	.189	.094	.062
NUPIPE	.599	.187	.093	.062
ADLPIPE	.599	.187	.093	.062

燕

②.

√2. ◎● ◎ ◎

This spectrum is applied in the X and Y directions only. Therefore, U_z in Equation (4) is zero and there are only two non zero components in Equations (5), (6), or (7). Since only one mode is excited, this test removes any form of intermodal combination, e.g. closely spaced modal methods.

Manual Calculations

Calculations for this problem consisted of, first determining the first four frequencies of the uniformly loaded propped cantilevered beam. All hand calculations are included in the attachment. Then the eigenvectors and modal participation factors for the second mode were calculated. The X and Y modal displacements (for the second mode) are listed in Table II for all methods of calculation. Finally, the displacements for Node 2 of the model were calculated using the three spatial combinations discussed. The modal participation factors for the second mode and the displacements are tabulated in Tables III and IV respectively for all calculations.

SAP IV

The spatial combination employed with this code is that of Equation (7). It is noted that care must be taken to insure correct combination by using positive factors to designate direction of spectral excitation.

NUPIPE

The NUPIPE computer code performed the spectral analysis spatial component combination in accordance with the NRC's Reg. Guide 1.92. The combination approach is equivalent to that shown in Equation (5) if all modes are considered equally.

ADLPIPE

The computer code ADLPIPE allows for three spatial component combination procedures. The Reg. Guide 1.92 approach is included in the code and can be reduced to yield the standard SRSS approach shown in Equation (5). Combination

TABLE II.

	TU A MAXIMU	M VALUE OF UNIT	
Node	Method	Δx	Өу
1	A	0	0
	B	0	0
	C	0	0
2	A	771	.638
	B	.778	.630
	C	774	.634
3	A	947	496
	B	.944	504
	C	946	449
4 .	A	.303	962
	B	307	963
	C	.305	962
5	A	1.0	.154
	B	-1.0	.155
	C	1.0	.155
6	A	0	1.0
	B	0	1.0
	C	0	1.0

MODE SHAPES FOR MODE 2 NORMALIZED VT101114 1/41 110 òr. -

A-Hand Calculations B-NUPIPE C-SAP IV

1.-1. Ai an

3.-

Note 1: No eigenvectors supplied in ADLPIPE output

Note 2: $\Delta x = -\Delta y$ and $\theta x = \theta y$ and $\Delta z = \theta z = 0$

Note 3: In NUPIPE the beam is modeled in positive z coordinates.

6

TABLE III

MODAL PARTICIPATION FACTORS FOR THE SECOND MODE

Method	Frequency (Hz)	<u> </u>	Гy
Manual	5.32	0927	.0927
NUPIPE	5.36	.0928	.0928
SAP IV	5.29	0927	.0927
ADLPIPE	5.36	.09	09

TABLE IV

COMPARISON OF RESULTANT DISPLACEMENTS OF MODEL NODE 2 CALCULATED BY VARIOUS METHODS

Method	_Δx	Δy	<u> </u>	<u> </u>
Manual (SRSS)	.0302	.0302	.0015	.0015
Manual (Algebraic Sum)	0	0	0	0
Manual (Absolute Sum)	.0428	.0428	.00211	.00211
NUPIPE	.030	.030	.0014	.0014
SAP IV	.0435	.0435	.00207	.00207
ADLPIPE (SRSS)	.0300	.0300	.0014	.0014
ADLPIPE (Algebraic Sum)	0	0	0	0,

7

89

by the algebraic summation method presented in Equation (6) is also available in the code. The combination procedures available prior to the 1978 version of ADLPIPE are not clearly defined in the input manual.

Conclusions

The result of this exercise shows the following:

1. NUPIPE combines spatially by the SRSS method.

- 2. SAP IV uses the absolute sum method which is more conservative than NUPIPE. Any code using this method will calculate displacements for this given problem which will be larger than the SRSS method calculations by a factor of $\sqrt{2}$.
- 3. ADLPIPE allows spatial combination by either the SRSS method or the algebraic sum method. Any code using the algebraic sum method and calculating displacements for <u>this given problem</u> will calculate zero values for all displacements.
- 4. The version of ADLPIPE used was dated 1978. The schemes of spatial combination in ADLPIPE before this date are not known at this time.
- 5. It appears that, while the algebraic sum method may be valid for excitation in a single direction, spatial combination does not appear to be required for this special case. If spatial combination is required unconservative deflections and forces could result using the algebraic sum method. (It is noted that if individual runs are made for each direction using <u>any</u> of the methods discussed and then those results are combined by SRSS, the final result would be the same as the SRSS spatial combination.)

ATTACHMENT A

)

HAND CALCULATIONS FOR CHECKING SPECTRAL ANALYSIS SPATIAL COMPONENT COMBINATION PROCEDURES

;*::

B //

The following piping system is analyzed to determine the effect of three spatial component combination procedures:

Modulus of elasticity = $E=1\times10^6$ psi The moment of inertia = I=1.0 in.⁴ The weight of the system = W=500 lb The weight/unit length = w=4.1667 lb/in. The length = $\pounds=120$ in. The acceleration of gravity = g=386.1 in./sec²

The piping configuration

È.



The three combination procedures considered are:

(1)
$$U = \sqrt{U_x^2 + U_y^2 = U_z^2}$$

(2) $U = U_x + U_y + U_z$

SRSS

Algebraic Sum

(3) $U = |U_x| + |U_y| + |U_z|$

Absolute Sum

A-1

The frequencies for the system may be derived from Table 36 of Reference 1.

Kn JETC		Mode	к _п	I
		1 -	15.4	
$f_n = \frac{\pi}{2\pi} \sqrt{\frac{c_1 q}{w_0^4}}$	where	2	50.0	
		3	104	
		4	178	

 $f_1 = 1.6385 \text{ cps}$ $f_2 = 5.3197 \text{ cps}$ $f_3 = 11.0649 \text{ cps}$ $f_4 = 18.9380 \text{ cps}$

The mode shape for the second mode of vibration can be derived from Table 3 of Reference 1 by a simple rotation of 45° and by multiplication of the curvature by the factor $\beta_2 = .0589$ based on a length of 120 inches. The mode shape values for z and θ_z are identically zero.

The modal participation factor for x input or y input is

 $\frac{\{\phi\}^{\mathsf{T}}[\mathsf{M}]\{\mathtt{I}\}}{\{\phi\}^{\mathsf{T}}[\mathsf{M}]\{\phi\}} = \mathbf{I}$

where {I} selects either x or y degrees of freedom

If a lumped mass matrix is assumed and further the mass inertias are assumed to be equal to zero, the following mass matrix can be formed for the x, y, θ_x , and θ_y degrees of freedom.

A-2



The modal participation factors become

$$\Gamma_{x} = -\Gamma_{y} = \frac{M_{E}(0) + M_{I}(-.75978) + M_{I}(-.93284) + M_{I}(.29888) + M_{I}(.98536) + M_{E}(0)}{2(M_{e}(0)^{2} = M_{I}(-.93284)^{2} + M_{I}(.29888)^{2} + M_{I}(.98536)^{2} + M_{E}(0)^{2})}$$

$$\Gamma_{x} = -\Gamma_{y} = \frac{-.40838}{5.01544} = -.81425$$

$$\Gamma_{y} = .081425$$

$$\Gamma_{y} = .081425$$

$$W_{2}^{2} = (2\pi(5.3197))^{2} = 1117.208 \frac{rad}{sec^{2}}$$

If x and y are nonmalized to the mass for comparison purposes the values become

 $\frac{\Gamma_{x}}{\sqrt{\frac{500}{386.1}}} = -\Gamma_{y} = -.0927 \qquad \Gamma_{x} = -.0927 \qquad \Gamma_{x} = -.0927 \qquad \Gamma_{y} = .0927 \qquad \Gamma_{y} = .0927$

The spectral displacement must be specified in inches. The spectral acceleraation for the second mode is defined to be 1.0 g's or 386.1 in./sec^2 . The spectral displacement becomes

$$S_d = \frac{386.1}{1117.308} = .34559$$
 in.

ч." ,

For Node 2 the discrete displacements and rotations become

Γx		Гy,	
x	.02138	02138	
y j	02138	.02138	
θx	00105	.00105	
Өу	00105	.00105	

A-4

The combined displacements and rotations become



÷,

A-5

REFERENCES

- 1. R. J. Roak and W. C. Young, <u>Formulas for Stress and Strain</u>, Fifth Edition, McGraw Hill, 1965.
- 2. D. Young and R. P. Felgar, Jr., "Tables of Characteristic Functions Representing Normal Mode of Vebration of a Beam", <u>The University of Texas Pub-</u><u>lication No. 4913</u>, July 1, 1949.

MICROFICHE COPIES OF NUPIPE-II COMPUTER RUNS

APPENDIX C



Dresidea Unit 2, Pl Medel, XHY (N. StVent.) OBE, SRSS, Reasonable Stiffnesses



D2 P1 Model, Z+Y (E-W+Vert.) OBE, SRSS, Reasonable Stiffnesses







C-4



D2 P1 Model, Current Criteria SSE



C-6



D2 P2 Model, Z+Y (E-W+Vert.) OBE, Ab. Sum



D2 P2 Model, Current Criteria SSE



C'-9





D2 P3 Model, Current Criteria SSE



وسوم والمراجع

D2_LPCI Suction, Current Criteria SSE

Information provided for the small piping seismic example problem consisted of a representative small diameter (eight inch nominal size) system from the Quad Cities Nuclear Power Station. Therefore, the following computer output is labeled as "Quad Cities Test Problem". While the system analyzed is not from the Dresden Unit 2 reactor, the analysis does serve the purpose of verifying the design charts.

Quad Cities Test Problem, SSE, Vent. Restraints In, Reasonable Support Stiffness

C-13

Quad Cities Test Problem, SSE, No Vert. Restraints, Reasonable Stiffness



Quad Cities Test Problem, SSE, No Vert. Restraints, Restraint Stiffness = 10 x Pipe Span Stiffness
APPENDIX D

ORIGINAL ANALYSIS LPCI SUCTION PIPING NOZZLE LOADS

MAD - 67 -6-30-69 NOTE: FORCES (LES) AND MOMENTS (FT-LES) ARE APPLIED TO ANCHOR POLITS FIFING: LPCI PUMP A AND B SUCTION AND DISCH NOZZLE LCADS SEE DWG M-527 OPERATENG CONDITIONS LOADS CAN CE SEE CUT-SEORTS SUMMARY + OR - SOTTE 57% CUT-SHORT SEISMIC (1) NODE HOT, Sa COLD, Ze 235 5 Fχ Fy 3153 תונוישל Fz 2760 DISCH 6172 Mx Му 206 G, <u>!4z</u> 3036 TX: 4364 **45** īУ 1223 9 "AM 895 Ξz DVSCH 2753 ΜX. 1316 9320 MV Р, MZ 4413 5 FX Fy 1697 diund . H Fz 3298 2005 10 507 Mx 6725 H 2734 MZ 85 9779 FX 2722 ĒΥ dund 117 -(+y, up) Fz "0" pur SUCY MX 11-5% 10059 KX Mz 2513 450 22 Fy . Pz MX -DISCH My Mz 12 PLAN VIEW R Fel MX My Me ORIANTATION OF SUCT Fx DISCH Fy *a N O* Fz MX My MZ (1) 1.00× HORIZ + 0.067× VERT ----

DI