

RECEIVED DISTRIBUTION SERVICES UNIT

1981 FEB 17 PM 12 52



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

February 4, 1981

Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Dresden 2
SEP Topic VIII-2
On-Site Emergency Power Systems -
Diesel Generator
NRC Docket 50-237

Reference (a): D. M. Crutchfield letter to D. L. Peoples dated
August 20, 1980

Dear Mr. Crutchfield:

Commonwealth Edison has reviewed the staff evaluation on the above referenced topic transmitted by Reference (a). The report is a correct statement of the facts except for the ratings of the diesel generator shown on page six of the report. The correct ratings are:

2860 KW at .8 P.F for two hours
2600 KW at .8 P.F continuous

This is a minor change in the context of the report and will not change the results of the evaluation.

Paragraph 3.3 states that Dresden 2 Technical Specification do not meet current licensing criteria for diesel generator testing. Edison does not believe the technical specifications are the correct place to address detailed testing parameters for the diesel generators. Edison believes these parameters are better addressed in station procedures and tests as appropriate.

Please address any questions you may have concerning this matter to this office.

One (1) signed original and thirty-nine (39) copies of this transmittal have been provided for your use.

A035
3
1/0

Very truly yours,

Robert F. Janecek

Robert F. Janecek
Nuclear Licensing Administrator
Boiling Water Reactors

8102180287

P

cc: RIII Inspector - Dresden
0077B