NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Field	Value
01 Licensee Code (2)	I L D R S 2
License Number (3)	0 0 - 0 0 0 0 0 - 0 0
License Type (4)	4 1 1 1 1
Cat (5)	
CON'T 01 Report Source (6)	L
Docket Number (7)	0 5 0 0 0 2 4 9
Event Date (8)	1 1 4 8 1
Report Date (9)	0 2 0 9 8 1

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During Unit shutdown, while recirculating the condensate system, a 3/4 inch drain
03 line downstream of Minimum Flow Line Valve 2-3406-500 separated 2 inches from the
04 recirculation piping at a socket weld. The health and safety of the public was not
05 jeopardized because all leakage was contained in the Turbine Building Floor Drain
06 System. This was the first recorded event of this type at Dresden.
07
08

09	System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
	H H	E	C	P I P E X X	A	Z

LER/RO Report Number (17)	Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
	8 1	—	0 0 4	/	0 3	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
B	F	Z	Z	0 0 0 0	N	N	A	U 1 0 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Excessive vibration of the Minimum Flow Line caused the 16 inch long drain line to
11 completely break. Drain was temporarily plugged, and will be shortened and capped
12 during the present refueling outage. No further action deemed necessary.
13
14

15	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
	H	0 0 0	N/A	A	Abnormal Radwaste Input

16	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
	Z	Z	N/A	N/A

17 Personnel Exposures	Number (37)	Type (38)	Description (39)
	0 0 0	Z	N/A

18 Personnel Injuries	Number (40)	Description (41)
	0 0 0	N/A

19 Loss of or Damage to Facility (43)	Type (42)	Description
	Z	N/A

20 Publicity	Issued (44)	Description (45)	NRC Use Only
	N	N/A	

NAME OF PREPARER: G. Bergan PHONE: X-529

GPO 917-926

8102180577