

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 I L D R S 2 0000000000 00000000 0 41111 0 5
7 8 9 14 15 25 26 30 57 CAT. 58
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T
01 R P O S D O C T E R 05000237 011781 012981 9
7 8 80 81 68 69 74 75 80
 REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 | During local leak rate testing of containment vent line, the measured leakage was
03 | 1715.55 SCFH which exceeds Tech. Spec. 4.7.A for single isolation (29.38 SCFH).
04 | Investigation showed leakage through A0-2-1601-23. No leakage was detected through
05 | any other valve. The safety significance was minimal since all leakage was con-
06 | tained in the vent line. Similar Events: 50-249/80-07. Health and safety of the
07 | public was not affected.

08 _____ 7 8 9 80

09 S D E F V A L V E X B D 11 12 13 14 15 16
9 10 11 12 13 18 19 20
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

17 LER/RO REPORT NUMBER 81 005 03 L 0
21 22 24 26 27 28 29 30 31 32
 EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

Z A Z Z 0000 N Y N P340 26
33 34 35 38 37 40 41 42 43 44 47
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPSR-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 | Valve A0-2-1601-23 will be repaired before start-up of the unit. A supplemental
11 | report will be sent after investigation of the valve failure mode has been completed.
12 | _____
13 | _____
14 | _____

15 H 000 0 B Local Leak Rate Testing
7 8 9 10 12 13 44 45 46 80
 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

16 Z Z N/A N/A
7 8 9 10 11 44 45 80
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

17 000 Z N/A
7 8 9 10 11 44 80
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

18 000 N/A
7 8 9 10 11 44 80
 PERSONNEL INJURIES NUMBER DESCRIPTION

19 Z N/A
7 8 9 10 44 80
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

20 N N/A
7 8 9 10 68 69 80
 ISSUED PUBLICATION DESCRIPTION

NAME OF PREPARER K. Zirwas

PHONE: 942-2920 Ext 422

8102180666