

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 I L D R S 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

CON'T REPORT SOURCE L 0 5 0 0 0 2 3 7 0 1 2 3 8 1 0 2 1 7 8 1

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

02 During local leak rate testing of MSIV 203-2B, a packing leak was found which de-
03 graded the primary containment boundary. There was no effect on public health since
04 there was no leakage from the inboard isolation valve. Similar event was reported
05 R.O. 50-237/77-38.

09 SYSTEM CODE C D 11 CAUSE CODE E 12 CAUSE SUBCODE F 13 COMPONENT CODE V A L V E X 14 COMP. SUBCODE F 15 VALVE SUBCODE D 16
17 LER/RO REPORT NUMBER 8 1 EVENT YEAR 8 1 SEQUENTIAL REPORT NO. 0 0 8 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0
ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NPRO-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER C 6 6 5 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

10 The cause of the leak was worn out packing. The valve was repacked and local leak
11 rate tested satisfactorily. No further action is deemed necessary.

15 FACILITY STATUS H 28 % POWER 0 0 0 29 OTHER STATUS N/A 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Local Leak Rate Test 32

16 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY N/A 35 LOCATION OF RELEASE N/A 36

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION N/A 39

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION N/A 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION N/A 43

20 PUBLICITY ISSUED N 44 DESCRIPTION N/A 45

NAME OF PREPARER K. Zirwas

PHONE: 942-2920 Ext 422