



Telegram

1973 AUG 16 PH 2: 25

VEA193(1421)(1-0198580228)PD 08/16/73 1418

ICS IPMVEIA MVN

01179 IDVE MORRIS IL 84-5EA 08-18 1P CDT

50-237

PMS MR. BOYCE GRIER

DIRECTOR DIVISION OF COMPLIANCE REGION 3

US ATOMIC ENERGY COMMISSION

WUA

799 ROOSEVELT RD

GLENN ELYN IL 60157

TELEGRAMS (OTHER THAN MONEY ORDERS) *0-0*

IS THIS CALL DELIVERED? (YES-AGENT, NO-ADDRESSEE)

ADDRESS SECTION

Nbr. & Name *8/16* Date *3:10* By *177*

To be delivered by *mail*

Attempts to deliver (indicate DA or BY)

SUBJECT: DPR-19 DRESDEN NUCLEAR POWER STATION NO 2

THIS WILL CONFIRM A CONVERSATION WITH MR. FRED MAURA OF YOUR OFFICE OF 1145 HOURS THIS DATE CONCERNING A FAILURE OF THE HIGH PRESSURE COOLANT

INJECTION SYSTEM STEAM SUPPLY VALVE. MO2-2301-3 WHILE CONDUCTIN MONTHLY VALVE AND PUMP SURVEILLANCE THE VALVE FAILED IN THE *MO* POSITION RENDERING THE

SF-1201 (R5-69)

HPCI SYSTEM INOPERABLE. THE REQUIRED SURVEILLANCE FOR AN INOPERABLE HPCI SYSTEM WAS CONDUCTED AND AN INSPECTION OF THE FAILED VALVE HAS COMMENCED.

W.P. WORDEN
SUPERINDENT DRESDEN NUCLEAR
POWER STATION
COMMONWEALTH EDISON COMPANY
ROUTE 1 MORRIS IL

SF-1201 (R5-69)

Duplicate of 177

Incident

8/03030647