

Dresden Station19 ~~60~~ Report of Occupational Personnel Radiation Doses*
Commonwealth Edison Company

Station Employees

Job Function	Work Function					Total by Job Function # of People/Man-Rem
	Reactor Operations & Surveillance # of People/Man-Rem	Routine Maint. # of People/Man-Rem	Inservice Inspection # of People/Man-Rem	Waste Processing # of People/Man-Rem	Refueling # of People/Man-Rem	
Maintenance	15/19.8	263/366.4	1/0.5	1/1.8	2/2.7	282/391.2
Operating	103/119.6	7/11.6	2/3.5	22/38.4	17/35.4	151/208.5
Health Physics	2/2.7	38/54.3	3/4.5	15/21.4	4/6.2	62/89.1
Supervision	60/13.0	61/83.2	—	—	3/7.7	124/103.9
Engineering	52/72.3	59/21.3	11/4.0	3/1.1	5/1.8	130/100.5

Company Employees other than Station Employees

Special Maintenance	—	173/68.2	—	—	—	173/68.2
Engineering	227/13.2	—	—	—	—	227/13.2

Contract Workers

Routine Maintenance	—	2093/1053.4	—	—	—	2093/1053.4
---------------------	---	-------------	---	---	---	-------------

*Reported in accordance with U.S. NRC Regulatory Guide 1.16 (Rev. 4), 1975.

QUAD CITIES Station

19 ~~80~~ Report of Occupational Personnel Radiation Doses *
Commonwealth Edison Company

Station Employees

Work Function

Job Function	Reactor Operations & Surveillance # of People/Man-Rem	Routine Maint. # of People/Man-Rem	Inservice Inspection # of People/Man-Rem	Waste Processing # of People/Man-Rem	Refueling # of People/Man-Rem	Total by Job Function # of People/Man-Rem
Maintenance	9/30.3	87/391.6	1/1.8	1/4.9	5/15.2	103/443.8
Operating	82/101.1	1/3.3	—	30/107.4	16/50.2	129/262.0
Health Physics	8/21.9	4/9.6	3/8.7	10/25.4	8/21.9	33/87.5
Supervision	38/35.6	42/105.0	—	—	5/5.5	85/146.1
Engineering	51/94.3	23/30.4	4/4.7	1/1.0	8/11.0	87/141.4

Company Employees other than Station Employees

Special Maintenance	—	90/50.4	—	—	—	90/50.4
Engineering	143/18.5	—	—	—	—	143/18.5

Contract Workers

Routine Maintenance	—	3136/3560.6	—	—	—	3136/3560.6
---------------------	---	-------------	---	---	---	-------------

*Reported in accordance with U.S. NRC Regulatory Guide 1.16 (Rev. 4), 1975.

ZION Station

1980 Report of Occupational Personnel Radiation Doses * Commonwealth Edison Company

Station Employees

Job Function	Work Function					Total by Job Function # of People/Man-Rem
	Reactor Operations & Surveillance # of People/Man-Rem	Routine Maint. # of People/Man-Rem	Inservice Inspection # of People/Man-Rem	Waste Processing # of People/Man-Rem	Refueling # of People/Man-Rem	
Maintenance	7/4.5	120/129.0	—	—	—	127/133.5
Operating	107/49.8	26/12.3	—	16/7.8	6/11.9	155/81.8
Health Physics	6/9.0	16/23.5	—	5/6.7	—	27/39.2
Supervision	47/5.6	43/9.9	—	—	3/2.5	93/18.0
Engineering	82/23.3	50/9.4	7/1.4	5/1.0	7/1.4	151/36.5

Company Employees other than Station Employees

Special Maintenance	—	102/20.7	—	—	—	102/20.7
Engineering	127/8.0	—	—	—	—	127/8.0

Contract Workers

Routine Maintenance	—	1203/526.0	—	—	—	1203/526.0
---------------------	---	------------	---	---	---	------------

*Reported in accordance with U.S. NRC Regulatory Guide 1.16 (Rev. 4), 1975.