

174 DEC 18 AM 9 10 KS

WU AGCY WHEA

WU MVN ILL

WU043 BS 128A

VED364(1817)(2-040580E351)PD 12/17/74 1817

ICS IPMBNGZ CSP

8159424449 TDBN MORRIS IL 92 12-17 0617P EST

PMS JAMES G KEPPLER REGIONAL DIRECTOR DIRECTORATE OF REGULATORY OPERATIONS- REGION 3, WUX

US ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD

GLEN ELLYN IL 60137

SUBJECT DPR-19, DRESDEN NUCLEAR POWER STATION UNIT 2.

THIS WILL CONFIRM A CONVERSATION WITH PHIL HOKNSON OF YOUR OFFICE AT 1500 HOURS THIS DATE CONCERNING A FAILURE OF SWITCHES DPIS2-261-34 AANDC WHICH WAS DISCOVERED DURING REFUELING LOGIC TESTING OF THE LOW PRESSURE COOLANT INJECTION LOOP SELECTION CIRCUITRY. ADDITINAL DETAILS AND CORRECTIVE ACTION WILL BE FORTHCOMING IN THE FORM OF A TEN DAY LETTER. THIS FAILURE WOULD HAVE RENDERED THE LPCI LOOP SELECTION LOGIC INOPERABLE IF IT WERE REQUIRED BY CAUSING THE A LOOP TO BE SELECTED FOR INJECTION AT ALL TIMES.

BB STEPHENSON SUPERINTENDENT

DEC 18 1974

western union Telegram

8103060666