

WESTERN UNION

Telegram

VED031(1128)(1-008370A322).PD 11/13/74 1125

1974 NOV 18 AM 10:46 *rl*

ICS IPMVEIB MVN

TELEPHONES TO 312 - 858-2660/129

02037 TDVE MORRIS IL 11-18 910A CST

DATE DLD *Nov 18 1139 am*

PMS JAMES G KEPPLER WUX

ATTEMPTS TO DELIVER.

REGIONAL DIRECTOR DIRECTORATE OF REGUARLITY OPERATIONS

REGION 3 US ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD

GLEN ELLYN ILL 60137

SUBJECT 9 DPR-19 DRESDEN NUCLEAR POWER STATION
UNIT 2

THIS WILL CONFIRM A CONVERSATION WITH JOHNSON OF YOUR OFFICE
AT 1600 HOURS 15 NOVEMBER 1974 CONCERNING FAILURE OF B FEED
WATER LINE LOCAL LEAK RATE TEST OF VALVE 2-220-58B 2-220-62B
FAILURE OF CONTAINMENT PENETRATIONS FOR B LOW PRESSURE
COOLANT INJECTION VALVE FOR TORUS SPRAY DRY WELL SPRAY
AND FULL FLOW TEST LINE

SF-1201 (R5-69)

WESTERN UNION

Telegram

FAILURE OF DRY WELL TORUS INERTING AND PURGE SYSTEM LINE
BOUNDED BY AO-2-1601-21 2-1601-32 2-1601-56 2-1601-55 AND
MANUEL VALVE 2-8502-501 AND 2-8503-500 VALVE AO-2-16-01-55
HAD FAILED A LEAK RATE TEST EARLY IN 1974 BUT THIS SYSTEM
HAD PASSED LEAD RATES TESTS WITH THE MANUEL VALVE 2-8502-501
2-8503-500 SHUT

RECEIVED 11/18/74

BB STEPHENSON SUPERINTENDENT
DEESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON COMPANY
RT 1 MORRIS ILL 60450

NNNN

NOV 20 1974

SF-1201 (R5-69)

8103060790