

TO: James G. Kessler, Regional Director
Directorate of Regulatory Operations
Region III
U.S. Atomic Energy Commission
799 Roosevelt Road
Glenn Bllyn, IL 60137

DATE: 2 Dec 74
Telecopied: None 2 Dec 74
CC: [unclear]
DC: 1545 [unclear]
BY: [unclear]

CC: J. F. O'Leary, Director
Directorate of Licensing
U.S. Atomic Energy Commission
Washington, D.C. 20545

SUBJECT: DPE-19, Dresden Nuclear Power Station, Unit 2

This will confirm a conversation with P. Knop of your office at 1600 hrs ^{28 Nov} 28 Nov concerning:

A failure of one of the reactor building superstructure blow off panels which occurred during a ventilation system transient. Refueling activities were suspended on unit 2, unit 3 was shut down in accordance with the technical specifications. Additional details will be forthcoming in the form of a 10 day letter.

Station Dist: Originator (copy)
8103060806 Incident File (copy)
Telegram File (original)
To Call:
OH - 5-838-2660x16
DC - 9-1-301-973-7617 (auto)

B. E. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.E. #1
Morris, IL 60450
Telephone: 815-262-2920/2921x212