



Commonwealth Edison  
Dresden Nuclear Power Station  
R.R. #1  
Morris, Illinois 60450  
Telephone 815/942-2920

BBS Ltr. #458-76

June 16, 1976

Mr. James G. Keppler, Director  
Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

SUBJECT: Report of Unit 2 Isolation Condenser Tube Integrity  
IE Bulletin #76-1

Dear Mr. Keppler:

On May 14, 1976 a hydrostatic pressure test was performed on Unit 2 reactor vessel to comply with the 1971 ASME Code for the isolation condenser and HPCI safe end replacements and also for two welded valve replacements. The test was successfully performed for four (4) hours at a pressure of 1140 psig.

The isolation condenser tube bundle was included in the hydro boundary and no evidence of any leakage was noted. As a result of the hydrostatic test continued integrity of the tube bundle was verified.

Very truly yours,

B. B. Stephenson  
Superintendent  
Dresden Nuclear Power Station

BBS:JSK:jo

cc: G. Abrell/NLA  
NRC File  
J. Kolanowski

8103100011