

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME:

01	I	L	D	R	S	2
----	---	---	---	---	---	---

 LICENSE NUMBER:

00	-	00	00	00	00	-	00
----	---	----	----	----	----	---	----

 LICENSE TYPE:

4	1	1	1	1
---	---	---	---	---

 EVENT TYPE:

03

CATEGORY:

01	CON'T
----	-------

 REPORT TYPE:

L

 REPORT SOURCE:

L

 DOCKET NUMBER:

05	0	-	02	3	7
----	---	---	----	---	---

 EVENT DATE:

05	2	7	7	6
----	---	---	---	---

 REPORT DATE:

06	2	3	7	6
----	---	---	---	---

EVENT DESCRIPTION

02 DURING ROUTINE SURVEILLANCE TESTING, REACTOR PROTECTION SYSTEM 600 PSI BYPASS
03 PRESSURE SWITCH PS 2-263-51A WAS FOUND TO ACTUATE AT 610 PSI (TECH SPEC 3.1.A
04 LIMIT: LESS THAN 600 PSI). SYSTEM OPERABILITY WAS NOT AFFECTED BECAUSE REDUNDANT
05 PRESSURE SWITCH 2-263-51B OPERATED PROPERLY. PS 2-263-51A WAS ADJUSTED TO THE
06 PROPER SETPOINT. REPORTABLE SETPOINT DRIFT ON SIMILAR SWITCHES HAS OCCURRED SEVERAL TIMES.
(50-237/1976-37)

SYSTEM CODE:

I	A
---	---

 CAUSE CODE:

E

 COMPONENT CODE:

I	N	S	T	R	U
---	---	---	---	---	---

 PRIME COMPONENT SUPPLIER:

N

 COMPONENT MANUFACTURER:

M	2	2	5
---	---	---	---

 VIOLATION:

Y

CAUSE DESCRIPTION

08 THE EVENT WAS CAUSED BY INSTRUMENT SETPOINT DRIFT. PRESSURE SWITCH 2-263-51A IS
09 A MELETRON MODEL 372 PRESSURE SENSOR, WITH A RANGE OF 28-1400 PSIG.
10

FACILITY STATUS:

C

 % POWER:

0	2	5
---	---	---

 OTHER STATUS:

NA

 METHOD OF DISCOVERY:

B

 DISCOVERY DESCRIPTION:

NA

FORM OF ACTIVITY RELEASED:

Z

 CONTENT OF RELEASE:

Z

 AMOUNT OF ACTIVITY:

NA

 LOCATION OF RELEASE:

NA

PERSONNEL EXPOSURES

NUMBER:

0	0	0
---	---	---

 TYPE:

Z

 DESCRIPTION:

NA

PERSONNEL INJURIES

NUMBER:

0	0	0
---	---	---

 DESCRIPTION:

NA

OFFSITE CONSEQUENCES

15 NA

LOSS OR DAMAGE TO FACILITY

TYPE:

Z

 DESCRIPTION:

NA

PUBLICITY

17 NA

ADDITIONAL FACTORS

18 NA

19 8103100039

NAME: G. REIMERS

PHONE: EXT. 265



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

W. Kaskam

BBS Ltr. #76-478

June 24, 1976

Mr. James G. Keppler, Regional Director
Directorate of Regulatory Operations - Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Enclosed please find Reportable Occurrence Report number 50-237/1976-37.
This report is being submitted to your office in accordance with the Dresden
Nuclear Power Station Technical Specifications, Section 6.6.B.

Arthur M. Roberts
for B. B. Stephenson
Station Superintendent
Dresden Nuclear Power Station

BBS:jo

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
File/NRC