

EVENT DESCRIPTION (continued)

conditions with respect to the torus were as follows: at 0340 hours, torus water temperature was 98 degrees F; at 0430 hours, torus level was plus 2.25 inches. During the event, peak drywell pressure was 0.32 psi; peak torus pressure was 0.42 psi. Following the unit shutdown, a primary containment entry was made to visually inspect the torus and to troubleshoot valve 203-3A. No anomalies were noted during either the internal or the external torus inspection. By 0638 hours, torus level was again within Tech Spec limits. This is the first failure of a Target Rock safety/relief valve at Dresden. (50-237/1976-34)

CAUSE DESCRIPTION (continued)

valve leakage to within the vendor's specifications. To further ensure valve operability, the solenoid valve was disassembled, inspected, and replaced following the discovery of foreign matter in the solenoid valve body. After repairs had been completed, the unit was returned to operation on May 26, and the valve was successfully tested at both 150 and 950 psi.

To prevent recurrence, the pilot stage of these valves will be leak-tested during the annual refueling outages. Valve 2-203-3A is a 6-x10- inch combination safety/relief valve, model 7367, manufactured by Target Rock Corp.



Commonwealth Edison

Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

BBS Ltr. #439-76

June 7, 1976

Regulatory File CY

Mr. James G. Keppler, Regional Director
Directorate of Regulatory Operations - Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137




Enclosed please find Reportable Occurrence number 50-237/1976-34.
This report is being submitted to your office in accordance with the
Dresden Nuclear Power Station Technical Specifications, Section 6.6.B.

B. B. Stephenson
Station Superintendent
Dresden Nuclear Power Station

BBS:smp

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
File/NRC



5943