



Telegram

00050

1975 MAY -9 PH 5:47

VER287(1746) (2-059360E129) PD 05/09/75 BCCX NO. CPR. NO.

ICS IRMBNGZ CSP

TELEPHONE NO. 312-858-2660

8159424449 TDBN MORRIS IL 70 05-09

TELEPHONED TO JJK BY 40

PMS JAMES G KEPPLER REGIONAL DIRECTOR

DATE DLD. 5/9/75 TIME 1024H

OPERATIONS, WUX

ATTEMPTS TO DELIVER 51000 of 1038A to 428A mail

REGION 3 US NUCLEAR REGULATORY COMMISSION 799 ROOSEVELT RD

GLEN ELLYN IL 60137

SUBJECT: DPR-25 DRESDEN NUCLEAR POWER UNIT 3.

THIS WILL CONFIRM A CONVERSATION WITH MR P JOHNSON AT YOUR OFFICE AT 1515 HOURS THIS DATE CONCERNING FAILURE OF THE 24/48 VDC BATTERY TO DELIVER RATED CAPACITY DURING REFUELING OUTAGE TESTING. BATTERY CHARGERS FOR THE BATTERY WERE OPERABLE. NEW CELLS WILL BE INSTALLED WHILE THE UNIT IS SHUT DOWN AT RATED CAPACITY DEMONSTRATED PRIOR TO START UP.

BB STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION

SF-1201 (RS-69) COMMONWEALTH EDISON CO RR#1 MORRIS ILLINOIS 60450

MAY 16 1975

810310530

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

A. IE Inspection Report No. _____

Transmittal Date : _____

Distribution:
IE Chief, FS&EB
IE:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)
IE Files

Distribution:
IE Chief, FS&EB
IE:HQ (4)
L:D/D for Fuels & Materials
DR Central Files
IE Files
IE Chief, M&PPB
L:D/D for Reactor Project

B. IE Inquiry Report No. _____

Transmittal Date : _____

Distribution:
IE Chief, FS&EB
IE:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)
IE Files

Distribution:
IE Chief, FS&EB
IE:HQ
DR Central Files
IE Files

C. Incident Notification From: Commonwealth Edison Company 50-249
(Licensee & Docket No. (or License No.))

Transmittal Date : May 19, 1975 Dresden Station Unit 3

Distribution:
IE Chief, FS&EB
IE:HQ (4)
Licensing (4)
DR Central Files
IE Files

Distribution:
IE Chief, FS&EB
IE:HQ (4)
L:D/D for Fuels & Materials
DR Central Files
IE Files



A0
(2)