

Telegram

BNB032(0941)(1-003451C004)PD 01/04/74 0938

ICS IPMVEIG MVN

07006 02235 TDVE MORRIS ILL 83 01-03 425P CST

50-237

FON 3128582660

MR JAMES G KEPPLER REGIONAL DIRECTOR DIRECTORATE OF  
REGULATORY OPERATIONS REGENT 3 US ATOMIC ENERGY  
COMMISSION 799 ROOSEVELT RD GLEN ELLYN IL 60137

SUBJECT DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2. THIS WILL  
CONFIRM A CONVERSATION WITH FRED MAURA OF YOUR OFFICE AT 245PM THIS  
DATE CONCERNING DISCOVERY OF 1-1-74 OF 2 OPEEN 5 INCH PENETRATION  
BETWEEN THE REACTOR BUILDING AND THE TURBINE BUILDING WHICH COMPRISE  
THE ABILITY OF THE STANDBY GAS TREATMENT SYSTEM TO MAINTAIN 0/25  
ONCHES WATER VACCUM IN THE BUILDING. THE OPENING HAS SINCE BEEN  
SEALED AND FURTHER INFORMATION WILL BE FORWARDED TO YOU IN A 10 DAY  
LETTER.

JAN 7 1974

SF-1201 (R5-69)

Telegram

western union

W P WORDEN SUPERINTENDENT DRESDEN NUCLEAR POWER STATION  
COMMONWEALTH EDISON COMPANY ROUTE 1 MORRIS ILLINOIS

NNNN

NNNN

Duplicate

8103120319

Abnormal  
occ

SF-1201 (R5-69)