

Western Union

Telegram

VEA250(1724)(1-028860C338)PD 12/04/73 1721

1973 DEC -4 PH 4: 25

ICS IPMVEIC MVN

03151 TDVE MORRIS IL 107 12-04 355PM CST

50-237

PMS MR JAMES G. KEPPLER

TELEGRAMS (OT...)

REGIONAL DIRECTOR, DIRECTORATE OF REGULATORY OPERATIONS

Is PHYSICAL DELIVERY requested?

REGION 3, US ATOMIC ENERGY COMMISSION

DATE 12/4/73

799 ROOSEVELT ROAD

DATE 12/4/73

GLENELLYN IL 60137

To be mailed by

Attempts to deliver (Indicate DA or BY)

373-858-2660
9:57A PDC By KE

SUBJECT DPR 19 DRESDEN NUCLEAR POWER STATION UNIT 2

THIS WILL CONFIRM A CONVERSATION WITH MR MAURA OF YOUR OFFICE AT 1505 HOURS THIS DATE CONCERNING UNIT 2 TORUS HIGH LEVEL CONDITION CAUSED BY DRAIN FROM HPCI DRAIN LINE GOING TO TORUS. WHILE MAINTANANCE PATCHED STEAM DRAIN LINE TO CONDENSOR, HPCI STEAM DRAINS WERE LINED UP TO TORUS. OPERATIONS FAILED TO GET THE REPORT THAT REPAIRS WERE COMPLETE, AND FAILED TO NOTICE GRADUAL RISE IN TORUS LEVELS UNTIL ALARM SOUNDED BEYOND LIMITS AT 0715 TODAY. LINE WAS

SF-1201 (R5-69)

Western Union

Telegram

1973 DEC -4 PH 4: 25

RESTORED TO NORMAL ON HPCI DRAIN AND TORUS LEVEL PUMPED DOWN TO NORMAL LEVEL AT 0900.

W T WORDEN, SUPERINTENDENT DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON COMPANY RR 1 MORRIS ILLINOIS

NNNN

8103120478

DEC 7 1973

abnormal
see.

SF-1201 (R5-69)