

western union

Telegram

1973 NOV 27 AM 9:22

VED072(1020)(1-005631C331)PD 11/27/73 1019

ICS IPMVEIE MVN

05048 TDVE MORRIS IL 77 10EX 11-27 838A CST
PMS JAMES G KEPPLER, REGIONAL DIRECTOR
DIRECTORATE OF REGULATORY OPERATIONS
REGION 3 US ATOMIC ENERGY COMMISSION WUX 799 ROOSEVELT ROAD
GLENELLYN IL 60137

SUBJECT DPR-19 DRESDEN NUCLEAR POWER STATEION UNIT 2
THIS WILL CONFIRM A CONVERSATION WITH MR FISHER OF
YOUR OFFICE AT 1630 HOURS NOVEMBER 26 1973 CONCERNING
TORUS HIGH LEVEL FOLLOWING HPCI SURVEILLANCE. TORUS
LEVEL WAS FOUND TO BE APPROXIMATELY 15 THOUSAND GALLONS
IN ACCESS OF THE LICENSE LIMIT. AT 2130 NOVEMBER 23
1973 THE TORUS WAS SAMPLED AND EXCESS PUMPED OUT TO
RESTORE TORUS TO PROPER LEVEL

SF-1201 (R5-69) W P WORDEN SUPERINTENDENT

western union

Telegram

DRESDEN NUCLEAR POWER STATION RTE 1 MORRIS IL

NNNN

TELEGRAMS (OTHER THAN MONEY ORDERS) NO D

Is PHYSIC (AGENT, NO-ADDRESSEE)
AGENT
Nbr. &
Date 11-27 1107A 312-858-2660
To be
Attempts to deliver NOV 29 97 (BY)

Duplicate
(see orig TX)

8103120607