



Telegram

1973 AUG 16 PM 2:46

58-237

VEB135(1441)(1-020700C223)PD 08/16/73 1431

ICS IPMVEIB MVN

02025 TDVE MORRIS IL 59 08-16 100P CDT

PMS BOYCE GRIER, DIRECTOR DIVISION OF COMPLIANCE REGION 3
US ATOMIC ENRGY COMMISSION

WUX

799 ROOSEVELT RD

GLEN ELYN IL 60137

SUBJECT DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2

THS WILL CONFIRM A CONVERSATION WITH MR FRED MAURA OF
YOUR OFFICE AT 1145 HOURS THIS DATE CONCERNING A CONDITION
WHICH RESULTED IN THE MAXIMUM ALLOWABLE WATER VOLUME IN
UNIT 2 SUPPRESSION CHAMBER BEING EXCEEDED BY APPROXIMATELY
1,400 CUBIC FEET FOR A PERIOD OF THREE HOURS

W P WORDEN, SUPERINTENDENT

AUG 16 1973

SF-1201 (R5-69)

DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON CO
ROUTE 1
MORRIS IL

TELEGRAMS (OTHER THAN MONEY ORDERS) *UC-D*

IS PRA. CAL DELIVERY reg. tested? (YES-AGENT NO-AGENT)

Attn: *AKG*

No. *312-258-2660*

Date *8-16-73* *3:34 PM*

To be mailed or filed *Mail*

Attempts to deliver *AKG*

SF-1201 (R5-69)

8103130360

Incident