



Telegram

ENEG49(0993)(1-004698C194)PD 07/13/73 0901

ICS IPHVEIC MVN

03603 (1-029803C193 1653 01238)

FON 3128582660

TDVE MORRIS ILL 64 07-12 335P CDT

MR BOYCE GRIER DIRDIV OF CO PLIENCE REGION 3

US ATOMIC COMMISSION 799 ROOSEVENT RD

GLEN ELLYN ILL 60137

SUBJECT DPR-19 DRESDAN NUCLEAR POWER STATION UNIT TWO

THIS WILL CONFIRM OUR CONVERSATION WITH MR DANCE OF YOUR

OFFICE AT 1430 HOURS THIS DATE CONCERNING HIGH ACTIVITY IN

B FLOOR DRAIN SAMPLE TANK ACTIVITY AT 0839 THIS DATE WAS

0.011 MICRO CURIE/ML WHICH CALLS FOR THE CURRIE CONTENTS TO EXCEED TH

E

TECH SPEC LIMITS OF .7 CURRIE BY APPROXIANTELY .1 CURRIES

ACTIVITY IS BELIEVED TO RE RESIDUAL FROM PREVIOUS HIGH

APR 1 6 197

SF-1201 (R5-69)

ACTIVITY WATER SINCE OTHER TANK HAVE NOT EXPERIENCE THIS

ACTIVITY WILL LIMIT LEVEL IN B FLOOR DRAIN SAMPLE TANK

UNTIL CONDITIONS PERMIT EMPTYING AND CLEANING

V P VORDEN SPT DREDAN NUCLEAR POWER STATION COMMONWEALTH EDISON CO

RT 1 MORRIS ILL

SF-1201 (R5-69)

*Duplicate of 174 (copy)*

8103130436