



Telegram

VER362(2125)(1-039643C166)PD 06/15/73 21973 JUN 15 P11 9: 24 312-858-2660
 ICS IPMVEIS MVN TELEGRAMS (OTHER THAN MONEY ORDERS)
 07167 TDVE MORRIS IL 118 06415 04477 PL 5574. requested? (YES-AGENT, NO-ADDRESSEE)
 PMS MR BOYCE GRIER, DIRECTOR DIVISION OF COMPLIANCE Nbr. ADDRESSSEE SECTION
 REGION 3 U.S. ATOMIC ENERGY COMMISSION Time old 11AM To 84 By OM
 799 ROOSEVELT ROAD WUX Attempts to deliver (Indicate DA or BY)
 GLEN ELLYN IL 60137

SUBJECT DPR19 DRESDEN NUCLEAR POWER STATION UNIT TWO.
 THIS WILL CONFIRM A CONVERSATION WITH MR MAURA OF YOUR OFFICE AT
 1500 HOURS THIS DATE CONCERNING PRESSURE SWITCHES 2-263-51A AND B
 ABOVE THE TECH SPEC LIMITS OF 600 PSI. THIS SWITCH BYPASSES THE
 MAIN BEAM ISOLATION VALVE CLOSURE SCRAM AND CONDENSOR LOW
 VACUUM SCRAM WHEN REACTOR PRESSURE IS LESS THAN 600 PSI. DRIFT
 WAS DISCOVERED DURING ROUTINE SURVEILLANCE. REACTOR HAS
 NEVER BEEN OPERATED ABOVE 600 PSI WITHOUT ADEQUATE CONDENSOR
 VACUUM OR WITH ALL MAIN STEAM ISOLATION VALVE CLOSED
 W P WORDEN SUPT DRESDON NUCLEAR POWER STATION COMMONWEALTH EDISON CO
 ROUTE 1 MORRIS ILL

JUN 20 1973

SF-1201 (RS-69)

~~8103130445~~
2170 TUX

8103130445