



Commonwealth Edison

DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
	D-12	- 3	- 81	- 11

PART 1 TITLE OF DEVIATION	OCURRED
SBLC Tank Low Temperature	2/12/81 1840
SYSTEM AFFECTED	DATE TIME

PLANT CONDITIONS	TESTING
Standby Liquid Control	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
MODE Run PWR(MWT) 2501	
LOAD(MWE) 829	

DESCRIPTION OF EVENT
 Operator on his normal rounds found SBLC tank temperature at 77°F. Per last samples on 2-6-81 solution was 16.50 % sodium pentaborate. The required temperature per Tech. Spec. curve 3.4.2 should have been greater than or equal to 83°F.

DESCRIPTION OF CAUSE
 Temperature control setpoint was found set at 56°F. Reason unknown at this time.

OTHER APPLICABLE INFORMATION
 Operator was instructed to raise temperature control setpoint and temperature was 83° by 2130 hours.

EQUIPMENT FAILURE	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	DR NO.	WR NO.	Responsible Supervisor	Date
		N/A	N/A	Carl Chapman	2/12/81

PART 2 OPERATING ENGINEERS COMMENTS
 Tank was sampled and temperature setpoint was returned to normal.

TYPE OF DEVIATION REPORTABLE OCCURRENCE	EVENT OF POTENTIAL PUBLIC INTEREST	TECH SPEC VIOLATION	NON-REPORTABLE OCCURRENCE	ANNUAL REPORTING	SAFETY-RELATED WR ISSUED
<input type="checkbox"/> 14 DAY <input type="checkbox"/> 10CFR21	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
<input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.b					

REPORTABLE OCCURRENCE NUMBER	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION	DATE	TIME
81-06/03L-0		R. M. Ragan	2/13/81	0600
		TITLE	DATE	TIME
		TITLE	DATE	TIME

24-HOUR NRC NOTIFICATION	1935 & 2130	PROMPT OFF-SITE NOTIFICATION	DATE	TIME
<input checked="" type="checkbox"/> TPH ENS Phone REGION III	2/12/81	F. A. Palmer	2/17/81	12:50
<input type="checkbox"/> TGM REGION III & DOL	DATE TIME	TITLE	DATE	TIME
		TITLE	DATE	TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC

REVIEW AND COMPLETED	John M. Almer	2/13/81
	OPERATING ENGINEER	DATE

ACCEPTANCE BY STATION REVIEW AS REQUIRED
 DATE
 RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION

J. Brunner 3/9/81
Michael W. Wright 3-9-81
Douglas R. ... 3/9/81
 STATION SUPERINTENDENT DATE