

TO: Regional Director  
Directorate of Regulatory Operations  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Telecopy Date 2-14-78  
or  
Telegrammed GE 12:51  
DC \_\_\_\_\_  
By \_\_\_\_\_

cc:  
Director  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

• SUBJECT: DPR- 19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with Heinz of  
your office at SUN. 2/12/78 hrs this date concerning

*CONDUCTIVITY*  
INCREASE TO 9.2 MMHO'S - COND.  
Demin DP INCREASED TO 70PSID  
FOR SHORT PERIOD DURING WHICH  
RESINS WERE INTRODUCED TO REACTOR  
CAUSING COND. SPIKE. INVESTIGATION  
AS TO CAUSE IN PROGRESS. COND.  
RETURNED TO 65 IN 2 NRS.

*J. Kolanowski*  
*2/14/78*

\*\*\*\*\*

To Call:  
GE - 7-858-2660x16  
DC - 9-1-301-492-7617 (auto)  
WU - 815-942-4449/4321

Station Dist: Originator (copy)  
Incident File (copy)  
Telegram File (orig)

B. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Company  
R.R. #1  
Morris, IL 60450

Telephone: 815-942-2920/2921x212  
(telecopy x262)

Rev. 12-75

8103180059