

TO: Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DATE: _____
Telecopy _____ Date 12/19/77
or
Telegrammed: GE DB 3:45PM
DC _____
By SB

cc: Director
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit _____.

This will confirm a conversation with W. Shafer of your office at 1330 hrs this date concerning HPCI Sys inoperability. A STM leak in the HPCI Exhaust line flange resulted in an isolation of the HPCI Sys. on high Temp. The HPCI Sys was declared Inop. and required surveillance completed successfully. The STM leak has been repaired.

To Call: *****
GE - 7-858-2660x16 *****
DC - 9-1-301-492-7617 (auto) *****
WU - 815-942-4449/4321 *****

B. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450

Station Dist: Originator (copy) *****
Incident File (copy) *****
Telephone: 815-942-2920/2921x212 *****

810 3180062

Rev. 12-75

RECEIVED DOCUMENT
CONTROL DESK

11131

1978 JAN 17 AM 8 37

HPC 1

U.S. NRC
DISTRIBUTION SERVICES
BRANCH

Pump Exhaust GASKET