

TO: Regional Director  
Directorate of Regulatory Operations  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

DATE: \_\_\_\_\_  
Telecopy \_\_\_\_\_ Date 12/19/77  
or  
Telegrammed: GE DB 3:45PM  
DC \_\_\_\_\_  
By SB

cc: Director  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit \_\_\_\_\_.

This will confirm a conversation with W. Shafer of your office at 1330 hrs this date concerning HPCI Sys inoperability. A STM leak in the HPCI Exhaust line flange resulted in an isolation of the HPCI Sys. on high Temp. The HPCI Sys was declared Inop. and required surveillance completed successfully. The STM leak has been repaired.

\*\*\*\*\*  
To Call: \*\*\*\*\*  
GE - 7-858-2660x16 \*\*\*\*\*  
DC - 9-1-301-492-7617 (auto) \*\*\*\*\*  
WU - 815-942-4449/4321 \*\*\*\*\*

Station Dist: Originator (copy) \*\*\*\*\*  
Incident File (copy) \*\*\*\*\*  
\*\*\*\*\*

B. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Company  
R.R. #1  
Morris, IL 60450

Telephone: 815-942-2920/2921x212  
\*\*\*\*\*

Rev. 12-75

810 3180062

RECEIVED DOCUMENT  
CONTROL DESK

11131

1978 JAN 17 AM 8 37

HPC 1

U.S. NRC  
DISTRIBUTION SERVICES  
BRANCH

Pump Exhaust GASKET