

TO: Regional Director  
Directorate of Regulatory Operations  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

DATE: \_\_\_\_\_  
Telecopies Date 12/2/77  
or  
Telegrammed GE 4:00 pm  
DC \_\_\_\_\_  
By \_\_\_\_\_

cc: Director  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

SUBJECT: DPR- 19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with W. SCHAFFER of  
your office at 1130 hrs this date concerning D-2

DIESEL GENERATOR FAILURE TO START  
WHILE 2/3 D-6 INOPERABLE FOR COOLING  
WATER PUMP REPAIR. DIESEL SUBSEQUENTLY  
STARTED THREE TIMES - SUSPECT  
FUEL FILTER PROBLEM. FILTERS WILL  
BE CHANGED OUT AS SOON AS POSSIBLE

*J. Kolonowski*

\*\*\*\*\*  
To Call:  
GE - 7-858-2660x16  
DC - 9-1-301-492-7617 (auto)  
WU - 815-942-4449/4321

Station Dist: Originator (copy)  
Incident File (copy)  
Telegram File (orig)

B. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Company  
R.R. #1  
Morris, IL 60450

Telephone: 815-942-2920/2921x212  
(telecopy x262)

Rev. 12-75

8103180067

RECEIVED DOCUMENT  
PROCESSING UNIT

1977 DEC 28 AM 8 07

*[Faint, illegible handwritten text, possibly bleed-through from the reverse side of the page]*