

TO: Regional Director  
Directorate of Regulatory Operations  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

DATE:

Telecopies Date 2/10/78  
or  
Telegrammed GE 3:50  
DC \_\_\_\_\_  
By \_\_\_\_\_

cc: Director  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with W. Schaefer of  
your office at 3:45 PM hrs this date concerning

*BINDING OF VACUUM BREAKERS  
1601-31A & B DURING ROUTINE  
SURVEILLANCE. EXCESSIVE GREASE  
REMOVED FROM VALVE PACKINGS  
AND SUBSEQUENTLY EXERCISED  
SATISFACTORILY*

*J. Kolonowski  
2/10/78*

\*\*\*\*\*  
To Call:  
GE - 7-858-2660x16  
DC - 9-1-301-492-7617 (auto)  
WU - 815-942-4449/4321  
\*\*\*\*\*

B. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Company  
R.R. #1  
Morris, IL 60450

Station Dist: Originator (copy)  
Incident File (copy)

Telephone: 815-942-2920/2921x212  
(teletype 262)

Rev. 12-75

8103180080