

1254P EST SEP 9 72

SSE150 DE CCA023 (CH 253CC106023) PD WU TRUX IL MVN

0142P EDT 09/09/72

56-237

ZCZC 095 JQ PDF TDVE MOPRIS ILL 9 1129A CDT  
MR BOYCE GRIER, DIR OF COMPLIANCE REGION 3  
US ATOMIC ENERGY COMM (DLR DONT FONE)  
799 ROOSEVELT RD GLEN ELLYN ILL 60136

BT  
SUBJECT DPR-19 DRESBAN NUCLEAR POWER STATION UNIT TWO  
THIS IS TO CONFIRM A CONVERSATION WITH MR. H. DANCE  
OF YOUR OFFICE AT 1700 HOURS YESTERDAY CONCERNING AN  
INSTRUMENT SET POINT DRIFT BEYOND THE LIMITS ALLOWED  
IN SECTION 3.1 OF THE TECHNICAL SPECIFICATION DURING  
CALIBRATION ON SEPTEMBER 8 1972 THE EHC LOW OIL  
PRESSURE SCRAM SWITCHES. PS-LS-1-2-3 WERE FOUND SET  
AT 881PSIG, AND 849PSIG, RESPECTIVELY, COMPARED TO A

SF-1201 (R5-69)

LIMIT OF 900 PSIG DECREASING THESE SWITCHES HAVE  
HISTORY OF DRIFTING AS RELATED IN THE LETTER TO  
MR BLOCH FR  
M MR WORDEN DATED AUGUST 23, 1972.  
SWITCHES PF-LF-3 IS ONE OF THE NEW SWITCHES INSTALLED  
AS REFERENCED IN THAT LETTER,  
TO PROVIDE A LARGER MARGIN FOR INSTRUMENT ACCURACY  
THE CALIBRATION SET POINT TARGET OF THESE SWITCHES  
WILL BE CHANGED TO 935PSIG PLUS OR MINUS 5PSIG.  
THE CAUSE OF THIS PHOMEMON IS STILL UNDER INVESTIGATI  
N  
AND LETTER WILL BE FORWARDED AS REQUIRED BY SECTION  
6.B.2 OF THE TECHNICAL SPECIFICATION

SF-1201 (R5-69)

W P WORDEN, SUPT,

DRESDEN NUCLEAR POWER STATION  
MORRIS ILLINOIS.

DPR-19 1700 3.1 8 1972 EHC PS-LS-1-2-3 881PSIG 849PSIG  
900 PSIG 23 1972 PF-LF-3 935PSIG 6.B.2  
NNNN(0149P EDT)

8103230684

*D.R. Central file*  
TELEGRAMS (OTHER THAN MONEY ORDERS)  
(YES-AGENT, NO-ADDRESS)  
ADDRESS SECTION  
TELEPHONE DELIVERY requested?  
Date of filing  
To be mailed or filed  
Attempts to deliver  
Indicate DA or BY

~~D. H. H.~~

Misc Appl.

Copy sent PDR

1443