

DR Central file

58-237
Telegram

VEB030(0939)(1-005441C265002)PD 09/21/72 0935
ICS IPMVEIA MVN
ZCZC 093 A EE PD TDVE MORRIS ILL 20 NFT
PMS BOYCE GRIER US ATOMIC ENERGY COMMISSION DIV OF
COMPLIANCE REGION 3 799 ROOSEVELT RD GLENELLYN ILL
SUBJECT DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2
THIS IS TO CONFIRM OUR CONVERSATION WITH MR H DANCE OF YOUR
OFFICE AT 1415 HOURS THIS DATE CONCERNING
AN INSTRUMENT UP SCALE DRIFT BEYOND THE LIMITS SPECIFIED
IN SECTION 3.2 OF THE TECHNICAL SPECIFICATIONS
DURING INSTRUMENT CALIBRATION CHECKS ON SEPTEMBER
19 1972 REACTOR LOW PRESSURE PERMISSIVE SWITCHES (FOR
OPENING CORE SPRAY AND LPCI ADMISSION VALVES)
PS-2-263-52A1 AND PIS-2-263-52B2 WERE FOUND SET
AT A VALUE OF 357PSIG AND 352PSIG, RESPECTIVELY
COMPARED TO A LIMIT OF 350PSIG, DECREASING.

312-
557-2660
TELEGRAMS (OTHER THAN MONEY ORDERS)
Is PHYSICAL DELIVERY requested? (YES-AGENT, NO-ADDRESSEE SECTION)
AGENT SECTION ADDRESS SECTION
NO. & DATE
To be filled in by sender
To be filled in by receiver (indicate SA of BY)
10

SF-1201 (R5-69)

THESE SWITCHES DO NOT HAVE A HISTORY OF DRIFTING.
THEY WERE PREVIOUSLY SET AS CLOSE TO 350PSIG AS PRACTICAL
SINCE THE SWITCHES HAVE A 50PSIG TRIP SETTING SPAN
(TABLE 3.2.2 OF THE TECHNICAL SPECIFICATION) THEY WILL
BE SET TO THE CENTER OF THIS SPAN IN THE FUTURE. THIS
SHOULD PREVENT SIMILAR OCCURANCES IN THE FURE
SINCERELY

W P WORDEN SUPERINTENDANT DRESDEN NUCLEAR POWER STATION

SF-1201 (R5-69)

8103230691

1448
Copy sent PDR
Misc appl