

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	1	L	L	D	R	S	3	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4	5		
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

0	1	L	6	0	5	0	0	0	2	4	9	7	0	3	0	3	8	1	8	0	3	2	5	8	1	9
7	8	REPORT SOURCE		60	61	DOCKET NUMBER						68	69	EVENT DATE			74	75	REPORT DATE					80		

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation, the 3A Recirc. Pump began to run back from 90% speed and

0 3 | Recirc. Pump speed mismatch alarm annunciated. 3A scoop tube was locked out at 58%

0 4 | but 3A speed increased to 68%. 3B Recirc. speed control was then placed in manual

0 5 | and reduced to 68% in order to satisfy mismatch criteria of Dresden Tech Spec

0 6 | 3.6.H.1. Safety significance was minimal because of the short duration of less than

0 7 | 3 minutes of mismatch. Similar event: LER 80-34/03L-0.

0	8	7	8	9																													80
---	---	---	---	---	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

0	9	C	B	11	E	12	G	13	I	N	S	T	R	U	14	C	15	Z	16	17	8	1	21	22	23	0	0	9	24	25	26	27	0	3	28	29	L	30	31	0	32	G	0	8	0	26																									
7	8	SYSTEM CODE		9	CAUSE CODE		11	CAUSE SUBCODE		12	COMPONENT CODE						13	COMP. SUBCODE		19	VALVE SUBCODE		20	LER/RO REPORT NUMBER		21	22	SEQUENTIAL REPORT NO.		24	25	26	OCCURRENCE CODE		28	REPORT TYPE		30	REVISION NO.		32	ACTION TAKEN			33	34	EFFECT ON PLANT		35	SHUTDOWN METHOD		36	HOURS		37	ATTACHMENT SUBMITTED		41	NPRO-4 FORM SUB.		42	PRIME COMP. SUPPLIER		43	COMPONENT MANUFACTURER			44	45	46	47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Event was caused by an unexplained failure of MG Set speed controller, GE Model 50-

1 1 | 5430, 41D-AA Z1PBE. Corrective action was to lock out A and B scoop tubes, thereby

1 2 | eliminating speed controller effects on Recirc. Pump speeds and any consequent speed

1 3 | mismatches. Further actions call for monitoring the speed controller signals for

1 4 | data analysis to determine failure mode of controller.

1	5	E	28	0	9	9	29	NA	30	A	31	Operator Observation	32						
7	8	FACILITY STATUS		9	% POWER			12	OTHER STATUS		30	METHOD OF DISCOVERY			45	DISCOVERY DESCRIPTION			32

1	6	Z	33	Z	34	NA	35	NA	36					
7	8	ACTIVITY CONTENT		9	RELEASED OF RELEASE		10	AMOUNT OF ACTIVITY		35	LOCATION OF RELEASE			36

1	7	0	0	0	37	Z	38	NA	39					
7	8	PERSONNEL EXPOSURES		9	NUMBER		10	TYPE		37	DESCRIPTION			39

1	8	0	0	0	40	NA	41				
7	8	PERSONNEL INJURIES		9	NUMBER		10	DESCRIPTION			41

1	9	Z	42	NA	43							
7	8	LOSS OF OR DAMAGE TO FACILITY		9	TYPE			42	DESCRIPTION			43

2	0	N	44	NA	45	NRC USE ONLY												
7	8	PUBLICITY ISSUED		9	DESCRIPTION			44										

NAME OF PREPARER Raymond Magrow PHONE: (815) 942-2920, X-421

8104080566