

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 I L D R S 3 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

0 1 REPORT SOURCE L 6 0 5 0 0 0 2 4 9 7 0 4 0 3 8 1 8 0 4 1 0 8 1 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 During an orderly unit shutdown while performing the quarterly timing surveillance
0 3 of the main steam isolation valves, valve 3-203-1C had a closure time of 2.3 seconds.
0 4 Tech. Spec. Table 3.7.1 requires closure time limits of between 3 and 5 seconds.
0 5 Minimal effect upon public health and safety because remaining MSIV closure times
0 6 were within Tech. Spec. limits and all valves were operable. There have been similar
0 7 occurrences, the last being R.O. #80-046/03L-0.

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
C D 11 E 12 B 13 V A L V E X 14 F 15 D 16

17 LER/RO REPORT NUMBER 8 1 21
EVENT YEAR 8 1 22
SEQUENTIAL REPORT NO. 0 1 1 24
OCCURRENCE CODE 0 3 28
REPORT TYPE L 30
REVISION NO. 0 32
ACTION TAKEN E 18 Z 19 33 34
FUTURE ACTION Z 20 35
EFFECT ON PLANT Z 21 36
SHUTDOWN METHOD 0 0 0 0 37
HOURS 0 0 0 0 40
ATTACHMENT SUBMITTED N 23 41
NPRD-4 FORM SUB. N 24 42
PRIME COMP. SUPPLIER N 25 43
COMPONENT MANUFACTURER C 6 6 5 26 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 MSIV 3-203-1C timing mechanism became misadjusted during normal plant operation.
1 1 MSIV 3-203-1C was adjusted and timed at 3.4 seconds. The quarterly timing surveil-
1 2 lance will continue to be performed to ensure proper closure times are maintained.
1 3
1 4

1 5 FACILITY STATUS D 28 7 8 9
% POWER 0 3 2 29 10 11 12 13
OTHER STATUS NA 30 44
METHOD OF DISCOVERY B 31 45
DISCOVERY DESCRIPTION Operator Observation 32 80

1 6 ACTIVITY CONTENT Z 33 Z 34 7 8 9 10 11
RELEASED OF RELEASE N/A 35 44
AMOUNT OF ACTIVITY N/A 36 45
LOCATION OF RELEASE 36 80

1 7 PERSONNEL EXPOSURES 0 0 0 37 Z 38 7 8 9 10 11 12 13
NUMBER TYPE DESCRIPTION N/A 39 80

1 8 PERSONNEL INJURIES 0 0 0 40 7 8 9 10 11 12 13
NUMBER DESCRIPTION N/A 41 80

1 9 LOSS OF OR DAMAGE TO FACILITY Z 42 NA 7 8 9 10 11 12 13
TYPE DESCRIPTION NA 43 80

2 0 PUBLICITY ISSUED N 44 NA 7 8 9 10
DESCRIPTION NA 45 80

NAME OF PREPARER Randy D. Speroff

PHONE: 815-942-2920

8104220514