

5-6-81

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of )  
COMMONWEALTH EDISON COMPANY ) Docket Nos. 50-237-SP  
(Dresden Station, Units 2 & 3) ) 50-249-SP  
(Spent Fuel Pool  
Modification

STATE OF ILLINOIS )  
COUNTY OF COOK ) SS.

AFFIDAVIT OF ROBERT F. JANECEK

My name is Robert F. Janecek. I am employed by Commonwealth Edison Company as a Nuclear Licensing Administrator. My education and qualifications are set forth in my Affidavit dated March 18, 1981 concerning Board Question 2.


Two inconsistencies in Edison's testimony need to be corrected.

In the March 18, 1981 Affidavit I stated at pages 9 and 15 that the spent fuel pool cooling and cleanup systems are not seismically qualified. The NRC's Karl Kniel, in his Affidavit dated April 21, 1981 says that these systems need not be seismically qualified. However, Terry Pickens' prepared testimony for the November hearings, which was incorporated in the record following transcript page 94, includes the statement that the spent fuel pool cooling systems are Class I seismic components. Mr. Kniel and I are


8107020479

correct. Mr. Pickens misread the FSAR. The spent fuel pools and the proposed storage racks are seismically qualified, but the spent fuel pool cooling and clean-up systems are not.

There is another inconsistency which appears in Applicant's Licensing Report, Revs. 4 and 5 (Commonwealth Edison Exs. 1 and 2). On page 3-38 the statement is made that the minimum gap between two adjacent racks is 2.5" and the minimum gap between any rack and the adjacent pool wall is 3.5". However, Figure 3.1-2 on page 3-5 indicates that the minimum distance between racks is 1-3/4" and the minimum distance between any rack and the adjacent pool wall is 4-5/8". Figure 3.1-2 is correct. Applicant's conclusion that the proposed racks when arranged as shown in Figure 3.1-2 will not impact on each other or on the pool walls remains unchanged.

  
\_\_\_\_\_  
Robert F. Janecek

SUBSCRIBED AND SWORN TO  
before me this 6TH day  
of May, 1981.

  
\_\_\_\_\_  
Notary Public