



Commonwealth Edison
 One First National Plaza, Chicago, Illinois
 Address Reply to: Post Office Box 767
 Chicago, Illinois 60690

August 3, 1981



Mr. Darrell G. Eisenhut, Director
 Division of Licensing
 U.S. Nuclear Regulatory Commission
 Washington, DC 20555

Subject: Dresden Station Units 2 and 3
 Quad Cities Station Units 1 and 2
 Supplementary Information on Fire
 Protection Features to Meet
 10 CFR Appendix R - 125 Volt
D.C. Distribution

Reference (a): R. F. Janecek letter to D. G. Eisenhut
 dated May 19, 1981.

Dear Mr. Eisenhut:

In Reference (a), Commonwealth Edison detailed specific action for correction of a fire hazard identified on the 125 volt D.C. Distribution at Dresden Units 2 and 3 and Quad Cities Units 1 and 2. Preliminary detailed design drawings have been drafted to show the physical separation required of the D.C. Distribution switchgear.

Dresden Station electrical drawings 12E-2058C and 12E-3067B and Quad Cities electrical drawing 4E-1067B show the proposed separation of the D.C. switchgear and the addition of a three (3) hour fire wall. These drawings are presently in the comment stage due to lack of specific information on the new D.C. switchgear. Any changes to these drawings will be minor with the possible exception of the exact location of the new switchgear on Dresden Unit 3. Final detailed design drawings will be available when specific design information is obtained from the switchgear vendor. The work associated with this modification will be completed in accordance with paragraph 50.48(c)(4) of 10CFR50, Appendix R. Ten (10) copies of drawings 12E-2058C, 12E-3067B, and 4E-1067B are enclosed.

*A006
 5
 1/10*

Aperture Dist

Limited Dist. of Drawings

D. G. Eisenhut

- 2 -

August 3, 1981

Please address any question you may have concerning this matter to this office. One (1) signed original, and fifty-nine (59) copies of this cover letter are provided for your use.

Very truly yours,



Thomas J. Rausch
Nuclear Licensing Administrator
Boiling Water Reactors

cc: Region III Inspector - Dresden
Region III Inspector - Quad Cities

lm

2366N