




**Commonwealth Edison**  
 One First National Plaza, Chicago, Illinois  
 Address Reply to: Post Office Box 767  
 Chicago, Illinois 60690



December 29, 1981

Mr. Darrell G. Eisenhut, Director  
 Division of Licensing  
 U.S. Nuclear Regulatory Commission  
 Washington, DC 20555

Subject: Dresden Station Units 2 and 3  
 Modifications to Meet NUREG 0737  
 ITEM II.B.2 Requirements for Plant Shielding  
 NRC Docket Nos. 237/249

- References (a): D. L. Peoples letter to H. R. Denton dated January 1, 1980
- (b): J. S. Abel letter to D. G. Eisenhut dated December 15, 1980
- (c): J. S. Abel letter to D. G. Eisenhut dated December 31, 1980

Dear Mr. Eisenhut:

In References (a), (b), and (c) Commonwealth Edison Company committed to complete modifications associated with NUREG-0737 Item II.B.2 (NUREG-0578 Item 2.1.6.b) by January 1, 1982 at our operating nuclear stations. As part of this task, the Reactor Building Floor and Equipment Drain System is being modified to prevent automatic pumping to radwaste following an accident.

This is to inform you that this modification will not be completed by January 1, 1982 at Dresden Station Units 2 and 3. The modification is nearly complete; however, the power supply for the annunciators that was delivered with the new panel does not meet the design criteria. A DC input power supply was provided instead of an AC input power supply. We now expect to complete installation and testing of this system on Dresden Units 2 and 3 by February 15, 1982.

Please address any questions you may have concerning this matter to this office.

One (1) signed original and thirty-nine (39) copies of this transmittal are provided for your use.

Very truly yours,

*Thomas J. Rausch*  
 Thomas J. Rausch  
 Nuclear Licensing Administrator  
 Boiling Water Reactors

cc: RIII Inspector - Dresden  
 3121N

8201050224 811229  
 PDR ADDCK 05000237  
 PDR

*HO46  
 S/10*