




**Commonwealth Edison**  
 One First National Plaza, Chicago, Illinois  
 Address Reply to: Post Office Box 767  
 Chicago, Illinois 60690

February 1, 1982

Mr. Darrell G. Eisenhut, Director  
 Division of Licensing  
 U.S. Nuclear Regulatory Commission  
 Washington, DC 20555

Subject: Dresden Station Units 2 and 3  
Quad Cities Station Units 1 and 2  
Status of NUREG 0737 Item II.F.1.5  
Containment Water Level Monitor  
NRC Docket Nos. 50-237, 50-249,  
50-254 and 50-265



Reference (a): E. D. Swartz letter to D. G.  
 Eisenhut dated December 15, 1981.

Dear Mr. Eisenhut:

Reference (a) requested Commission approval to extend the implementation date for NUREG 0737 Item II.F.1.5, Containment Water Level Monitor, to February 1, 1982, for our Dresden and Quad Cities Stations. Qualified instruments have since been installed and currently provide an indication of torus water level in each control room.

These instruments are capable of providing an indication for normal torus water level and also ECCS suction line level. However, due to problems that we are currently experiencing in calibrating these instruments, the indicated level can only be considered as a "gross" indication of level.

A systems review has been initiated to determine the cause of our calibrational difficulties in order to insure that our accuracy requirements for the system are maintained. We expect to be able to submit a schedule for the resolution of this matter by February 19, 1982.

Current system operation has been discussed with both the Dresden and Quad Cities Station on-site NRC Resident Inspectors. This letter is being provided to document this status.

Please address any questions that you may have concerning this matter to this office.


*Hoak  
6/10*

8202090079 820201  
 PDR ADDCK 05000237  
 PDR

February 1, 1982

One (1) signed original and fifty-nine (59) copies of this letter are provided for your use.

Very truly yours,



E. Douglas Swartz  
Nuclear Licensing Administrator

EDS/lm

cc: J. G. Keppler (RIII)  
Region III Inspector - Dresden  
Region III Inspector - Quad Cities

3374N