



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

May 25, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Dresden Station Unit 3
Correction of Typographical
Error in License Amendment
59 to DPR-25
NRC Docket No. 50-249

References (a): J. D. Hegner letter to L. DelGeorge
dated March 26, 1982.

(b): T. J. Rausch letter to H. R. Denton
dated March 18, 1982.

Dear Mr. Denton:

Reference (a) issued Amendment No. 67 to the Dresden Unit 2
Provisional Operating License No. DPR-19 and Amendment 59 to the
Dresden Unit 3 Facility Operating License No. DPR-25 related to Scram
Discharge Volume (SDV) requirements. The page changes forwarded to
Dresden 3 were taken from those which Commonwealth Edison submitted
in Reference (b).

We recently discovered that note number 3 on page 24
(changed in Am. 59) to DPR-25 is incorrect due to a typographical
error in the page we provided in Reference (b). Specifically, the
note should read "Permissible to bypass when reactor pressure is <
600 psig." This note now reads " < 100 psig" due to this typogra-
phical error.

As was discussed with the Dresden 3 NRC Project Manager in
a May 24, 1982, telephone call, we have attached a corrected page 24
for you to reissue. We regret any inconvenience this may have
caused you.

One (1) signed original and thirty-nine (39) copies of this
transmittal are provided for your use.

Very truly yours,

Thomas J. Rausch
Nuclear Licensing Administrator

lm
Attachment
cc: Region III Inspector - Dresden

8206020359 820525
PDR ADDCK 05000249
PDR

4193N

A001
1/1