



**Commonwealth Edison**  
One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690

March 31, 1983

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: Dresden Station Unit 2  
Proposed Amendment to DPR-19  
Technical Specification  
Concerning Unidentified Reactor  
Coolant Leakage  
NRC Docket No: 50-237

- References (a): T. J. Rausch letter to H. R. Denton  
dated December 31, 1982.
- (b): B. Rybak letter to H. R. Denton  
dated March 1, 1983.
- (b): B. Rybak letter to H. R. Denton  
dated March 18, 1983.

Dear Mr. Denton:

Pursuant to 10 CFR 50.59, Commonwealth Edison proposes to amend Appendix A, Technical Specifications, to Provisional Operating License DPR-19 for Dresden Station Unit 2. This amendment, Attachment 1 to this letter, proposes changes to both the Technical Specifications and Bases and provides for specific actions to be taken under various unidentified reactor coolant leakage conditions for the ensuring operating cycle.

This proposed Amendment was deemed necessary by your staff as a result of crack indications found on recirculation piping during the current refueling outage and is a result of a series of discussions with us. It is our understanding that this change will be incorporated as part of a previous submittal (Reference (a)).

These proposed changes have received On-Site and Off-Site review and approval.

8304110601 830331  
PDR ADOCK 05000237  
P PDR

A601

Please address any questions regarding this matter to this office.

Three (3) signed originals and thirty-seven (37) copies of this letter with Attachment is provided for your use.

Very truly yours,



B. Rybak  
Nuclear Licensing Administrator

lm

cc: Region III Inspector - Dresden  
R. Gilbert - NRR

Attachment

SUBSCRIBED and SWORN to  
before me this 31st day  
of March, 1983

  
\_\_\_\_\_  
Notary Public