



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

April 25, 1983

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Dresden Station Units 2 and 3
Quad Cities Station Units 1 and 2
TMI Technical Specifications
Item II.K.3.15 (Isolation of HPCI
and RCIC) Generic Letter 83-02
NRC Docket Nos. 50-237, 50-249,
50-254, and 50-265

References (a): D. G. Eisenhut letter to All
Boiling Water Reactor Licensees
dated January 10, 1983.

(b): B. Rybak letter to H. R. Denton
dated April 20, 1983.

Dear Mr. Denton:

Reference (a) requested Commonwealth Edison to submit Technical Specifications for various NUREG-0737 (TMI) items following the guidance given by that letter. As detailed within reference (b) we have reviewed all these TMI items and, in some cases, provided justifications as to why Technical Specifications are not required.

Enclosed in the form of attachments are our proposed Technical Specification amendments for Item II.K.3.15 - Isolation of HPCI and RCIC. The proposed amendments specify the time delay settings for high steam flow for the HPCI system at Dresden Station and for both HPCI and RCIC systems at Quad Cities Station.

As this amendment is a requirement per NUREG-0737 and is designed to prevent inadvertent isolation of the formentioned systems this change does not increase the potential risk to public health and safety. These changes have undergone both On-Site and Off-Site review and approval.

As the changes are minor in nature and submitted at the request of the NRC, no amendment fees are being submitted.

A046

8304280053 830425
PDR ADOCK 05000237
P PDR

April 25, 1983

Please address any questions you may have regarding this matter to this office.

Three (3) signed originals and sixty (60) copies of this transmittal are provided for your use.

Very truly yours,




B. Rybak
Nuclear Licensing Administrator

lm

Attachment

cc: R. Gilbert - NRR
R. Bevan - NRR
NRC Resident Inspector - Dresden
NRC Resident Inspector - Quad Cities

SUBSCRIBED and SWORN to
before me this 25th day
of April, 1983


Notary Public

6424N

ATTACHMENT 1

Proposed Amendment for
DPR-19 and DPR-25

DPR-19

Revised Pages 38
39
44
45

DPR-25

Revised Pages 38
39
44
45*

* This page does not reflect changes made by Amendment 64 which is to be effective 30 days after installation of the degraded voltage modifications. Although these modifications have been installed on Dresden Unit 2, they will not be completed until the Fall, 1983 outage for Unit 3. If this amendment is approved prior to the Fall, 1983 outage, these pages should be properly amended by NRR.