



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

August 31, 1983

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Dresden Station Units 2 and 3
Quad Cities Station Units 1 and 2
Proposed Amendment to Appendix A
of the Technical Specifications
Reactor Protection System (RPS)
Power Monitoring System
NRC Docket Nos. 50-237, 50-249,
50-254, and 50-265

- References (a): D. B. Vassallo letter to L. O. DelGeorge
dated July 28, 1982 (TJR 82-298).
- (b): T. J. Rausch letter to H. R. Denton
dated February 4, 1983 (TJR 83-33).
- (c): B. Rybak letter to H. R. Denton
dated April 20, 1983.
- (d): B. Rybak letter to H. R. Denton
dated May 6, 1983.

Dear Mr. Denton:

Pursuant to 10 CFR 50.59, Commonwealth Edison proposes to amend Appendix A to the Technical Specifications to the Licenses of the subject facilities. The requested amendment changes proposed additional limiting conditions for operation for the Class 1E RPS power monitoring systems when the number of Class 1E power monitoring systems are less than specified and surveillance requirements which included a functional test, channel calibration, and verification of trip setpoints. These amendment changes have been requested by the NRC as modified per Reference (a) and were submitted in DRAFT form in References (c) and (d). The modifications required to install the Class 1E power monitoring systems has been completed on Dresden Unit 2 and Quad Cities Unit 1; for Dresden Unit 3 and Quad Cities Unit 2 the work will be completed during their Fall, 1983 outages. We have determined that operations with these RPS modifications, installed in accordance with 10 CFR 50.59, and without applicable Technical Specifications does not in any way compromise the safe operation of these facilities.

8309080164 830831
PDR ADOCK 05000237
P PDR

Add 9/10 w/check \$8,500

The attached changes have received both On-Site and Off-Site review and approval. We have reviewed these amendment requests and find that no significant hazard consideration exists. Our review is documented in Attachment 3. Commonwealth Edison is notifying the State of Illinois of our request for these amendments by transmittal of a copy of this letter and its attachments to the designated State officials. We have determined that these requests are a combined Class I and Class III per 10 CFR 170.22. As such, a fee remittance of \$8,800 for both sites is enclosed.

Please direct any questions you may have concerning this matter, to this office.

Three (3) signed originals and thirty-seven (37) copies of this transmittal are provided for your use.

Very truly yours,



B. Rybak

Nuclear Licensing Administrator

lm

Attachments

- cc: Region III Inspector - Dresden
- Region III Inspector - Quad Cities
- R. Gilbert - NRR
- R. Bevan - NRR
- G. Wright - Illinois

SUBSCRIBED and SWORN to before me this 1st day of September, 1983


Notary Public