



**Commonwealth Edison**  
One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690

August 17, 1983

TE HQ FILE COPY

Mr. James G. Keppler, Regional Administrator  
- Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Subject: Dresden Station Unit 3  
ECCS Suction Header  
Snubber Removal  
NRC Docket No. 50-249

Reference: A) Attachment to letter number COM-01-576,  
B.J. Whiteway to W.H. Koester, "Dresden  
Units 2 and 3, Torus Support Modifications,  
ECCS Suction Header Snubbers," dated  
January 4, 1980"

Dear Mr. Keppler:

During a meeting with the NRC to discuss the safety implication of the Dresden Unit 3 ECCS suction header snubber removal Mr. R. D. Walker of the NRC raised the concern of whether the analysis being presented included the SSE load condition. The analysis in question (Reference A), was that for the "no-snubber case". In response to this concern Nutech provided an assessment of that analysis and performed calculations to scale up the results to include the SSE load condition. As can be seen from their summary table the prior conclusion that the snubbers are not needed during the seismic event, does not change.

Please direct any questions you may have regarding this matter to this office.

Very truly yours,

B. Rybak  
Nuclear Licensing Administrator

lm

Attachment

cc: NRC Resident Inspector - Dresden  
Mr. R. D. Walker - Region III

7151N

8311070328 831103  
PDR ADDCK 05000249  
PDR

AUG 25 1983



July 8, 1983  
BJW-83-107

Mr. R. H. Mirochna  
Station Nuclear Engineering Department  
Commonwealth Edison Company  
P.O. Box 767 - 35 FN W  
Chicago, Illinois 60690

Subject: Dresden Units 2 & 3 ECCS Suction Header Seismic  
Analysis Calculations for SSE Case

Reference: Attachment to letter number COM-01-576,  
B. J. Whiteway to W. H. Koester, "Dresden  
Units 2 & 3, Torus Support Modifications,  
ECCS Suction Header Snubbers," dated  
January 4, 1980.

Dear Rick,

The reference letter presented calculations for the ECCS  
suction header seismic analysis for the OBE condition, for  
the case of no snubbers attached to the header. The  
attachment to this letter provides supplementary calculations  
for the SSE condition. Please add these to the referenced  
calculations.


The results for both conditions are listed below. As seen from  
the table, all stresses are below their respective code allow-  
ables.

Percent of Allowable Stress

<u>Location</u>	<u>OBE</u>	<u>SSE</u>
Header Pipe	53%	56%
Shell at Nozzles	83%	89%
Header Supports	68%	71%
Shell at Supports	81%	77%

If you need additional information, please call me.

Very truly yours,

  
B. J. Whiteway, P.E.  
Senior Director

Attachment

- cc: E. R. Zebus w/o attachment
- R. H. Buchholz w/o attachment
- W. V. Weber w/attachment
- File 27.200.0004 w/attachment

Project Dresden Nuclear Power Station File No. \_\_\_\_\_  
 Owner Commonwealth Edison Company  
 Client Commonwealth Edison Company

Check Vertical Strap for SSE + W  
 (Ref Computer Runs FRS009T + FRS002Y dtd 10/12/79)

OBE Load :  $\pm 8110 \#$   
 Weight :  $- 12,511 \#$  } from p. 4

SSE =  $2 \times OBE = 2 \times 8110 \# = 16,220 \#$   
 Weight =  $12,511$   
 SSE+W =  $28,731 \#$

$f_t = \text{tension stress} = \frac{28,731 \#}{2(1.5 - \frac{1}{2}(1\frac{1}{8}))} = 15,323 \text{ psi}$

$F_t = 0.45 F_y \times 1.33 = 21,550 \text{ psi} > f_t$   
 (ref AISC 1.5.1.1)  
 " " 1.5.1.6)

Revision	0					Page <u>2A</u> of <u>28</u>
Prepared By/Date	wvw 7/6/83					
Accuracy Chk By/Date	mmh 7/6/83					
Criteria Chk By/Date	mmh 7/6/83					

Project DRESDEN NUCLEAR POWER STATION

File No. \_\_\_\_\_

Owner COMMONWEALTH EDISON COMPANY

Client COMMONWEALTH EDISON COMPANY

checking torus shell stresses for Service Level C :-

Membrane S.I. for Service Level B

$$= 23.926 \text{ ksi}$$

Service level C combination includes SSE instead of OBE.

∴ the level C<sub>A</sub> stress can be conservatively assumed to be twice the above stress

∴ Membrane Stress intensity for Service level C load combination

$$= 2 \times 23.926 = 47.852 \text{ ksi}$$

Allowable stress = 1.5 S<sub>y</sub>

$$= 1.5 (35.86) = 53.79 \text{ ksi}$$

(PVAR vol. 2)

$$\therefore \frac{\text{Actual stress}}{\text{Allowable stress}} = \frac{47.852}{53.79} = 0.89$$

= 89%

For Service Level C, range is not required to be checked. (SSE load can not cause fatigue)

Revision	1				
Prepared By/Date	V. Kumar/6-9-83				
Checked By/Date	mml / 10/83				

Project Dresden Nuclear Power Station File No. \_\_\_\_\_  
 Owner Commonwealth Edison Company  
 Client Commonwealth Edison Company

Check Pipe Stress for SSE + W + P

Ref. Computer Run FRS009 T dtd 10/12/79  
 " " " FRS002 Y " "

For Pipe Critical Node 75 :

$$\begin{aligned} W &= 2927 \text{ psi} \\ P &= 1200 \text{ psi} \\ W+P &= 4127 \text{ psi} \end{aligned}$$

$$OBE = 9589 \text{ (p26)} - 4127 = 5462 \text{ psi}$$

$$SSE = 2 \times OBE = 2 \times 5462 = 10,924 \text{ psi}$$

$$SSE + W + P = 10,924 + 4,127 = 15,051 \text{ psi}$$

$$15,051 \text{ psi} < 27,000 \text{ psi Level C allowable}^*$$

\* ASME III, 1977 incl Winter Addenda

Revision	0					
Prepared By/Date	www 7/6/83					Page <u>26A</u>
Accuracy Chk By/Date	mmh 7/6/83					of <u>28</u>
Criteria Chk By/Date	mmh 7/6/83					

Project Dresden Nuclear Power Station File No. \_\_\_\_\_  
 Owner Commonwealth Edison Company  
 Client Commonwealth Edison Company

STRESSES FOR STRAP PAD PLATE-TO-SHELL JUNCTIONS  
 (FOR ALL SNUBBERS REMOVED)

Reference: (1) Results of Torus Suction Ring Header Analysis for all snubbers attached; prepared for CECO by NUTECH; Doc No. COM-01-589, Attachment A, January 1980. File 64.311.0029.

Method of Calculation: Pages 24-34 of Reference 1 report the shell stresses due to 1000 lb vertical and horizontal load at the strap-pads. The actual stresses are calculated using the ratio of the maximum strap loads to 1000 lbs.

Maximum Strap Loads:

Vertical Strap:  $OBE + DW = 20621 \text{ lb.}$   
 $SSE + DW = 28731 \text{ lb.}$

\*\* Horizontal Strap  $OBE + DW = 5971 \text{ lb.}$   
 $SSE + DW = 10575 \text{ lb.}$

\*\* Horizontal strap load at SE2B due to  $OBE_I$  (Pg. 4)

$F_x = \pm 3275$      $F_y = \pm 1687$      $F_z = \pm 3275$

due to DW (Pg. 4)

$F_x = 1888$      $F_y = -973$      $F_z = -1888$

	<u>5163</u>	<u>714</u>	<u>1387</u>	
DW + $OBE_I$ {	-1387	-2660	-5163	Resultant 5393 lb.
	8438	2401	4662	9934 lb.
DW + $SSE_I$ {	-4662	-4347	-8438	-10575 lb.

Revision	0						Page <u>27A</u>
Prepared By/Date	mmh 7/1/83						of <u>28</u>

Project Dresden Nuclear Power Station

File No. \_\_\_\_\_

Owner Commonwealth Edison Company

Client Commonwealth Edison Company

## STRESS CALCULATION DUE (DW + OBE I)

Maximum Vertical Load = 20 261 lb.

MEMBRANE STRESS:

$$\sigma_{\phi} = \frac{20\,261\text{ lb}}{1000\text{ lb}} (136\text{ psi}) + 19\,300^* \text{ psi} = 22\,055 \text{ psi}$$

$$\sigma_x = \frac{20\,261\text{ lb}}{1000\text{ lb}} (183\text{ psi}) + 19\,300^* \text{ psi} = 23\,007 \text{ psi}$$

$$\tau = \frac{20\,261\text{ lb}}{1000\text{ lb}} (35\text{ psi}) = 709 \text{ psi}$$

$$SI = \frac{1}{2} \left( 22\,055 + 23\,007 + \sqrt{(22\,055 - 23\,007)^2 + 4(709)^2} \right)$$

$$= 23\,385 \text{ psi} < 28\,950 \text{ psi}$$

PRIMARY + SECONDARY STRESS RANGE:

$$\sigma'_{\phi} = \frac{20\,261\text{ lb}}{1000\text{ lb}} (800\text{ psi}) = 16\,208.8 \text{ psi}$$

$$\sigma'_x = \frac{20\,261\text{ lb}}{1000} (593\text{ psi}) = 12\,015 \text{ psi}$$

$$\tau = \frac{20\,261\text{ lb}}{1000\text{ lb}} (35\text{ psi}) = 709 \text{ psi}$$

$$SI = 2 \times \frac{1}{2} \left( 16\,208.8 + 12\,015 + \sqrt{(16\,208.8 - 12\,015)^2 + 4(709)^2} \right)$$

$$+ 19\,300$$

$$= 51\,950 \text{ psi} < 69\,300 \text{ psi}$$

\* Assume applied general membrane stress = maximum service limit A or B allowable stress

Revision	0			
Prepared By/Date	mmh 7/7/83			

Project Dresden Nuclear Power Station File No. \_\_\_\_\_  
 Owner Commonwealth Edison Company  
 Client Commonwealth Edison Company

Maximum Horizontal Load = 5971 lb.

MEMBRANE STRESS:

$$\sigma_{\phi} = \frac{5971 \text{ lb}}{1000 \text{ lb}} (222 \text{ psi}) + 19300^* \text{ psi} = 20626 \text{ psi}$$

$$\sigma_x = \frac{5971 \text{ lb}}{1000} (276 \text{ psi}) + 19300^* \text{ psi} = 20942 \text{ psi}$$

$$\tau = \frac{5971 \text{ lb}}{1000} (39 \text{ psi}) = 233 \text{ psi}$$

$$SI = \frac{1}{2} (20626 + 20942 + \sqrt{(20626 - 20942)^2 + 4(233)^2})$$

$$= 21066 \text{ psi} < 28950 \text{ psi}$$

PRIMARY + SECONDARY STRESS RANGE:

$$\sigma'_{\phi} = \frac{5971}{1000} (1384 \text{ psi}) = 8264 \text{ psi}$$

$$\sigma'_x = \frac{5971}{1000} (1030 \text{ psi}) = 6150 \text{ psi}$$

$$\tau = \frac{5971}{1000} (39 \text{ psi}) = 233 \text{ psi}$$

$$SI = 2 \times \frac{1}{2} (8264 + 6150 + \sqrt{(8264 - 6150)^2 + 4(233)^2}) + 19300$$

$$= 35879 \text{ psi} < 69,300 \text{ psi}$$

\* Assume applied general membrane stress = max. service limit A or B allowable

Revision	0				
Prepared By/Date	mmh 7/7/83				
					Page <u>27C</u> of <u>28</u>



Project Dresden Nuclear Power Station File No. \_\_\_\_\_  
 Owner Commonwealth Edison Company  
 Client Commonwealth Edison Company

## STRESS CALCULATION DUE TO (DW + BSE<sub>x</sub>)

Maximum Vertical Load = 28731 lb.

MEMBRANE STRESS:

$$\sigma_{\phi} = \frac{28731 \text{ lb}}{1000 \text{ lb}} (136 \text{ psi}) + 35860 \text{ psi}^{**} = 39767 \text{ psi}$$

$$\sigma_x = \frac{28731 \text{ lb}}{1000 \text{ lb}} (123 \text{ psi}) + 35860 \text{ psi}^{**} = 41118 \text{ psi}$$

$$\tau = \frac{28731 \text{ lb}}{1000} (35 \text{ psi}) = 1006 \text{ psi}$$

$$SI = \frac{1}{2} (39767 + 41118 + \sqrt{(39767 - 41118)^2 + 4(1006)^2})$$

$$= 41654 \text{ psi} < 53790 \text{ psi} \quad (1.5S_y = 53790 \text{ psi})$$

Maximum Horizontal Load = 10757 lb.

MEMBRANE STRESS:

$$\sigma_{\phi} = \frac{10757 \text{ lb}}{1000 \text{ lb}} (222) + 35860 \text{ psi}^{**} = 38248 \text{ psi}$$

$$\sigma_x = \frac{10757 \text{ lb}}{1000 \text{ lb}} (275 \text{ psi}) + 35860 \text{ psi}^{**} = 38818 \text{ psi}$$

$$\tau = \frac{10757 \text{ lb}}{1000 \text{ lb}} (39 \text{ psi}) = 420 \text{ psi}$$

$$SI = \frac{1}{2} (38248 + 38818 + \sqrt{(38248 - 38818)^2 + 4(420)^2})$$

$$= 39040 < 53790 \text{ psi}$$

Ref. ASME Sec  
Fig. NE-3221-3  
& Table I-21

\*\* Assuming General Membrane Stress = Max. Allowable = 1.0S<sub>y</sub> (@ 165°F)

Revision	0				
Prepared By/Date	MMH 7/7/83				Page <u>27 D</u> of <u>28</u>

Project Dresden Nuclear Power Station File No. \_\_\_\_\_  
 Owner Commonwealth Edison Company  
 Client Commonwealth Edison Company

## STRESS SUMMARY

SHELL STRESS AT STRAP DAD PLATE JUNCTION  
(Maximum)

STRAP	LOAD	MEMBRANE $P_m$			MEMBRANE + BENDING $(P_m + P_b + Q)$		
		S.I KSI	ALLOW. KSI	%	SI (KSI)	ALLOW. KSI	%
Vertical	DW+OBE <sub>T</sub>	23.4	28.95	81%	51.95	69.3	75%
	DW+SSE <sub>T</sub>	41.65	53.79	77%	NA	NA	NA
Horizontal	DW+OBE <sub>T</sub>	21.06	28.95	73%	35.9	69.3	52%
	DW+SSE <sub>T</sub>	39.04	53.79	73%	NA	NA	NA