



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

January 10, 1984

Mr. Darrell G. Eisenhut, Director
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Response to Generic Letter 83-41 "Fast
Cold Starts of Diesel Generators"
Dresden Station Units 2 and 3
Quad Cities Station Units 1 and 2
Zion Station Units 1 and 2
LaSalle County Station Units 1 and 2
NRC Docket Nos. 50-237/249, 50-254/265,
50-295/304, and 50-373/374

Dear Mr. Eisenhut:

We have reviewed the subject request for information regarding diesel generator fast cold start (without prelubrication and warmup of any moving parts of the diesel generator).

Our diesel generator lubrication systems provide for some prelubrication with some warming (via heaters) of some moving parts of the diesel generator. As such our diesel generators have been subjected to no cold starts as defined by the subject letter.

If you have any questions regarding this subject please address them to this office. One (1) original and forty (40) copies are provided for your use.

Respectfully,

P. L. Barnes

P. L. Barnes
Nuclear Licensing Administrator

cc: RIII - J. G. Keppler
RIII Inspectors - D/QC/Z/LSC

7964N

8401170339 840110
PDR ADOCK 05000237
PDR

*A056
1/10*