



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

March 15, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Dresden Station Units 2 and 3
Proposed Amendment to Technical
Specification for Facility Operating
License DPR-19 and DPR-25
NRC Docket Nos. 50-237 and 50-249

Dear Mr. Denton:

Pursuant to 10 CFR 50.59, Commonwealth Edison proposes to amend Appendix A, Technical Specification, to Facility Operating Licenses DPR-19 and 25. A description of the changes is included in Attachment A.

The proposed changes are enclosed in Attachment B. The attached changes have been received both Onsite and Offsite review and approval. We have reviewed this amendment request and find that no significant hazards consideration exists. Our review is documented in Attachment C. Commonwealth Edison is notifying the State of Illinois of our request of this amendment by transmittal of a copy of this letter and its attachments to the designated State Official.

We have determined that this request is a 10 CFR 170, Class I and Class III amendment request. As such a fee remittance of \$4,400.00 is enclosed.

Please direct any questions you may have concerning this matter to this office.

Acc 11 w/check \$4,400 # 202965

8403220153 840315
PDR ADOCK 05000237
PDR

H. R. Denton

- 2 -

March 15, 1984

Three (3) signed originals and thirty-seven (37) copies of this transmittal and its attachments are provided for your use.

Very truly yours,



B. Rybak
Nuclear Licensing Administrator

lm

Attachments (A): Description of the Amendment Request
(B): Technical Specification Change to DPR-19 and DPR-25
(C): Evaluation of Significant Hazards Consideration

cc: Region III Inspector - Dresden
G. Wright - Ill.
R. Gilbert - NRR

SUBSCRIBED and SWORN to
before me this 15th day
of March, 1984


Notary Public

8269N

ATTACHMENT A

Description of Amendment Request

The basic purpose of this amendment request is to update the snubber tables to reflect additions, deletions and other changes which have occurred. With the completion of both the Mark I and I.E. Bulletin 79-14 work on both units and the Scram Discharge Volume modifications on Unit 3, additional snubbers are to be added to the snubber table. Additional changes are being made. They are:

- (1) Revised Sections 3.6.I.2 and 3.6.I.4 to remove any reference to the Torus Ring Header Snubber work which has been completed at both units.
- (2) Combined Tables 3.6.I.a and 3.6.I.b into a single table. No references will be made to the type of snubbers which are used.
- (3) Revised the description of the functional testing (4.6.I.2 and 4) of mechanical snubbers to allow for velocity range tests as required by certain types of snubbers (Anchor-Darling) which until recently were not used at the site.
- (4) Deleted Snubber No. 35 (Unit 3 only) which was found not to be required during the Mark I containment program.
- (5) Changed three hydraulic snubbers in the isolation condenser pipe way to two mechanical units and one rigid restraint at each unit. The use of a rigid restraint was allowed as the engineering analysis showed insufficient thermal movement at the location.