



**APPLICABLE TO:**  
 PUBLICATION NO. NEDO-24146A  
 T. I. E. NO. 79NED273  
 TITLE LOCA ANALYSIS REPORT FOR  
DRESDEN UNITS 2, 3 AND QUAD  
CITIES 1,2 NUCLEAR POWER STATIONS  
 ISSUE DATE APRIL 1979

### ERRATA And ADDENDA SHEET

NO. 9  
 DATE January 1983

*NOTE: Correct all copies of the applicable publication as specified below.*

ITEM	REFERENCES (SECTION, PAGE PARAGRAPH, LINE)	INSTRUCTIONS (CORRECTIONS AND ADDITIONS)
1	Page 4-14	Replace with new page 4-14. (Change brackets in right-hand margin indicate areas where report has been revised.)

8403270136 840319  
 PDR ADOCK 05000249  
 P PDR

Table 40

## MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Quad Cities 2FUEL TYPE: P8DGB298 (Barrier Fuel)

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	9.9	1962	0.016
1,000	9.9	1959	0.016
5,000	10.4	2000	0.018
10,000	11.7	2148	0.028
15,000	12.0	2198	0.033
20,000	11.9	2194	0.033
25,000	11.6	2153	0.029
30,000	10.9	2074	0.034
35,000	10.2	1963	0.032
40,000	9.5	1827	0.009

NOTE: Same as Table 4I.

Table 4P

## MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Dresden 2,3/  
Quad Cities 1,2FUEL TYPES: P8DRB265L, P8DGB265L (Barrier Fuel)

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	11.6	2171	0.032
1,000	11.6	2177	0.033
5,000	12.0	2198	0.034
10,000	12.1	2195	0.033
15,000	12.1	2199	0.033
20,000	11.9	2187	0.032
25,000	11.3	2115	0.025
30,000	10.7	2018	0.018
35,000	10.2	1927	0.022
40,000	9.6	1834	0.009

NOTE: Same as Table 4I.