



Tennessee Valley Authority, Post Office Box 2000, Soddy Daisy, Tennessee 37384-2000

July 12, 2017


Chattanooga Environmental Field Office
Division of Water Pollution Control
1301 Riverfront Parkway, #206
Chattanooga, Tennessee 37402-2013

TENNESSEE VALLEY AUTHORITY (TVA) - SEQUOYAH NUCLEAR PLANT (SQN) - NPDES
PERMIT NO. TN0026450 - DISCHARGE MONITORING REPORT (DMR) FOR June 2017

Enclosed is the June 2017 Discharge Monitoring Report for Sequoyah Nuclear Plant. There were no exceedances during the reporting period. Attachment 1 is enclosed and provides information on a sewage tank overflow that occurred during the reporting period. At no time was there any threat to drinking water supplies, human health, or the environment. If you have any questions or need additional information, please contact Millicent Garland by email at mrmoore@tva.gov or by phone at (423) 843-6714.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,



Anthony L. Williams
Site Vice President
Sequoyah Nuclear Plant

Enclosures

cc (Enclosures):
U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

IEZS
NRR

Attachment 1
TVA Sequoyah Plant
NPDES Permit TN0026450

Description and Duration of Event

On June 15, 2017 at approximately 10:30 am, SQN site personnel observed water overflowing from a sewage holding tank located behind the Switchyard building and into a nearby yard drain. This drain leads to the Yard Pond and from there to the Diffuser Pond. The Diffuser Pond discharges through Outfall 101 to the Tennessee River. The sewage tank had been pumped empty on June 13, 2017, and there was no evidence of sewage on the ground. The cause of the overflow was found to be a toilet that had been "running" for approximately 2 days, which overwhelmed the holding tank with potable water. The water supply to the toilet was cut off on June 15, 2017, at about 10:40 am which prevented further overflow of the sewage tank. A fecal coliform sample was collected at the yard drain, and the resulting bacterial count was 0 colony forming units per 100 mL. At no time was there any threat to public drinking supplies, human health, or the environment.

Actions Taken to Mitigate Reoccurrence

SQN has documented the event in the TVA Corrective Action Program and is in the process of determining corrective actions to reduce or prevent recurrence. Condition Report (CR) 1316248 has been written to develop corrective actions designed to mitigate reoccurrence.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 **101 G**
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 17	06	01	To 17	06	30

*** NO DISCHARGE ***

ATTN:Millicent Garland

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE		*****	*****	**	*****	*****	39.1	04	0	30 / 30	RCORDR
00010 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	*****	*****	Req. Mon. DAILY MAX	DEG. C.		CONTINUOUS	CALCTD
TEMPERATURE, WATER DEG. CENTIGRADE		*****	*****	**	*****	*****	27.3	04	0	30 / 30	MODEL
00010 Z 0 INSTREAM MONITORING	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C		*****	*****	**	*****	*****	2.4	04	0	30 / 30	CALCTD
00016 1 S EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	*****	*****	3.0 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
FLOW, IN CONDUIT OR THRU TREATMENT PLANT		*****	*****	03	*****	*****	*****	**	0	30 / 30	RCORDR
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	***		CONTINUOUS	RCORDR
FLOW, IN CONDUIT OR THRU TREATMENT PLANT		1878	*****	03	*****	*****	*****	03	0	30 / 30	CALCTD
50050 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	Req. Mon. MO AVG	*****	MGD	*****	*****	*****	MGD		CONTINUOUS	CALCTD
CHLORINE, TOTAL RESIDUAL		*****	*****	**	*****	0.017	0.027	19	0	23 / 30	GRAB
50060 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	0.1 MO AVG	0.1 DAILY MAX	MG/L		FIVE PER WEEK	CALCTD
TEMPERATURE - C, RATE OF CHANGE		*****	0.8	62	*****	*****	*****	**	0	30 / 30	CALCTD
82234 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	2.0 DAILY MX	DEG C/HR	*****	*****	*****	****		CONTINUOUS	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Anthony L. Williams Site Vice President		423 843-7001		17	07	11
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No closed mode operation. The following injections occurred: Flogard 6236 (max calc. was 0.03, limit -- 0.20 mg/L, Flogard MS 6237 (max calc. was 0.036 phosphate, limit 0.20 mg/L, and 0.01 zinc, limit - 0.20 mg/L), Spectrus BD 1500 (max calc. was 0.02 mg/L, limit - 2.0 mg/L, Spectrus CT 1300 (max calc. 0.03 mg/L, limit - -0.05 mg/L).

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR

(SUBR 01)

F - FINAL

BIOMONITORING FOR OUTFALL 101

EFFLUENT

Form Approved.

OMB No. 2040-0004

TN0026450
 PERMIT NUMBER

101 T
 DISCHARGE NUMBER

MONITORING PERIOD							
YEAR	MO	DAY	YEAR	MO	DAY		
From	17	06	01	To	17	06	30

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN:Millicent Garland

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP3B 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	42.8 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP6C 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	42.8 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Anthony L. Williams Site Vice President		743	843-7001	17	07	11
TYPED OR PRINTED		AREA CODE	NUMBER	YEAR	MO	DAY

[Signature]
 Site Vice President
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Toxicity was not sampled in June 2017

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR

(SUBR 01)

F - FINAL

LOW VOL. WASTE TREATMENT POND

EFFLUENT

Form Approved.

OMB No. 2040-0004

TN0026450 **103 G**
 PERMIT NUMBER DISCHARGE NUMBER


MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
17	06	01	To	17	06	30

ATTN:Millicent Garland

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**	7.1	*****	8.6	12	0	6 / 30	GRAB
00400 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		ONCE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	5.4	5.4	19	0	1 / 30	GRAB
00530 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	30.0 MO AVG	100.0 DAILY MX	MGL		ONCE/ MONTH	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	<5.0	<5.0	19	0	1 / 30	GRAB
00556 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	15.0 MO AVG	20.0 DAILY MX	MGL		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	1.047	1.387	03	*****	*****	*****	**	0	6 / 30	INSTAN
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	**		ONCE/ WEEK	INSTAN
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Anthony L. Williams Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Site Vice President SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			AREA CODE	NUMBER	YEAR	MO	DAY
			423	843-7001	17	07	11

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-6N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR (SUBR 01)
 F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

Form Approved.
 OMB No. 2040-0004

TN0026450 **110 G**
 PERMIT NUMBER DISCHARGE NUMBER


MONITORING PERIOD
 From **17 06 01** To **17 06 30**

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN:Millicent Garland

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	*****	*****	REPORT DAILY MX	DEG C		CONTINUOUS	CALC'D
TEMPERATURE, WATER DEG. CENTIGRADE 00010 Z 0	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
INSTREAM MONITORING	PERMIT REQUIREMENT	*****	*****	**	*****	*****	30.5 DAILY MX	DEG C		CONTINUOUS	CALC'D
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C 00016 1 0	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	*****	*****	5 DAILY MX	DEG C		CONTINUOUS	CALC'D
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0	SAMPLE MEASUREMENT	*****		03	*****	*****	*****	**			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MX	MGD	*****	*****	*****	**		CONTINUOUS	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0	SAMPLE MEASUREMENT	*****	*****	**	*****			19			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	*****	0.1 MO.AVG	0.1 DAILY MX	MG/L		Five per Week	CALC'D
TEMPERATURE - C, RATE OF CHANGE 82234 1 0	SAMPLE MEASUREMENT	*****		04	*****	*****	*****	**			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C	*****	*****	*****	**		CONTINUOUS	CALC'D
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Anthony L. Williams Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423	843-7001	17	07	11
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  Site Vice President		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR

(SUBR 01)

F - FINAL

RECYCLED COOLING WATER

EFFLUENT

Form Approved.

OMB No. 2040-0004

TN0026450 **110 T**
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
 From

YEAR	MO	DAY
17	06	01

 To

YEAR	MO	DAY
17	06	30

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN:Millicent Garland

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP3B 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	42.8 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP6C 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	42.8 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Anthony L. Williams Site Vice President		423	843-7001	17	07	11
TYPED OR PRINTED		AREA CODE	NUMBER	YEAR	MO	DAY

[Signature]
 Site Vice President
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR

(SUBR 01)

F - FINAL

WASTEWATER & STORM WATER

EFFLUENT

Form Approved.

OMB No. 2040-0004

TN0026450
 PERMIT NUMBER

118 G
 DISCHARGE NUMBER

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
17	06	01	To	17	06	30

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN:Millicent Garland

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO)	SAMPLE MEASUREMENT	*****	*****	**		*****	*****		19		
00300 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	***	2 MINIMUM	*****	*****		MG/L	TWICE/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	***	*****	*****	100 DAILY MX		MG/L	TWICE/WEEK	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		25			
00545 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	***	*****	*****	1 DAILY MX		ML/L	ONCE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*		ONCE/BATCH	ESTIMA
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Anthony L. Williams Site Vice President		743 843-7001		17	07	11
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall. No Discharge this Period