

ATTACHMENT 2

Proposed Change to Appendix A
Technical Specifications to
Operating License DPR-19

Revised pages: 3/4.1-5
3/4.1-8
3/4.1-9
3/4.1-10
B 3/4.1-12
B 3/4.1-20
3/4.2-12
3/4.2-13
3/4.2-21

Please note these changes include those previously submitted for RETS and include proposed changes which will be shortly submitted for an amendment to reflect the installation of an analog trip system.

9170N

8410110004 840927
PDR ADDCK 05000237
P PDR

TABLE 3.1.1

REACTOR PROTECTION SYSTEM (SCRAM) INSTRUMENTATION REQUIREMENTS

Minimum Number Operable Inst. Channels per Trip (1) System	Trip Function	Trip Level Setting	Modes in Which Function Must be Operable			
			Refuel (7)	Startup/Hot		Action*
				Standby	Run	
1	Mode Switch in Shutdown		X	X	X	A
1	Manual Scram		X	X	X	A
	IRM					
3	High Flux	(LT/E) 120/125 of Full Scale	X	X	X(5)	A
3	Inoperative		X	X	X(5)	A
	APRM					
2	High Flux	Specification 2.1.A.1	X	X(9)	X	A or B
2	Inoperative**		X	X(9)	X	A or B
2	Downscale	(GT/E) 5/125 of Full Scale	X(12)	X(12)	X(13)	A or B
2	High Flux (15% Scram)	Specification 2.1.A.2	X	X	X(14)	A
2	High Reactor Pressure	(LT/E) 1060 psig	X(11)	X	X	A
2	High Drywell Pressure	(LT/E) 2 psig	X(8), X(10)	X(8), (10)	X(10)	A
2	Reactor Low Water Level	(GT/E) 1 inch***	X	X	X	A
2 (Per Bank)	High Water Level in Scram Discharge Volume (Thermal and dP Switch)	(LT/E) 40 inches above bottom of the Instrument Volume	X(2)	X	X	A or D
2	Turbine Condenser Low Vacuum	(GT/E) 23 in. Hg Vacuum	X(3)	X(3)	X	A or C
2	Main Steam Line High Radiation	(LT/E) 3 X Full Power Background	X(3)	X(3)	X(15)	A or C
4(6)	Main Steam Line Isolation Valve Closure	(LT/E) 10% Valve Closure	X(3)	X(3)	X	A or C
2	Generator Load Rejection	****	X(4)	X(4)	X(4)	A or C
2	Turbine Stop Valve Closure	(LT/E) 10% Valve Closure	X(4)	X(4)	X(4)	A or C
2	Turbine Control - Loss of Control Oil Pressure	(GT/E) 900 psig	X	X	X	A or C

Notes: (LT/E) = Less than or equal to.
(GT/E) = Greater than or equal to.
(Notes continue on next two pages)

TABLE 4.1.1

SCRAM INSTRUMENTATION FUNCTIONAL TESTS

MINIMUM FUNCTIONAL TEST FREQUENCIES FOR SAFETY INSTR. AND CONTROL CIRCUITS

<u>Instrument Channel</u>	<u>Group (3)</u>	<u>Functional Test</u>	<u>Minimum Frequency (4)</u>
Mode Switch in Shutdown	A	Place Mode Switch in Shutdown	Each Refueling Outage
Manual Scram	A	Trip Channel and Alarm	Every 3 Months
IRM			
* High Flux	C	Trip Channel and Alarm (5)	Before Each Startup (6)
* Inoperative	C	Trip Channel and Alarm	Before Each Startup (6)
APRM			
High Flux	B	Trip Output Relays (5)	Once Each Week
Inoperative	B	Trip Output Relays	Once Each Week
Downscale	B	Trip Output Relays (5)	Once Each Week
High Flux (15% scram)	B	Trip Output Relays	Before Each Startup
High Reactor Pressure	A	Trip Channel and Alarm	(1)
High Drywell Pressure	A	Trip Channel and Alarm	(1)
Reactor Low Water Level (2)	B	(8)	(1)
High Water Level in Scram Discharge Volumes (Thermal and dp Switch)	A	Trip Channel and Alarm (7)	Every 3 Months
Turbine Condenser Low Vacuum	A	Trip Channel and Alarm	(1)
Main Steam Line High Radiation (2)	B	Trip Channel and Alarm (5)	Once Each Week
Main Steam Line Isolation Valve Closure	A	Trip Channel and Alarm	(1)
Generator Load Rejection	A	Trip Channel and Alarm	(1)
Turbine Stop Valve Closure	A	Trip Channel and Alarm	(1)
Turbine Control - Loss of Control Oil Pressure	A	Trip Channel and Alarm	(1)

Notes: (See next page.)

NOTES: (For Table 4.1.1)

1. Initially once per month until exposure hours (M as defined on Figure 4.1.1) is 2.0×10^5 ; thereafter, according to Figure 4.1.1 with an interval not less than one month nor more than three months. The compilation of instrument failure rate data may include data obtained from other Boiling Water Reactors for which the same design instrument operates in an environment similar to that of Dresden Unit 3.
2. An instrument check shall be performed on low reactor water level once per day and on high steam line radiation once per shift.
3. A description of the three groups is included in the Bases of this Specification.
4. Functional tests are not required when the systems are not required to be operable or are tripped. If tests are missed, they shall be performed prior to returning the systems to an operable status.
5. This instrumentation is exempted from the Instrument Functional Test Definition (1.0.G). This Instrument Function Test will consist of injecting a simulated electrical signal into the measurement channels.
6. If reactor start-ups occur more frequently than once per week, the functional test need not be performed; i.e., the maximum functional test frequency shall be once per week.
7. Only the electronics portion of the thermal switches will be tested using an electronic calibrator during the three month test. A water column or equivalent will be used to test the dp switches.

TABLE 4.1.2

SCRAM INSTRUMENTATION CALIBRATIONS

MINIMUM CALIBRATION FREQUENCIES FOR REACTOR PROTECTION INSTRUMENT CHANNELS

<u>Instrument Channel</u>	<u>Group (1)</u>	<u>Calibration Test</u>	<u>Minimum Frequency (2)</u>
* High Flux IRM	C	Comparison to APRM after Heat Balance	Every Shutdown (4)
High Flux APRM	B	Heat Balance	Once Every 7 Days
Output Signal	B	Standard Pressure and Voltage Source	Refueling Outage
Flow Bias			
High Reactor Pressure	A	Standard Pressure Source	Every 3 Months
High Drywell Pressure	A	Standard Pressure Source	Every 3 Months
Reactor Low Water Level	B	Water Level	(5)
Turbine Condenser Low Vacuum	A	Standard Vacuum Source	Every 3 Months
Main Steam Line High Radiation	B	Standard Current Source (3)	Every 3 Months
Turbine Control - Loss of Control Oil Pressure	A	Pressure Source	Every 3 Months
High Water Level in Scram Discharge Volume (dp only)	A	Water Level	Once per Refueling Outage

NOTES: (For Table 4.1.2)

1. A description of the three groups is included in the bases of this Specification.
2. Calibration tests are not required when the systems are not required to be operable or are tripped. If tests are missed, they shall be performed prior to returning the systems to an operable status.
3. The current source provides an instrument channel alignment. Calibration using a radiation source shall be made during each refueling outage.
- *4. If reactor startups occur more frequently than once per week, the functional test need not be performed; i.e., the maximum functional test frequency shall be once per week.
5. Trip units are calibrated monthly concurrently with functional testing. Transmitters are calibrated once per operating cycle.

3.1

LIMITING CONDITION FOR OPERATION BASES (Continued)

system can tolerate a single failure and still perform its intended function of scrambling the reactor. Three APRM instrument channels are provided for each protection trip system.

APRM's #1 and #3 operate contacts in a one subchannel and APRM's #2 and #3 operate contacts in the other subchannel. APRM's #4, #5 and #6 are arranged similarly in the other protection trip system. Each protection trip system has one more APRM than is necessary to meet the minimum number required per channel. This allows the bypassing of one APRM per protection trip system for maintenance, testing or calibration. Additional IRM channels have also been provided to allow for bypassing of one such channel. The bases for the scram settings for the IRM, APRM, high reactor pressure, reactor low water level, generator load rejection, and turbine stop valve closure are discussed in Specification 2.3.

Instrumentation (pressure switches) in the drywell are provided to detect a loss of coolant accident and initiate the emergency core cooling equipment. This instrumentation is a backup to the water level instrumentation which is discussed in Specification 2.2. A scram is provided at the same setting as the emergency core cooling system (ECCS) initiation to minimize the energy which must be accommodated during a loss of coolant accident and to prevent the reactor from going critical following the accident.

The control rod drive scram system is designed so that all of the water which is discharged from the Reactor by a scram can be accommodated in the discharge piping. A part of this system is an individual instrument volume for each of the south and north CRD accumulators. These two volumes and their piping can hold in excess of 90 gallons of water and is the low point in the piping. No credit was taken for these volumes in the design of the discharge piping relative to the amount of water which must be accommodated during a scram. During normal operations, the discharge volumes are empty; however, should either volume fill with water, the water discharged to the piping from the Reactor may not be accommodated which could result in slow scram times or partial or no control rod insertion. To preclude this occurrence, level switches have been installed in both volumes which will alarm and scram the Reactor when the volume remaining in either instrument volume is approximately 40 gallons. For diversity of level sensing methods that will ensure and provide a scram, both differential pressure switches and thermal switches have been incorporated into the design and logic of the system. The setpoint for the scram signal has been chosen on the basis of providing sufficient volume remaining to accommodate a scram even with 5 gpm leakage per drive into the SDV. As indicated above, there is sufficient volume in the piping to accommodate the scram without impairment of the scram times or the amount of insertion of the control rods. This function shuts the Reactor down while sufficient volume remains to accommodate the discharged water and precludes the situation in which a scram would be required but not be able to perform its function properly.

4.1 SURVEILLANCE REQUIREMENT BASES (Cont'd.)

A comparison of Tables 4.1.1 and 4.1.2 indicates that six instrument channels have not been included in the latter Table. These are: Mode Switch in Shutdown, Manual Scram, High Water Level in Scram Discharge Volume dp and Thermal Switches, Main Steam Line Isolation Valve Closure, Generator Load Rejection, and Turbine Stop Valve Closure. All of the devices or sensors associated with these scram functions are simple on-off switches and, hence, calibration is not applicable; i.e., the switch is either on or off. Further, these switches are mounted solidly to the device and have a very low probability of moving; e.g., the switches in the scram discharge volume tank. Based on the above, no calibration is required for these six instrument channels.

- B. The MFLPD for fuel fabricated by GE shall be checked once per day to determine if the APRM gains or scram requires adjustment. This may normally be done by checking the LPRM readings, TIP traces, or process computer calculations.

Only a small number of control rods are moved daily and thus the peaking factors are not expected to change significantly and thus a daily check of the MFLPD is adequate.

For fuel fabricated by ENC, the power distribution will be checked once per day to ensure consistency with the power distribution assumptions of the fuel design analysis for overpower conditions. During periods of operation beyond these power distribution assumptions, the APRM gains or scram settings may be adjusted to ensure consistency with the fuel design criteria for overpower conditions.

TABLE 3.2.3

INSTRUMENTATION THAT INITIATES ROD BLOCK

Minimum No. of Operable Inst. Channels Per Trip System (1)	Instrument	Trip Level Setting
1	APRM upscale (flow bias) (7)	Less than or equal to (0.58 W_D plus 50) (FRP/MFLDP) (See Note 2)
1	APRM upscale (refuel and Startup/Hot Standby mode)	Less than or equal to 12/125 full scale
2	APRM downscale (7)	Greater than or equal to 3/125 full scale
1	Rod block monitor upscale (flow bias) (7)	Less than or equal to (0.65 W_D plus 45)
1	Rod block monitor downscale (7)	Greater than or equal to 5/125 full scale
3	IRM downscale (3)	Greater than or equal to 5/125 full scale
3	IRM upscale	Less than or equal to 108/125 full scale
3	IRM detector not fully inserted in the core	N/A
2 (5)	SRM detector not in startup position	(4)
2 (5) (6)	SRM upscale	Less than or equal to 10^5 counts/sec.
1 (per bank)	Scram discharge volume water level - high	(LT/E) 26 inches above the bottom of the instrument volume

Notes:
(See Next Page)

NOTES: (For Table 4.2.1) (Cont'd.)

9. The functional test of the Scram Discharge Volume thermal switches is not applicable; i.e., the switch is either on or off. Further, these switches are mounted solidly to the device and have a very low probability of moving; e.g., the thermal switches in the scram discharge volume tank. Based on the above, no calibration is required for these instrument channels.
10. Functional test shall include verification of the second level undervoltage (degraded voltage) timer bypass and shall verify operation of the degraded voltage 5-minute timer and inherent 7-second timer.
11. Verification of time delay setting between 3 and 9 seconds shall be performed during each refueling outage.
12. Trip units are functionally tested monthly. A calibration of the trip units is to be performed concurrent with the functional testing.

TABLE 3.2.3 (Notes)

1. For the Startup/Hot Standby and Run positions of the Reactor Mode Selector Switch, there shall be two operable or tripped trip systems for each function, except the SRM rod blocks, IRM upscale, IRM downscale and IRM detector not fully inserted in the core need not be operable in the "Run" position and APRM downscale, APRM upscale (flow bias), and RBM downscale need not be operable in the Startup/Hot Standby mode. A RBM upscale need not be operable at less than 30% rated thermal power. One channel may be bypassed above 30% rated thermal power provided that a limiting control rod pattern does not exist. For systems with more than one channel per trip system, if the first column cannot be met for both trip systems, the systems shall be tripped. For the scram discharge volume water level high rod block, there is one instrument channel per bank.
2. W_D percent of drive flow required to produce a rated core flow of 98 Mlb/hr. MFLPD = highest value of FLPD for G.E. fuel.
3. IRM downscale may be bypassed when it is on its lowest range.
4. This function may be bypassed when the count rate is greater than or equal to 100 cps.
5. One of the four SRM inputs may be bypassed.
6. This SRM function may be bypassed in the higher IRM ranges when the IRM upscale Rod Block is operable.
7. Not required while performing low power physics test at atmospheric pressure during or after refueling at power levels not to exceed 5 MWt.

ATTACHMENT 3

Evaluation of Significant Hazards Consideration

Description of Amendment Request

Subsequent to a failure of 76 of 185 control rods to fully insert at Browns Ferry Unit 3 in response to a manual scram signal, the Commission had embarked on an indepth review of the BWR control rod drive system which identified a number of design issues requiring both short and long term corrective measures. On October 1, 1980 letters were sent to all BWR licensees requesting commitments to reevaluate the present scram system and modifying it as necessary to meet both the design and performance criteria as developed by the BWR Owners Subgroup. Accordingly, a Confirmatory Order was written June 24, 1983 for Dresden Unit 2 regarding a schedule for implementation of the long term corrective actions. That Confirmatory Order also provided model technical specification changes. Based on our final design and upon a review of the model technical specifications, Commonwealth Edison is proposing a number of changes to Appendix A of the Technical Specification for Dresden Unit 2 in accordance with the forementioned Confirmatory Order.

Basis for Proposed No Significant Hazards Consideration Determination

The Commission has provided guidance concerning the application of standards for determining whether a significant hazards consideration exists by providing specific examples. The examples of actions involving no significant hazards consideration include: (ii) changes that constitute an additional limitation or restriction or control not presently within the technical specifications e.g., a more stringent surveillance requirement.

The changes proposed in this application for amendment is encompassed by this example because of the additional limitations and restrictions that will be added by this Technical Specification amendment.

Therefore, since the application for amendment involves a proposed change that is similar to an example for which no significant hazards consideration exists, Commonwealth Edison has made a proposed determination that the application involves no significant hazards consideration.