



**Commonwealth Edison**  
One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690

January 17, 1985

Mr. James G. Keppler  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Subject: ~~Dresden Station Units 2 and 3~~  
Supplemental Response to IE Bulletin 84-02  
NRC Docket Nos. 50-237/249

- References (a): IE Bulletin No. 84-02 - R. C. DeYoung letter  
to All OLs and CPs dated March 12, 1984
- (b): G. L. Alexander letter to J. G. Keppler  
dated July 11, 1984
- (c): G. L. Alexander letter to J. G. Keppler  
dated August 8, 1984

Dear Mr. Keppler:

Reference (b) contained Dresden Station's initial response to IE Bulletin 84-02. At that time a commitment was made to replace all nylon or lexan coil spool-type normally energized or de-energized HFA relays used in Class 1E Safety systems.

Upon further consideration, the station has decided to limit the replacement program to the scope outlined in the Bulletin. The revised commitment should include replacement of nylon or Lexan coil spool-type HFA relays used in normally energized Class 1E safety systems and nylon coil spool-type HFA relays used in normally de-energized Class 1E safety systems.

Reference (b) also contained a commitment to visually inspect most safety-related normally energized relays on a monthly basis. Since July 1984 these visual inspections have not detected additional relays with coil deterioration; therefore, we plan to discontinue the visual inspections for Dresden Unit 3 starting February 18, 1985.

8501240066 850117  
PDR ADCK 05000237  
PDR  
G


A001  
1/0

Dresden Unit 2 is currently down for refueling. By the end of the outage approximately 275 out of 295 relays will have been replaced. The remaining relays associated with the Standby Gas Treatment System will be replaced by March 31, 1985 in conjunction other work.

Please address any questions that you or your staff may have concerning our response to this office.

One (1) signed original is being sent directly to the USNRC Document Control Desk in Washington, DC for reproduction and distribution as requested in the Bulletin.

Respectfully,



G. L. Alexander  
Nuclear Licensing Administrator

cc: US NRC, Document Control Desk  
Washington, DC 20555

RIII Inspector - D

9517N